

Monthly Overflow Report

Date Range: January, 2007

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	10611065	01/03/07	01/03/07	1.5 hours	0.00005	0.00	Roots	340 Plus Park Blvd, Line Cleaned.
000	06509059	01/05/07	01/05/07	2.5 hours	0.00009	0.00	Grit/Debris	213 Kenya Ct, Line Cleaned.
000	14702018	01/13/07	01/13/07	2 hours	0.00009	0.00	Grease	4811 Abbay Dr, Line Cleaned.
000	10703017	01/19/07	01/19/07	2 hours	0.00005	0.00	Roots	53 Century Blvd, Clean line.
000	14703008	01/27/07	01/27/07	2.5 hours	0.00006	0.00	Grease	4095 Nolensville Rd, Line Cleaned.
103	McCrary Creek PS	01/22/07	01/22/07	1.17 hours	0.037	0.00	Mechanical	#5 Line shaft failed. Emergency repairs completed.
176	Dodson Chapel PS	01/06/07	01/07/07	11.22 hours	2	0.84	Rainfall	Rainfall.
222	Barker Road	01/05/07	01/05/07	1.67 hours	0.01	0.84	Rainfall	Rainfall.
222	Barker Road	01/07/07	01/07/07	4.92 hours	0.036	0.64	Rainfall	Rainfall.
222	Barker Road	01/21/07	01/21/07	4.42 hours	0.29	0.88	Rainfall	Rainfall.

Monthly Overflow Report

Date Range: January, 2007

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	----------------	----------	----------------	---------

Sanitary Sewer Overflows

117	Neely's Bend PS	01/07/07	01/07/07	5 hours	0.25	0.81	Rainfall	Rainfall.
-----	-----------------	----------	----------	---------	------	------	----------	-----------

Monthly Overflow Report

Date Range: January, 2007

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05914038	01/01/07	01/01/07	3.4 hours	0.00006	0.00	Grit/Debris	749 Work Dr & Crouch Dr, Line Cleaned.
000	08013014	01/05/07	01/05/07	6 hours	0.00013	0.00	Grit/Debris	Briley Parkway @ Briley Parkway Ramp. Line Cleaned.
000	08008006	01/07/07	01/07/07	1 hours	0.00002	0.00	Grease	2842 Hydes Ferry Rd. Line Cleaned.
000	05914030	01/07/07	01/07/07	2.45 hours	0.00003		Grease	740 Mooremans Arm Rd & Crouch Dr, Line Cleaned.
000	06915033	01/15/07	01/15/07	0 hours	0	0.89	Excessive Flow	3814 Stewarts Ln,Backed up from 60" trunk.
104	Whites Creek PS	01/05/07	01/05/07	1.42 hours	0.146	0.99	Rainfall	Rainfall.
104	Whites Creek PS	01/24/07	01/24/07	0.33 hours	0.023	0.00	Controller	Air compressor failed causing controller problem.
114	Davidson Branch PS	01/05/07	01/05/07	1.67 hours	0.001	0.89	Rainfall	Rainfall.
217	Basswood	01/07/07	01/07/07	5.5 hours	0.205	0.89	Rainfall	Rainfall.

Monthly Overflow Report

Date Range: January, 2007

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

111	Brentwood PS	01/01/07	01/03/07	42.11 hours		0.99	Rainfall	Rainfall.
111	Brentwood PS	01/05/07	01/07/07	46.95 hours		1.05	Rainfall	Rainfall.
111	Brentwood PS	01/07/07	01/10/07	60.27 hours		0.88	Rainfall	Rainfall.
111	Brentwood PS	01/15/07	01/17/07	20.28 hours		0.78	Rainfall	Rainfall.
111	Brentwood PS	01/21/07	01/23/07	34.69 hours		0.82	Rainfall	Rainfall.
111	Brentwood PS	01/24/07	01/24/07	1.08 hours		0.00	Excessive Flow	I/I from previous rainfall.