

Monthly Overflow Report

Date Range: March, 2007

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	08608101	03/03/07	03/03/07	3 hours	0.00005	0.00	Roots	908 Market Sq, Line Cleaned.
000	08505015	03/07/07	03/07/07	3 hours	0.00001	0.00	Grease	Heartland Drive. Line cleaned.
000	18003012	03/07/07	03/07/07	3 hours	0.00009	0.00	Grease	6713 Holt Rd, Line Cleaned.
000	07213009	03/07/07	03/07/07	3 hours	0.00002	0.00	Grit/Debris	2367 Gallatin Pk. Line Cleaned.
000	13613001	03/09/07	03/09/07	2.5 hours	0.0007	0.00	Grease	5304 Cane Ridge Rd, Line Cleaned.
000	WMN30K068	03/12/07	03/12/07	3 hours	0.00011	0.00	Grit/Debris	901 Creekwood Dr, Line Cleaned.
000	08702034	03/12/07	03/12/07	2.5 hours	0.0001	0.00	Grit/Debris	4621 Raccoon Trail, Line Cleaned.
000	12005036	03/18/07	03/18/07	2.5 hours	0.00009	0.00	Roots	418 Southwood Dr, Line Cleaned.
000	13209034	03/20/07	03/20/07	1 hours	0.00002	0.00	Line Collapse	966 Battery Ln, Line repaired and televised.
000	09306038	03/24/07	03/24/07	2.5 hours	0.00008	0.00	Grit/Debris	Malloy St & 4th Ave So, Line Cleaned.
000	14906055	03/31/07	03/31/07	2 hours	0.00003	0.00	Grease	3012 Split Oak Tr. Line Cleaned.
103	McCrary Creek PS	03/01/07	03/01/07	4.67 hours	0.383	0.83	Other/not listed	Construction debris from construction @ Dodson Chapel PS.
103	McCrary Creek PS	03/28/07	03/28/07	4.08 hours	0.267	1.40	Controller	Pumps airlocked. Pump operating range adjusted.

Monthly Overflow Report

Date Range: March, 2007

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	13007039	03/01/07	03/01/07	2 hours	0.00003	0.00	Grit/Debris	3910 Trimble Rd, Line Cleaned.
000	05909027	03/17/07	03/17/07	1.5 hours	0.00007	0.00	Grit/Debris	1040 Rambling Brook, Line Cleaned.

Monthly Overflow Report

Date Range: March, 2007

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

111	Brentwood PS	03/01/07	03/03/07	19.25 hours	1.19	0.85	Rainfall	Rainfall.
-----	--------------	----------	----------	-------------	------	------	----------	-----------