

Monthly Overflow Report

Date Range: May, 2007

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	16112171	05/04/07	05/04/07	1 hours	0.00005	0.00	Grit/Debris	Hickory Tr. Line Cleaned
000	11714141	05/05/07	05/05/07	4.5 hours	0.00009	0.00	Grease	3900 Hillsboro Pk. Line Cleaned
000	08309000	05/08/07	05/08/07	6.5 hours	0.00012	0.00	Grease	601 McFerrin St,Line Cleaned
000	09209120	05/14/07	05/14/07	1.5 hours	0.00003	0.00	Grease	3920 Clifton Ave. Line Cleaned.
000	14814000	05/24/07	05/24/07	3 hours	0.00004	0.00	Rags	4740 Colemont Pl. Line Cleaned
133	Holiday Travel Park PS	05/05/07	05/05/07	2 hours	0.005	1.88	Rainfall	Rainfall.

Monthly Overflow Report

Date Range: May, 2007

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
109	Dry Creek PS	05/05/07	05/05/07	0.25 hours	0.05	1.88	Rainfall	Rainfall.
127	Madison Heights PS	05/05/07	05/05/07	1.5 hours	0.001	1.88	Rainfall	Rainfall.
132	Berwick Trail PS / Center St.	05/05/07	05/05/07	0.08 hours	0.0001	1.88	Rainfall	Rainfall.

Monthly Overflow Report

Date Range: May, 2007

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14507042	05/06/07	05/06/07	1 hours	0.00002	0.00	Grit/Debris	5016 Granny White Pk. Line Cleaned
000	05815039	05/15/07	05/15/07	2 hours	0.00003	0.00	Grit/Debris	4125 Home Haven Dr. Line Cleaned,
000	05904076	05/22/07	05/22/07	1.5 hours	0.00003	0.00	Grit/Debris	2856 Creekbend Dr, Line Cleaned.
114	Davidson Branch PS	05/11/07	05/11/07	1.92 hours	0.025	0.69	Power Out	Power outage during thunderstorm. Pumps tripped and reset.
170	Edinburgh PS	05/04/07	05/05/07	3 hours	0.001	2.41	Rainfall	Rainfall.

Monthly Overflow Report

Date Range: May, 2007

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

111	Brentwood PS	05/12/07	05/12/07	2.78 hours	0.28	1.98	Rainfall	Rainfall.
-----	--------------	----------	----------	------------	------	------	----------	-----------