

Monthly Overflow Report

Date Range: September, 2007

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14812100	09/07/07	09/07/07	1 hours	0.00002	0.00	Roots	4721 Richards Ct. Line Cleaned.
000	12006036	09/12/07	09/12/07	10.5 hours	0.0012	0.00	Grit/Debris	1350 Murfreesboro Rd. Line Cleaned.
000	09314208	09/18/07	09/18/07	3 hours	0.00004	0.00	Grit/Debris	710 6th Ave S. Debris from collapsed svc line. Line Cleaned.
131	Hurricane Creek PS	09/11/07	09/11/07	0.05 hours	0.02	2.32	Controller	Telemetry alarm failed. #3 pump in standby. Alarms repaired.

Monthly Overflow Report

Date Range: September, 2007

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05012001	09/09/07	09/09/07	4 hours	0.00005	0.00	Grit/Debris	3466 Dickerson Rd. Line Cleaned
000	15811005	09/12/07	09/12/07	3 hours	0.00003	0.00	Line Collapse	321 White Swans Crossings. Line Repaired.
000	06013000	09/17/07	09/17/07	5 hours	0.00004	0.00	Grit/Debris	2725 Combs Dr, Line Cleaned. Sewer overflowed at clean out.
000	10401041	09/24/07	09/24/07	1.5 hours	0.00003	0.00	Roots	3129 Bellwood Ave Mason St. Line Cleaned
145	Joelton PS	09/10/07	09/10/07	3.5 hours	0.021	0.50	Rainfall	I/I flow from new development. Corrected by contractor.

Monthly Overflow Report

Date Range: September, 2007

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

111	Brentwood PS	09/11/07	09/11/07	2.25 hours	0.064	1.36	Rainfall	Station pumping above rated capacity.
111	Brentwood PS	09/27/07	09/27/07	1.42 hours	0.04	1.20	Rainfall	Station pumping above rated capacity.