

Monthly Overflow Report

Date Range: October, 2007

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09211099	10/03/07	10/03/07	0.5 hours	0.00002	0.00	Grit/Debris	356 Leslie Ave. Line Cleaned
000	17308022	10/04/07	10/04/07	2 hours	0.00004	0.00	Grit/Debris	5401 Oak Chase Dr. Line Cleaned
000	08305000	10/08/07	10/08/07	0.5 hours	0.00002	0.00	Roots	705 N 12th & Eastland Ave. (Cleanout overflowed)
000	08605096	10/08/07	10/08/07	2 hours	0.00005	0.00	Grit/Debris	3901 Central Pk. Line Cleaned
000	12001008	10/09/07	10/09/07	4 hours	0.00007	0.00	Grease	1130 Murfreesboro Rd. Line Cleaned
000	14815011	10/17/07	10/17/07	3 hours	0.00004	0.00	Grit/Debris	Sewer located at I-24 West. Line Cleaned
000	14916030	10/19/07	10/19/07	1 hours	0.00002	0.63	Line Collapse	Murfreesboro Pk. & Bell Rd. Line Repaired.
000	11714000	10/23/07	10/24/07	20 hours	0.00035	3.81	Grit/Debris	2201 Bandywood Dr. (Cleanout Overflowed).
000	06111059	10/25/07	10/25/07	5 hours	0.00011	3.32	Grit/Debris	1001 Hunters Meadow Ln.
000	10513000	10/30/07	10/30/07	1.5 hours	0.00002	0.00	Grit/Debris	11th Ave So, Line Cleaned. (Clean Out Overflowed.)
130	Brown's Creek PS / Visco Dr.	10/23/07	10/23/07	2.25 hours	0.383	3.54	VFD or Soft Start	#2 and #4 VFDs OoS. Both VFDs have been repaired.
222	Barker Road	10/23/07	10/24/07	16.59 hours	2.507	3.33	Rainfall	

Monthly Overflow Report

Date Range: October, 2007

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04310017	10/09/07	10/09/07	2 hours	0.00005	0.00	Grit/Debris	706 N. Dupont Ave. Line Cleaned

Monthly Overflow Report

Date Range: October, 2007

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

111	Brentwood PS	10/23/07	10/25/07	23.58 hours	0.814	4.14	Rainfall	Station pumping above rated capacity.
-----	--------------	----------	----------	-------------	-------	------	----------	---------------------------------------