

Monthly Overflow Report

Date Range: November, 2007

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	10513000	11/06/07	11/06/07	3.5 hours	0.00004	0.00	Grit/Debris	2216 11th Ave So, Line Clean, Overflowed from cleanout.
000	09206000	11/07/07	11/07/07	3 hours	0.00004	0.00	Grit/Debris	2831 Clifton Ave, Line Clean, Overflowed from clean out.
000	11903048	11/08/07	11/08/07	3.5 hours	0.00005	0.00	Grit/Debris	220 Dodge Dr, Line Cleaned.
000	13512004	11/19/07	11/19/07	4 hours	0.00005	0.00	Grit/Debris	2063 Nasboro Blvd, Line Cleaned.
000	08303022	11/19/07	11/19/07	4.5 hours	0.00006	0.00	Grit/Debris	2039 Greenwood Ave, Line Cleaned.
000	08302000	11/20/07	11/20/07	2 hours	0.00002	0.00	Grit/Debris	1317 Greenwood Ave. Line Cleaned. Sewer in basement.
000	056QL036	11/27/07	11/28/07	1.5 hours	0.00002	0.00	Grit/Debris	827 Stonebrook Blvd, Line Cleaned.
000	07107056	11/28/07	11/28/07	3 hours	0.00005	0.00	Line Collapse	1814 Meridian St, Line Repaired.
222	Barker Road	11/14/07	11/15/07	3.83 hours	0.11	1.25	Rainfall	

Monthly Overflow Report

Date Range: November, 2007

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09107001	11/02/07	11/02/07	4.5 hours	0.00005	0.00	Grease	5100 Kentucky Ave, Line Cleaned
114	Davidson Branch PS	11/14/07	11/14/07	4.17 hours	0.115	1.30	Power Out	Two pumps tripped at station. Overflow cleared upon reset.
114	Davidson Branch PS	11/22/07	11/22/07	3.5 hours	0.051	1.33	Rainfall	Rainfall.
126	Cleeces Ferry PS	11/14/07	11/14/07	0.69 hours	0.05	1.30	Power Out	Power tripped at station. Overflow cleared upon reset.