

Monthly Overflow Report

Date Range: December, 2007

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	11808042	12/11/07	12/11/07	0.5 hours	0.00001	0.00	Grit/Debris	2319 Winford Ave. Line Cleaned.
000	09601020	12/18/07	12/18/07	6 hours	0.001	0.00	Line Collapse	212 Riverpoint Ct. Sewer repaired.
000	14705006	12/22/07	12/22/07	1.5 hours	0.00002	0.00	Grit/Debris	306 Blackman Rd. Line Cleaned
000	11911104	12/23/07	12/23/07	1.5 hours	0.00002	0.00	Roots	47 East Thompson Ln. Line Cleaned.
000	13413086	12/29/07	12/29/07	6.5 hours	0.001	0.00	Grit/Debris	289 Paragon Mills Rd. Line Cleaned
000	13308000	12/31/07	12/31/07	1.5 hours	0.00003	0.00	Grease	537 Cathy Jo Cir, Line Cleaned.
222	Barker Road	12/28/07	12/28/07	7 hours	0.344	0.93	Rainfall	

Monthly Overflow Report

Date Range: December, 2007

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

000	00212000	12/24/07	12/24/07	3.5 hours	0.00005	0.00	Grit/Debris	1755 Lake Rd. Line Cleaned.
-----	----------	----------	----------	-----------	---------	------	-------------	-----------------------------

Monthly Overflow Report

Date Range: December, 2007

Whites Creek WWTP NPDES# TN 0024970

Volume

#	Overflow Name	Start Date	End Date	Duration	(mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	------	----------	----------------	---------

Sanitary Sewer Overflows

000	12911000	12/04/07	12/04/07	2 hours	0.00003	0.00	Grit/Debris	311 Cana Circle. Line Cleaned.
000	05016009	12/11/07	12/11/07	0.5 hours	0.00001	0.00	Grit/Debris	364 Oakview Dr. Line Cleaned
104	Whites Creek PS	12/12/07	12/12/07	0.42 hours	0.012	1.07	Rainfall	Rainfall. All equipment in service.
104	Whites Creek PS	12/28/07	12/29/07	3.16 hours	0.121	1.03	Rainfall	Rainfall. All equipment in service.
114	Davidson Branch PS	12/20/07	12/20/07	3.5 hours	0.018	0.90	Rainfall	Rainfall. All equipment in service.
114	Davidson Branch PS	12/28/07	12/28/07	4.25 hours	0.074	1.09	Rainfall	Rainfall. All equipment in service.
206	Brookwood Terrace	12/28/07	12/28/07	3.5 hours	0.001	1.03	Grease	47 Brookwood Ter. Line Cleaned

Monthly Overflow Report

Date Range: December, 2007

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

111	Brentwood PS	12/20/07	12/21/07	17.25 hours	0.396	0.86	Rainfall	Rainfall. Station pumping above rated capacity.
111	Brentwood PS	12/28/07	12/29/07	22.08 hours	0.652	0.94	Rainfall	Rainfall. Station pumping above rated capacity.