

Monthly Overflow Report

Date Range: January, 2008

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09605000	01/04/08	01/04/08	1.45 hours	0.00002	0.00	Grease	223 Donelson Pk, Line Cleaned. Overflowed from cleanout.
000	WMN56L044	01/05/08	01/05/08	4 hours	0.001	0.00	Grit/Debris	WMN056-L-044 Johnson Ind. Line Cleaned.(Williamson Co)
000	06316042A	01/06/08	01/06/08	2 hours	0.00001	0.00	Grit/Debris	5140 Southfork Blvd. Line Cleaned.
000	08401000	01/09/08	01/09/08	2 hours	0.00001	0.00	Grit/Debris	829 Rose Park Dr, Line Cleaned. Sewer backed into basement.
000	12009000	01/09/08	01/09/08	9 hours	0.001	0.00	Line Collapse	609 Glenpark Ct, Sewer Line Repaired.
000	10412108	01/11/08	01/11/08	3 hours	0.00004	0.00	Grit/Debris	2001 18th Ave So, Line Cleaned.
000	10516033	01/12/08	01/12/08	3 hours	0.00002	0.00	Grit/Debris	408 Hollydale Dr, Line Cleaned.
000	14710033	01/20/08	01/20/08	3 hours	0.00005	0.00	Grit/Debris	5029 Edmondson Pk, Line Cleaned
000	08113028	01/25/08	01/25/08	5 hours	0.001	0.00	Grit/Debris	Dr. Walter Davis, Line Cleaned.
000	14811019	01/29/08	01/29/08	1.5 hours	0.001	0.00	Line Blockage	3939 Apache Trail, Line Cleaned.
103	McCrary Creek PS	01/10/08	01/10/08	6.25 hours	0.436	2.06	Rainfall	Inflow/Infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	01/10/08	01/11/08	8.58 hours	1.311	1.05	Rainfall	Inflow/Infiltration. Station at rated capacity.
189	Langford Farms PS	01/10/08	01/10/08	6.47 hours	0.02	1.63	Rainfall	Inflow/Infiltration. Station at rated capacity.
222	Barker Road	01/10/08	01/11/08	24.42 hours	8.21	2.06	Rainfall	

Monthly Overflow Report

Date Range: January, 2008

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	10302052	01/28/08	01/28/08	3 hours	0.00005	0.00	Roots	5627 Meadow Crest Ln, Line Cleaned
114	Davidson Branch PS	01/10/08	01/10/08	3.08 hours	0.037	0.59	Rainfall	Inflow/Infiltration. Station at rated capacity.
114	Davidson Branch PS	01/31/08	02/01/08	3.08 hours	0.042	0.79	Rainfall	Inflow/Infiltration. Station at rated capacity.
148	Cockrill Bend PS	01/15/08	01/15/08	0.08 hours	0.001	0.00	Power Out	NES Power outage. Power restored.

Monthly Overflow Report

Date Range: January, 2008

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

111	Brentwood PS	01/10/08	01/12/08	38.42 hours	1.671	1.31	Rainfall	Inflow/Infiltration. Station at rated capacity (6,500 gpm).
111	Brentwood PS	01/31/08	02/02/08	35.5 hours	1.291	0.85	Rainfall	Inflow/Infiltration. Station at rated capacity (6,500 gpm).