

# Monthly Overflow Report

Date Range: February, 2008

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	10412000	02/01/08	02/01/08	2.5 hours	0.00002	0.00	Grit/Debris	1700 Bernard Ave, Line Cleaned. Overflow out of clean out.
000	09708062	02/05/08	02/05/08	2.5 hours	0.001	0.00	Grit/Debris	100 Lake Chateau, Line Cleaned.
000	07108000	02/14/08	02/14/08	4.5 hours	0.00014	0.00	Line Collapse	402 E Trinity Ln. NES Caused.
000	13316045	02/21/08	02/21/08	2 hours	0.00012	0.00	Roots	293 Garry Dr, Line Cleaned.
158	Farmingham Woods PS	02/22/08	02/22/08	6 hours	0.00075	0.00	Mechanical	Broken shaft on #2 pump. #1 pump OoS (ordered 2/15/08).
222	Barker Road	02/01/08	02/01/08	12 hours	0.269	0.76	Rainfall	Rainfall
226	Cowan St. Relief Bleeder	02/06/08	02/06/08	7.75 hours	0.216	1.16	Rainfall	Rainfall.
329	Village Court	02/04/08	02/04/08	2.5 hours	0.001	0.00	Roots	901 Village Ct, Line Cleaned.

---

# Monthly Overflow Report

Date Range: February, 2008

---

Dry Creek WWTP NPDES# TN0020648

Volume

#	Overflow Name	Start Date	End Date	Duration	(mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	------	----------	----------------	---------

## Sanitary Sewer Overflows

000	04309031	02/25/08	02/25/08	1 hours	0.00002	0.00	Grit/Debris	300 Gallatin Rd, Line Cleaned.
106	Vandiver PS	02/06/08	02/06/08	4.67 hours	0.057	0.99	Rainfall	Inflow/Infiltration. Station at rated capacity.

# Monthly Overflow Report

Date Range: February, 2008

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	07009096	02/11/08	02/11/08	2.45 hours	0.00006	0.00	Grit/Debris	3305 Curtis Hill Ct, Line Cleaned.
000	09112027	02/14/08	02/14/08	4.1 hours	0.00014	0.00	Grit/Debris	4600 Delaware Ave, Line Cleaned.
104	Whites Creek PS	02/01/08	02/01/08	6 hours	0.212	0.73	Rainfall	Inflow/Infiltration. Station at rated capacity.
104	Whites Creek PS	02/06/08	02/06/08	0.92 hours	0.032	1.16	Rainfall	Inflow/Infiltration. Station at rated capacity.
114	Davidson Branch PS	02/06/08	02/09/08	4.5 hours	0.106	1.11	Rainfall	Inflow/Infiltration. Station at rated capacity.
217	Basswood	02/06/08	02/06/08	1.5 hours	0.007	1.11	Rainfall	Rainfall

---

# Monthly Overflow Report

Date Range: February, 2008

---

## Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

## Sanitary Sewer Overflows

111	Brentwood PS	02/06/08	02/06/08	8.17 hours	0.213	0.41	Rainfall	Inflow/Infiltration. Station at rated capacity (6,500 gpm).
-----	--------------	----------	----------	------------	-------	------	----------	-------------------------------------------------------------