

Monthly Overflow Report

Date Range: March, 2008

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	10402038	03/04/08	03/04/08	1.15 hours	0.00002	1.68	Grit/Debris	3135 Long Blvd
000	10611000	03/10/08	03/10/08	1.2 hours	0.00002	0.00	Grit/Debris	305 Hill Rd Overflowed into Building
000	06210015	03/11/08	03/11/08	2.5 hours	0.00003	0.00	Grit/Debris	201 Rudy Cir
000	07309066	03/19/08	03/19/08	7 hours	0.001	1.84	Rainfall	Cooper Ter & Cooper Ln Inflow / Infiltration
000	08602062	03/19/08	03/19/08	5.5 hours	0.001	1.71	Rainfall	Old Lebanon Dirt Rd Inflow / Infiltration
000	07206000	03/20/08	03/20/08	1 hours	0.00002	0.00	Grit/Debris	3004 Gallatin Pk. Clean out overflowed.
000	07515047	03/26/08	03/26/08	1.35 hours	0.00002	0.00	Grit/Debris	831 Netherlands Dr
103	McCrary Creek PS	03/19/08	03/19/08	5.42 hours	0.205	1.71	Rainfall	Inflow/Infiltration. Station at rated capacity.
124	Williamson Ferry PS	03/19/08	03/19/08	6.83 hours	0.371	2.23	Rainfall	Inflow/Infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	03/19/08	03/20/08	20.83 hours	10.117	2.00	Rainfall	Inflow/Infiltration. Station at rated capacity.
133	Holiday Travel Park PS	03/04/08	03/05/08	26.25 hours	0.55	1.30	Rainfall	Inflow/Infiltration. Station at rated capacity.
133	Holiday Travel Park PS	03/19/08	03/19/08	9.05 hours	0.19	1.71	Rainfall	Inflow/Infiltration. Station at rated capacity.
140	28th Avenue PS / Centennial	03/19/08	03/19/08	7.33 hours	0.191	2.45	Rainfall	Inflow/Infiltration. Station at rated capacity.
189	Langford Farms PS	03/19/08	03/19/08	12.39 hours	0.04	1.91	Rainfall	Inflow/Infiltration. Station at rated capacity.
198	Lakeview P.S.	03/19/08	03/19/08	6.3 hours	0.001	1.92	Rainfall	Inflow/Infiltration. Station at rated capacity.
222	Barker Road	03/04/08	03/05/08	17.16 hours	1.403	1.30	Rainfall	Inflow / Infiltration
222	Barker Road	03/15/08	03/15/08	6.83 hours	0.128	1.03	Rainfall	Inflow / Infiltration
222	Barker Road	03/19/08	03/20/08	31.84 hours	13.537	1.71	Rainfall	Inflow / Infiltration
226	Cowan St. Relief Bleeder	03/19/08	03/20/08	16.92 hours	1.311	2.23	Rainfall	Inflow/Infiltration. Station at rated capacity.
310	Omohundro Dr. @ Filt Plnt	03/19/08	03/20/08	20.83 hours	0.1	2.00	Rainfall	Inflow / Infiltration
311	Omohundro Dr.-E of RR brg	03/19/08	03/20/08	20.83 hours	0.1	2.00	Rainfall	Inflow / Infiltration
312	Briley Pky (Sanborn)	03/19/08	03/19/08	5.1 hours	0.001	2.00	Rainfall	Inflow / Infiltration
328	Cooper Lane	03/19/08	03/19/08	7 hours	0.001	1.84	Rainfall	Inflow / Infiltration
329	Village Court	03/19/08	03/19/08	30 hours	0.001	2.23	Rainfall	901 Village Ct. Inflow / Infiltration
370	Lisa Lane Overflow	03/19/08	03/19/08	19.5 hours	0.01	2.00	Rainfall	Inflow / Infiltration
371	Apex St.	03/19/08	03/19/08	4 hours	0.001	2.23	Rainfall	Also Manholes 6 & 10 Inflow / Infiltration

Monthly Overflow Report

Date Range: March, 2008

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	03413012	03/05/08	03/05/08	1.5 hours	0.00001	0.00	Grit/Debris	1462 Gallatin Rd
000	04313084	03/09/08	03/09/08	1.5 hours	0.00002	0.00	Grease	328 Forest Park Rd
000	03410016	03/19/08	03/19/08	4.15 hours	0.001	1.84	Rainfall	345 Dinwiddie Dr. Inflow / Infiltration
106	Vandiver PS	03/04/08	03/04/08	5.83 hours	0.141	1.55	Rainfall	Inflow/Infiltration. Station at rated capacity.
106	Vandiver PS	03/19/08	03/19/08	14.33 hours	1.29	1.84	Rainfall	Inflow/Infiltration. Station at rated capacity.
110	Loves Branch PS	03/19/08	03/19/08	7.75 hours	0.254	1.84	Rainfall	Inflow/Infiltration. Station at rated capacity.
112	Gibson Creek PS	03/19/08	03/19/08	9 hours	1.632	1.84	Rainfall	Inflow/Infiltration. Station at rated capacity.
117	Neely's Bend PS	03/04/08	03/04/08	0.97 hours	0.05	1.56	Rainfall	Inflow/Infiltration. Station at rated capacity.
117	Neely's Bend PS	03/19/08	03/19/08	14.25 hours	0.76	1.84	Rainfall	Inflow/Infiltration. Station at rated capacity.
123	Lakewood PS	03/19/08	03/20/08	25.92 hours	0.22	1.96	Rainfall	Inflow/Infiltration. Station at rated capacity.
127	Madison Heights PS	03/06/08	03/06/08	2 hours	0.01	0.00	Power Out	NES power outage. Portable generator delivered to site.
127	Madison Heights PS	03/19/08	03/19/08	6.91 hours	0.02	1.84	Rainfall	Inflow/Infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	03/19/08	03/19/08	6.83 hours	0.11	1.84	Rainfall	Inflow/Infiltration. Station at rated capacity.
146	Pawnee Trail PS	03/19/08	03/19/08	0.5 hours	0.001	1.96	Rainfall	Inflow/Infiltration. Station at rated capacity.
150	Hidden Acres PS	03/19/08	03/19/08	6.5 hours	0.12	1.84	Rainfall	Inflow/Infiltration. Station at rated capacity.
303	N. Dupont Avenue	03/19/08	03/19/08	3 hours	0.001	1.84	Rainfall	Inflow / Infiltration

Monthly Overflow Report

Date Range: March, 2008

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07009019	03/06/08	03/06/08	1 hours	0.00001	0.00	Grit/Debris	3205 Lincoln Ave
000	05013010	03/19/08	03/19/08	11 hours	0.001	1.84	Rainfall	3000 Briley Pk Inflow / Infiltration
000	09105057	03/19/08	03/19/08	3.15 hours	0.001	2.60	Rainfall	6201 Laramie Ave. Inflow / Infiltration
000	10203046	03/19/08	03/19/08	1 hours	0.00001	0.00	Roots	Galaxie Dr & Annex Ave.
000	05915004	03/19/08	03/19/08	7 hours	0.001	2.23	Rainfall	3804 Crouch, Dr
000	06001009	03/19/08	03/19/08	12 hours	0.1	2.23	Rainfall	3258 Brick Church Pk Inflow / Infiltration
101	Bordeaux Hospital PS	03/19/08	03/19/08	9.72 hours	0.13	2.45	Rainfall	Inflow/Infiltration. Station at rated capacity.
104	Whites Creek PS	03/04/08	03/05/08	38.5 hours	6.931	1.84	Rainfall	Inflow/Infiltration. Station at rated capacity. Also (MH# 002).
104	Whites Creek PS	03/19/08	03/21/08	42.34 hours	5.833	2.45	Rainfall	Inflow/Infiltration. Station at rated capacity.
107	West Park PS	03/19/08	03/19/08	1 hours	0.259	2.60	Rainfall	Inflow/Infiltration. Station at rated capacity.
114	Davidson Branch PS	03/04/08	03/04/08	9.08 hours	1.977	1.84	Rainfall	Inflow/Infiltration. Station at rated capacity.
114	Davidson Branch PS	03/15/08	03/15/08	1.08 hours	0.028	1.18	Rainfall	Inflow/Infiltration. Station at rated capacity.
114	Davidson Branch PS	03/19/08	03/20/08	15.08 hours	3.016	2.60	Rainfall	Inflow/Infiltration. Station at rated capacity.
126	Cleeces Ferry PS	03/19/08	03/19/08	2.58 hours	0.19	2.60	Rainfall	Inflow/Infiltration. Station at rated capacity.
136	River Drive PS	03/04/08	03/04/08	4 hours	0.006	1.84	Rainfall	Inflow/Infiltration. Station at rated capacity.
136	River Drive PS	03/19/08	03/19/08	10 hours	0.183	2.45	Rainfall	Inflow/Infiltration. Station at rated capacity.
137	Harpeth Trace II PS	03/19/08	03/19/08	4.98 hours	0.02	1.92	Rainfall	Inflow/Infiltration. Station at rated capacity.
145	Joelton PS	03/04/08	03/05/08	2 hours	0.001	1.83	Rainfall	Inflow/Infiltration. Station at rated capacity.
170	Edinburgh PS	03/19/08	03/19/08	8.72 hours	0.001	1.92	Rainfall	Inflow/Infiltration. Station at rated capacity.
206	Brookwood Terrace	03/19/08	03/19/08	9.15 hours	0.001	2.60	Rainfall	Inflow / Infiltration
217	Basswood	03/04/08	03/04/08	10.5 hours	0.299	1.84	Rainfall	Inflow/Infiltration.
217	Basswood	03/19/08	03/20/08	17.59 hours	1.708	2.60	Rainfall	Inflow / Infiltration
337	Richland Creek (TDOT)	03/04/08	03/04/08	4.2 hours	0.1	1.84	Rainfall	Inflow / Infiltration
337	Richland Creek (TDOT)	03/19/08	03/20/08	13.5 hours	0.25	2.60	Rainfall	Also Manhole #14 Inflow / Infiltration
339	Richland Creek (23rd St.)	03/19/08	03/20/08	16.5 hours	0.25	2.60	Rainfall	Inflow / Infiltration
379	622 Davidson	03/19/08	03/19/08	3 hours	0.001	2.60	Rainfall	Inflow / Infiltration

Monthly Overflow Report

Date Range: March, 2008

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

111	Brentwood PS	03/04/08	03/05/08	34.91 hours	1.186	1.29	Rainfall	Inflow/Infiltration. Station at rated capacity (6,500 gpm).
111	Brentwood PS	03/07/08	03/09/08	38.25 hours	0.971	0.72	Rainfall	Inflow/Infiltration. Station at rated capacity (6,500 gpm).
111	Brentwood PS	03/15/08	03/16/08	9.91 hours	0.29	1.04	Rainfall	Inflow/Infiltration. Station at rated capacity (6,500 gpm).
111	Brentwood PS	03/19/08	03/21/08	50.42 hours	2.643	1.92	Rainfall	Inflow/Infiltration. Station at rated capacity (6,500 gpm).