

Monthly Overflow Report

Date Range: May, 2008

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	16108006	05/03/08	05/03/08	4 hours	0.00003	0.00	Grease	5319 Nolensville Rd.
000	08303030	05/04/08	05/04/08	0.45 hours	0.00001	0.00	Grit/Debris	1111 Porter Rd
000	07108000	05/07/08	05/07/08	9 hours	0.00012	0.00	Line Collapse	401 E. Trinity Ln, Line repaired.
000	14714028	05/09/08	05/09/08	0.5 hours	0.00002	0.00	Roots	521 Westcrest Dr.
000	10416066	05/11/08	05/11/08	1 hours	0.00002	0.00	Grit/Debris	1805 Blair Blvd.
000	09302136a	05/15/08	05/15/08	1.5 hours	0.00003	0.00	Grit/Debris	405 Gay St.
000	08302002	05/27/08	05/27/08	4 hours	0.00005	0.00	Grit/Debris	1539 Douglas Ave.
222	Barker Road	05/03/08	05/03/08	5.25 hours	0.088	1.34	Rainfall	
226	Cowan St. Relief Bleeder	05/03/08	05/03/08	3.5 hours	0.103	1.49	Rainfall	

Monthly Overflow Report

Date Range: May, 2008

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

132	Berwick Trail PS / Center St.	05/03/08	05/03/08	2 hours	0.01	1.44	Rainfall	Inflow/Infiltration. Station at rated capacity.
-----	-------------------------------	----------	----------	---------	------	------	----------	---

Monthly Overflow Report

Date Range: May, 2008

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14405016	05/15/08	05/16/08	10 hours	0.01	0.00	Excessive Flow	Chickering Ln, Manhole inter lid broken.
000	14405000	05/16/08	05/16/08	2 hours	0.00002	0.00	Excessive Flow	Chickering Ln, Leaking at creek.
000	14405016	05/16/08	05/16/08	4 hours	0.00005	0.00	Excessive Flow	Chickering, Ln Leaking under manhole ring.
000	14405000	05/17/08	05/17/08	0.5 hours	0.00001	0.00	Excessive Flow	Chickering Ln, Leaking at creek.
104	Whites Creek PS	05/03/08	05/03/08	2 hours	0.2	1.63	Rainfall	Inflow/Infiltration. Station at rated capacity.
104	Whites Creek PS	05/06/08	05/07/08	23.33 hours	1.193	0.14	Rainfall	Inflow/Infiltration. Station at rated capacity. #3 Pump OoS.
114	Davidson Branch PS	05/03/08	05/03/08	3.75 hours	0.297	1.53	Rainfall	Inflow/Infiltration. Station at rated capacity.
126	Cleeces Ferry PS	05/03/08	05/03/08	0.167 hours	0.001	1.53	Controller	Controller tripped pumps due to electrical surge.
145	Joelton PS	05/03/08	05/03/08	2 hours	0.01	1.63	Rainfall	Inflow/Infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: May, 2008

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

111	Brentwood PS	05/03/08	05/03/08	3.08 hours	0.037	1.11	Rainfall	Inflow/Infiltration. Station above design capacity @ 6,500 gpm.
-----	--------------	----------	----------	------------	-------	------	----------	---