

# Monthly Overflow Report

Date Range: July, 2008

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	16203000	07/06/08	07/06/08	1.5 hours	0.00002	0.00	Roots	113 Panamint Dr, Overflowed into basement.
000	09510037	07/10/08	07/10/08	5 hours	0.00011	0.00	Grit/Debris	Sanborn Dr, Line Cleaned
000	13505057	07/14/08	07/15/08	15 hours	0.01	0.00	Grit/Debris	308 Carillon Dr, Line Cleaned
000	10615000	07/14/08	07/14/08	1 hours	0.00002	0.00	Grit/Debris	925 Deervale Dr, Overflowed out of cleaned out.
000	08602060	07/24/08	07/24/08	1 hours	0.00001	0.00	Grit/Debris	417 Old Lebanon Dirt Rd, Line Cleaned.

# Monthly Overflow Report

Date Range: July, 2008

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	04309008	07/13/08	07/13/08	3 hours	0.00003	0.00	Grit/Debris	331 Gallatin Rd, Line Cleaned
000	03400039	07/17/08	07/29/08	Unknown	0.00001	0.00	Line Break	923 Swinging Bridge Rd.
106	Vandiver PS	07/12/08	07/12/08	1 hours	0.072	1.82	Power Out	NES Power out. Portable generator dispatched. Power restored.
146	Pawnee Trail PS	07/13/08	07/13/08	1 hours	0.005	1.82	Power Out	NES power out due to storm.
146	Pawnee Trail PS	07/25/08	07/25/08	2 hours	0.01	1.31	Power Out	NES Power out. Jack out on pole.

---

# Monthly Overflow Report

Date Range: July, 2008

---

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
101	Bordeaux Hospital PS	07/14/08	07/14/08	0.5 hours	0.0002		Power Out	Power Outage. Rain (.44") on 7/13/08.
104	Whites Creek PS	07/12/08	07/12/08	4 hours	0.235	1.24	Rainfall	Rainfall.