

# Monthly Overflow Report

Date Range: August, 2008

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	11709060	08/11/08	08/11/08	3 hours	0.00003	0.00	Grit/Debris	3717 Sugartree Pl. Line Cleaned.
000	08205000	08/11/08	08/11/08	3 hours	0.01	0.00	Other/not listed	Central WWTP Digester - Excess foaming lifted digester cover.
000	09609055	08/16/08	08/16/08	1 hours	0.00001	0.00	Grit/Debris	2827 Lakeland Dr. Line Cleaned
000	08302000	08/21/08	08/21/08	2.5 hours	0.00001	0.00	Grit/Debris	1317 Greenwood Ave. Overflow from cleanout. Line Cleaned.
000	16113003	08/23/08	08/23/08	1.5 hours	0.00002	0.00	Grit/Debris	5730 Brentwood Meadows Cir. Line Cleaned.
131	Hurricane Creek PS	08/05/08	08/05/08	0.083 hours	0.000005	0.00	Controller	Controller: Bad contact on #4 pump selector switch. <5 gals

---

# Monthly Overflow Report

Date Range: August, 2008

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

## Sanitary Sewer Overflows

132	Berwick Trail PS / Center St.	08/26/08	08/26/08	0.0833 hours	0.0005	1.80	Power Out	NES Power Failure. Portable generator dispatched.
-----	-------------------------------	----------	----------	--------------	--------	------	-----------	---

---

# Monthly Overflow Report

Date Range: August, 2008

---

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	02206005	08/04/08	08/04/08	5.5 hours	0.0009	0.00	Line Break	3500 Whites Creek Pk, Line Repaired