

Monthly Overflow Report

Date Range: October, 2008

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	13607014	10/08/08	10/08/08	2.5 hours	0.00002	0.00	Grit/Debris	Anderson Rd. Line Cleaned.
000	09206008	10/11/08	10/11/08	0.5 hours	0.00001	0.00	Grit/Debris	915 31st Ave No. Line Cleaned
000	17409000	10/14/08	10/14/08	3 hours	0.00004	0.00	Grit/Debris	5834 Pettus Rd. Line Cleaned (Private manhole)
000	11702013	10/19/08	10/19/08	3 hours	0.00002	0.00	Grit/Debris	2919 Compton Ave, Line Cleaned
140	28th Avenue PS / Centennial	10/16/08	10/17/08	21.25 hours	0.8	0.29	Line Break	3930 Centennial Blvd. Broken 42" FM repaired.
222	Barker Road	10/08/08	10/08/08	5.42 hours	0.146	2.52	Rainfall	
222	Barker Road	10/24/08	10/24/08	8.67 hours	0.723	1.80	Rainfall	
226	Cowan St. Relief Bleeder	10/08/08	10/08/08	6.75 hours	0.122	3.87	Rainfall	Rainfall. Cowan Street PS at rated capacity.

Monthly Overflow Report

Date Range: October, 2008

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04413019	10/18/08	10/18/08	4 hours	0.00006		Grease	Anita & Claudia Dr. Line Cleaned

Monthly Overflow Report

Date Range: October, 2008

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	12912050	10/09/08	10/09/08	2 hours	0.00001	0.00	Grit/Debris	6514 Highway 100. Line Cleaned
000	09004002	10/24/08	10/24/08	6 hours	0.01	2.42	Rainfall	Manhole in Rock Quarry
000	15901010	10/30/08	10/30/08	5 hours	0.00006	0.00	Grit/Debris	34 Park Meadows , Line Cleaned
104	Whites Creek PS	10/08/08	10/08/08	13.25 hours	2.283	3.81	Rainfall	Rainfall. Station at rated capacity.
104	Whites Creek PS	10/24/08	10/24/08	12.17 hours	1.735	2.10	Rainfall	Rainfall. Station at rated capacity.
114	Davidson Branch PS	10/24/08	10/24/08	3.17 hours	0.124	2.42	Rainfall	Rainfall. Station at rated capacity.
217	Basswood	10/08/08	10/08/08	9 hours	0.1	4.23	Rainfall	
217	Basswood	10/24/08	10/24/08	6.83 hours	0.329	2.42	Rainfall	
337	Richland Creek (TDOT)	10/08/08	10/08/08	10 hours	0.01	4.23	Rainfall	
337	Richland Creek (TDOT)	10/24/08	10/24/08	5 hours	0.01	2.06	Rainfall	

Monthly Overflow Report

Date Range: October, 2008

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

111	Brentwood PS	10/08/08	10/08/08	5.33 hours	0.079	3.02	Rainfall	Rainfall. Station at rated capacity.
111	Brentwood PS	10/24/08	10/25/08	12 hours	0.395	2.05	Rainfall	Rainfall. Station at rated capacity.