

# Monthly Overflow Report

Date Range: December, 2008

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	16111021	12/01/08	12/01/08	2.5 hours	0.00003	0.00	Grit/Debris	1000 Enclave Cir & Old Hickory Blvd. Line Cleaned
000	16102017	12/02/08	12/02/08	5 hours	0.00007	0.00	Grit/Debris	496 West Crest Dr. Line Cleaned
000	16111021	12/03/08	12/03/08	2 hours	0.00004	0.00	Roots	15301 Old Hickory Blvd
000	16009018	12/06/08	12/06/08	3 hours	0.00004	0.00	Roots	852 Lakemont Dr. Line Cleaned
000	14701054	12/09/08	12/10/08	26.15 hours	0.1	3.00	Rainfall	342 Lynn Dr.
000	10616033	12/10/08	12/11/08	9.5 hours	0.1	3.74	Rainfall	408 Hollydale Dr.
000	09510050	12/10/08	12/13/08	59 hours	0.2	4.00	Rainfall	510 Bismark Dr.
000	11903088	12/10/08	12/11/08	7.5 hours	0.1	3.74	Rainfall	349 Wimpole Dr.
000	10412043	12/11/08	12/11/08	2 hours	0.00003	0.42	Rainfall	2104 20th Ave So.
000	16206092	12/13/08	12/13/08	2 hours	0.00002	0.00	Grit/Debris	173 Tusculum Rd. Line Cleaned.
000	16106051	12/25/08	12/25/08	2 hours	0.00003	0.00	Grit/Debris	5242 Edmondson Pk & McMurray Dr. Line Cleaned
000	WLS51N001	12/25/08	12/25/08	2.5 hours	0.00006	0.00	Grit/Debris	Mockingbird Ln & Woodside Dr. MH in Wilson Co. Line Cleaned.
000	07605043	12/25/08	12/25/08	1 hours	0.00002	0.00	Grit/Debris	4819 Shadowlawn Dr & Hidden Hill Dr. Line Cleaned.
000	WMN34M001	12/26/08	12/27/08	26 hours	0.02	0.00	Grit/Debris	1551 Shining Ore Dr & Sapphire Ct. Line Cleaned.
000	13603019	12/27/08	12/27/08	2 hours	0.00003	0.00	Grit/Debris	108 Coastal Ct & PriestLake Dr. Line Cleaned.
000	16509000	12/29/08	12/29/08	1 hours	0.00002	0.00	Grit/Debris	1900 Port James Cir. Overflowed from clean out. Line Cleaned
102	Smith Springs PS	12/09/08	12/11/08	22.84 hours	1.829	3.93	Rainfall	Inflow/infiltration. Station at rated capacity.
124	Williamson Ferry PS	12/10/08	12/10/08	4.08 hours	0.179	3.14	Rainfall	Inflow/infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	12/09/08	12/12/08	28 hours	17.003	3.74	Rainfall	Inflow/infiltration. Station at rated capacity.
140	28th Avenue PS / Centennial	12/10/08	12/10/08	1.58 hours	0.032	3.13	Rainfall	Inflow/infiltration. Station at rated capacity.
159	Summerfield SPS	12/10/08	12/10/08	6.5 hours	0.01	3.93	Rainfall	I/I from new construction. Station at rated capacity.
176	Dodson Chapel PS	12/10/08	12/11/08	3.16 hours	0.087	3.60	Rainfall	Inflow/infiltration. Station at rated capacity.
187	Peppertree PS	12/09/08	12/10/08	12 hours	0.015	3.63	Rainfall	Inflow/infiltration. Station at rated capacity.
189	Langford Farms PS	12/09/08	12/10/08	8.5 hours	0.01	3.72	Rainfall	Inflow/infiltration. Station at rated capacity.
190	Towne Village PS	12/10/08	12/10/08	8 hours	0.01	3.93	Rainfall	Inflow/infiltration. Station at rated capacity.
222	Barker Road	12/09/08	12/12/08	46.75 hours	9.234	3.75	Rainfall	Inflow/infiltration

---

# Monthly Overflow Report

Date Range: December, 2008

222	Barker Road	12/24/08	12/24/08	7.67 hours	0.415	1.13	Rainfall	
226	Cowan St. Relief Bleeder	12/09/08	12/10/08	24 hours	2.251	3.14	Rainfall	Inflow/infiltration. Station at rated capacity.
226	Cowan St. Relief Bleeder	12/24/08	12/24/08	2.67 hours	0.026	1.24	Grit/Debris	Inflow/infiltration. Large rocks in trunk line. WLH to remove.
309	Omohundro Dr.-under RR br	12/09/08	12/10/09	12.5 hours	0.1	3.10	Rainfall	
311	Omohundro Dr.-E of RR brg	12/09/08	12/10/08	12 hours	0.1	3.10	Rainfall	
371	Apex St.	12/09/08	12/10/08	14 hours	0.1	3.14	Rainfall	

# Monthly Overflow Report

Date Range: December, 2008

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	03406024	12/24/08	12/24/08	1 hours	0.00002	0.00	Grit/Debris	671 Myatt Dr & Spring Branch Rd. Line Cleaned.
000	03316034	12/25/08	12/25/08	2 hours	0.00004	0.00	Grit/Debris	1105 Nelson Dr & Apple Valley Rd. Line Cleaned.
106	Vandiver PS	12/09/08	12/10/08	13.42 hours	0.81	2.88	Rainfall	Inflow/infiltration. Station at rated capacity.
110	Loves Branch PS	12/09/08	12/10/08	7 hours	0.339	2.87	Rainfall	Inflow/infiltration. Station at rated capacity.
112	Gibson Creek PS	12/09/08	12/10/08	16.41 hours	4.158	2.87	Rainfall	Inflow/infiltration. Station at rated capacity.
117	Neely's Bend PS	12/10/08	12/10/08	5.5 hours	0.05	3.15	Rainfall	Inflow/infiltration. Station at rated capacity.
127	Madison Heights PS	12/09/08	12/10/08	10 hours	0.015	3.15	Rainfall	Inflow/infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	12/09/08	12/10/08	12 hours	0.02	3.15	Rainfall	Inflow/infiltration. Station at rated capacity.

# Monthly Overflow Report

Date Range: December, 2008

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	06001013	12/09/08	12/10/08	17.5 hours	0.1	3.13	Rainfall	Brick Church Pk.
000	06001011	12/09/08	12/10/08	17 hours	0.1	3.13	Rainfall	Brick Church Pk.
000	06004000	12/10/08	12/10/08	2 hours	0.00005	3.13	Grease	120 Oak Valley Dr & Oak Ridge Dr. Line Cleaned.
000	10203046	12/24/08	12/24/08	3 hours	0.00005	1.33	Grit/Debris	635 Galaxie Dr & Annex Ave. Line Cleaned.
000	05904076	12/26/08	12/26/08	3 hours	0.00002	0.00	Grease	2895 Creekbend Dr & Bridge Point. Line Cleaned
104	Whites Creek PS	12/09/08	12/11/08	53.75 hours	8.089	3.45	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	12/24/08	12/25/08	20.17 hours	1.922	1.20	Rainfall	Inflow/infiltration. Station at rated capacity.
107	West Park PS	12/09/08	12/10/08	19.25 hours	8.011	3.67	Rainfall	Inflow/infiltration. Station at rated capacity.
107	West Park PS	12/24/08	12/24/08	0.75 hours	0.03	1.33	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	12/09/08	12/10/08	3.59 hours	0.624	3.67	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	12/24/08	12/24/08	1.83 hours	0.064	1.33	Rainfall	Inflow/infiltration. Station at rated capacity.
126	Cleeces Ferry PS	12/09/08	12/10/08	10 hours	0.03	4.00	Rainfall	Inflow/infiltration. Station at rated capacity.
136	River Drive PS	12/09/08	12/10/08	13.67 hours	0.288	3.13	Rainfall	Inflow/infiltration. Station at rated capacity.
136	River Drive PS	12/24/08	12/25/08	16.42 hours	0.344	1.20	Rainfall	Inflow/infiltration. Station at rated capacity. Bubbler line.
145	Joelton PS	12/09/08	12/10/08	10.25 hours	0.015	3.18	Rainfall	I/I from new construction. Station at rated capacity.
145	Joelton PS	12/24/08	12/24/08	14.217 hours	0.017	1.30	Rainfall	I/I from new construction. Station at rated capacity.
145	Joelton PS	12/28/08	12/28/08	3.12 hours	0.003	0.36	Rainfall	I/I from new construction. Station at rated capacity.
217	Basswood	12/09/08	12/10/08	25 hours	4.441	3.67	Rainfall	
217	Basswood	12/24/08	12/24/08	4.83 hours	0.248	1.33	Rainfall	
337	Richland Creek (TDOT)	12/09/08	12/11/08	36 hours	0.1	3.67	Rainfall	
379	622 Davidson	12/11/08	12/11/08	5 hours	0.1	4.00	Rainfall	

---

# Monthly Overflow Report

Date Range: December, 2008

---

## Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

## Sanitary Sewer Overflows

111	Brentwood PS	12/09/08	12/12/08	62.42 hours	3.28	4.02	Rainfall	Inflow/infiltration. Station at rated capacity.
111	Brentwood PS	12/24/08	12/25/08	7.92 hours	0.241	1.15	Rainfall	Inflow/infiltration. Station at rated capacity.