

Feb 2009

**CENTRAL WASTEWATER TREATMENT PLANT  
CSO - 018 - 1st & VAN BUREN**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1					1	
2					1	
3						
4						
5						
6						
7						
8						
9						
10						
11					1	
12						
13						
14						
15						
16						
17					1	
18					1	
19						
20						
21					1	
22						
23						
24						
25						
26						
27	0.087	1	0.69	2.00		Rain, Overflow Duration = 0.17 hours
28					1	

TOTAL	0.087	1	0.69	2.00	7	
AVG	0.087	1	0.69	2.00	1	
MAX	0.087	1	0.69	2.00	1	
MIN	0.087	1	0.69	2.00	1	
COUNT	1	1	1	1	7	

NAME NASHVILLE-CENTRAL STP  
 ADDRESS 1600 2ND AVENUE NORTH  
 NASHVILLE TN 372082206

TN0020575	018 G
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206

MAJOR \$  
 (SUBR 04)  
 VAN BUREN AT MI 189.5 CSO  
 External Outfall

FACILITY NASHVILLE-CENTRAL STP  
 LOCATION 1600 2ND AVENUE NORTH  
 NASHVILLE TN 372082206

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
FROM 02/01/2009	TO 02/28/2009

NO DISCHARGE [ ]

ATTN: MR. SCOTT POTTER

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	2.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	0.69	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	0.087	0.087		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	7.00			*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL		occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	1.00	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
SCOTT A. POTTER DIRECTOR			615 862-4591	03/10/2009
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)				

Feb 2009

CENTRAL WASTEWATER TREATMENT PLANT  
CSO - 019 - KERRIGAN

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1					1	
2					1	
3						
4						
5						
6						
7						
8						
9						
10						
11	0.598	1	0.26	1.00		Rain, Overflow Duration = 0.50 hours
12						
13						
14						
15						
16						
17			0.14	3.00		
18	6.546	1	0.63	6.00		Rain, Overflow Duration = 1.75 hours
19						
20						
21					1	
22						
23						
24						
25						
26						
27	7.003	1	0.60	3.00		Rain, Overflow Duration = 1.58 hours
28					1	
<b>TOTAL</b>	14.147	3	1.63	13.00	4	
<b>AVG</b>	4.716	1	0.41	3.25	1	
<b>MAX</b>	7.003	1	0.63	6.00	1	
<b>MIN</b>	0.598	1	0.14	1.00	1	
<b>COUNT</b>	3	3	4	4	4	

DISCHARGE MONITORING REPORT (DMR)

NAME NASHVILLE-CENTRAL STP  
 ADDRESS 1600 2ND AVENUE NORTH  
 NASHVILLE TN 372082206

TN0020575	019 G
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206  
 MAJOR \$  
 (SUBR 04) EJM  
 KERRIGAN AT MI 190.4 CSO  
 External Outfall

FACILITY NASHVILLE-CENTRAL STP  
 LOCATION 1600 2ND AVENUE NORTH  
 NASHVILLE TN 372082206

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
FROM 02/01/2009	TO 02/28/2009

NO DISCHARGE [ ]

ATTN: MR. SCOTT POTTER

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	13.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	1.63	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	4.716	7.003		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	4.00	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	3.00	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  SCOTT A. POTTER  DIRECTOR	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
		615 862-4591	03/10/2009
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER	MM/DD/YYYY
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			

Feb 2009

**CENTRAL WASTEWATER TREATMENT PLANT  
CSO - 020 - 1st & BROADWAY**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1					1	
2					1	
3						
4						
5						
6						
7						
8						
9						
10						
11	0.003	1	0.26	1.00		Intense Rainfall, Overflow Duration = 0.08 hours
12						
13						
14						
15						
16						
17					1	
18					1	
19						
20						
21					1	
22						
23						
24						
25						
26						
27	0.032	1	0.60	3.00		Intense Rainfall, Overflow Duration = 0.33 hours
28					1	

TOTAL	0.035	2	0.86	4.00	6
AVG	0.018	1	0.43	2.00	1
MAX	0.032	1	0.60	3.00	1
MIN	0.003	1	0.26	1.00	1
COUNT	2	2	2	2	6

NAME NASHVILLE-CENTRAL STP  
 ADDRESS 1600 2ND AVENUE NORTH  
 NASHVILLE TN 372082206

TN0020575  
 PERMIT NUMBER

020 G  
 DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206

MAJOR \$  
 (SUBR 04)  
 1ST & BROADWAY MI 191.0 CSO  
 External Outfall

FACILITY NASHVILLE-CENTRAL STP  
 LOCATION 1600 2ND AVENUE NORTH  
 NASHVILLE TN 372082206

MONITORING PERIOD  
 FROM 02/01/2009 TO 02/28/2009

NO DISCHARGE [ ]

ATTN: MR. SCOTT POTTER

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	4.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	0.86	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	0.018	0.032		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	6.00	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	2.00	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  SCOTT A. POTTER  DIRECTOR	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
		615 862-4591	03/10/2009
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER MM/DD/YYYY
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			

Feb 2009

**CENTRAL WASTEWATER TREATMENT PLANT  
CSO - 023 - BENEDICT & CRUTCHER**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1					1	
2					1	
3						
4						
5						
6						
7						
8						
9						
10						
11	0.027	1	0.27	1.00		Rain, Overflow Duration = 0.58 hours
12						
13						
14						
15						
16						
17			0.02	2.00		
18	0.574	1	0.49	4.00		Rain, Overflow Duration = 2.25 hours
19						
20						
21					1	
22						
23						
24						
25						
26						
27	0.301	1	0.69	2.00		Rain, Overflow Duration = 1.25 hours
28	0.002	1	0.47	10.00		Rain, Overflow Duration = 1.42 hours
<b>TOTAL</b>	0.904	4	1.94	19.00	3	
<b>AVG</b>	0.226	1	0.39	3.80	1	
<b>MAX</b>	0.574	1	0.69	10.00	1	
<b>MIN</b>	0.002	1	0.02	1.00	1	
<b>COUNT</b>	4	4	5	5	3	

**DISCHARGE MONITORING REPORT (DMR)**

NAME NASHVILLE-CENTRAL STP  
 ADDRESS 1600 2ND AVENUE NORTH  
 NASHVILLE TN 372082206

TN0020575  
 PERMIT NUMBER

023 G  
 DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206

MAJOR \$  
 (SUBR 04)  
 BENEDICT & CRUTCHER 191.6 CSO  
 External Outfall

FACILITY NASHVILLE-CENTRAL STP  
 LOCATION 1600 2ND AVENUE NORTH  
 NASHVILLE TN 372082206

**MONITORING PERIOD**

FROM 02/01/2009 TO 02/28/2009

**NO DISCHARGE [ ]**

ATTN: MR. SCOTT POTTER

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration 00135 1 0 Effluent Gross	SAMPLE MEASUREMENT	19.00	*****		*****	*****	*****	****			
	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall 46529 1 0 Effluent Gross	SAMPLE MEASUREMENT	1.94	*****		*****	*****	*****	****			
	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.226	0.574		*****	*****	*****	****			
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge 51407 1 0 Effluent Gross	SAMPLE MEASUREMENT	3.00	*****		*****	*****	*****	****			
	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation 84165 1 0 Effluent Gross	SAMPLE MEASUREMENT	4.00	*****		*****	*****	*****	****			
	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  SCOTT A. POTTER DIRECTOR	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
		615 862-4591	03/10/2009
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			MM/DD/YYYY



Feb 2009

**CENTRAL WASTEWATER TREATMENT PLANT  
CSO - 024 - WASHINGTON DC**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1					1	
2					1	
3						
4						
5						
6						
7						
8						
9						
10					1	
11	1.776	1	0.34	1.00		Rain, Overflow Duration = 12.33 hours
12	0.313					Rain, Overflow Duration = 12.83 hours
13						
14						
15						
16						
17			0.06	3.00		
18	3.868	1	0.53	5.00		Rain, Overflow Duration = 10.83 hours
19						
20						
21	0.001	1	0.22	5.00		Rain, Overflow Duration = 0.42 hours
22						
23						
24						
25						
26						
27	3.185	1	0.63	3.00		Rain, Overflow Duration = 8.83 hours
28	1.234		0.57	10.00		Rain, Overflow Duration = 6.92 hours
TOTAL	10.377	4	2.35	27.00	3	
AVG	1.730	1	0.39	4.50	1	
MAX	3.868	1	0.63	10.00	1	
MIN	0.001	1	0.06	1.00	1	
COUNT	6	4	6	6	3	

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Form Approved

OMB NO. 2040-0004

DISCHARGE MONITORING REPORT (DMR)

NAME NASHVILLE-CENTRAL STP  
 ADDRESS 1600 2ND AVENUE NORTH  
 NASHVILLE TN 372082206

TN0020575  
 PERMIT NUMBER

024G  
 DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206

MAJOR \$  
 (SUBR 04) EMH  
 WASHINGTON MI 190.4 CSO  
 External Outfall

FACILITY NASHVILLE-CENTRAL STP  
 LOCATION 1600 2ND AVENUE NORTH  
 NASHVILLE TN 372082206

MONITORING PERIOD  
 FROM 02/01/2009 TO 02/28/2009

NO DISCHARGE [ ]

ATTN: MR. SCOTT POTTER

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	27.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	2.35	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	1.730	3.868		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	3	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	4	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  SCOTT A. POTTER  DIRECTOR	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
		615 862-4591	03/10/2009
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER MM/DD/YYYY
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			

Feb 2009

**CENTRAL WASTEWATER TREATMENT PLANT  
CSO - 033 - SCHRADER LANE**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1					1	
2					1	
3						
4						
5						
6						
7						
8						
9						
10						
11	0.276	1	0.28	2.00		Rain, Overflow Duration = 0.58 hours
12						
13						
14						
15						
16						
17			0.03	2.00		
18	0.309	1	0.53	6.00		Rain, Overflow Duration = 1.92 hours
19						
20						
21					1	
22					1	
23						
24						
25						
26						
27	0.740	1	0.74	3.00		Rain, Overflow Duration = 1.50 hours
28	0.490	1	0.49	11.00		Rain, Overflow Duration = 0.58 hours

TOTAL	1.815	4	2.07	24.00	4
AVG	0.454	1	0.41	4.80	1
MAX	0.740	1	0.74	11.00	1
MIN	0.276	1	0.03	2.00	1
COUNT	4	4	5	5	4

NAME NASHVILLE-CENTRAL STP  
ADDRESS 1600 2ND AVENUE NORTH  
NASHVILLE TN 372082206

TN0020575	033 G
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206  
MAJOR \$  
(SUBR 04) EMH  
SCHRADER LN MI 184.7 CSO  
External Outfall

FACILITY NASHVILLE-CENTRAL STP  
LOCATION 1600 2ND AVENUE NORTH  
NASHVILLE TN 372082206

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
FROM 02/01/2009	TO 02/28/2009

NO DISCHARGE [ ]

ATTN: MR. SCOTT POTTER

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	24.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	2.07	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	0.454	0.740		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	4	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	4	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  SCOTT A. POTTER  DIRECTOR	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
		615 862-4591	03/10/2009
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER	MM/DD/YYYY
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			

Feb 2009

**CENTRAL WASTEWATER TREATMENT PLANT  
CSO - 035 - DRIFTWOOD**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1					1	
2					1	
3						
4						
5						
6						
7						
8						
9						
10						
11					1	
12						
13						
14						
15						<b>NO DISCHARGE FOR THIS SITE FOR THIS MONTH</b>
16						
17					1	
18					1	
19						
20						
21					1	
22						
23						
24						
25						
26						
27					1	
28					1	

TOTAL	0.000	0	0.00	0.00	8	
AVG	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	1	
MAX	0.000	0	0.00	0.00	1	
MIN	0.000	0	0.00	0.00	1	
COUNT	0	0	0	0	8	

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Form Approved  
OMB NO. 2040-0004

DISCHARGE MONITORING REPORT (DMR)

NAME NASHVILLE-CENTRAL STP  
ADDRESS 1600 2ND AVENUE NORTH  
NASHVILLE TN 372082206

TN0020575  
PERMIT NUMBER

035 G  
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206

MAJOR \$  
(SUBR 04)  
DRIFTWOOD MI 192.0 CSO  
External Outfall

FACILITY NASHVILLE-CENTRAL STP  
LOCATION 1600 2ND AVENUE NORTH  
NASHVILLE TN 372082206

MONITORING PERIOD  
MM/DD/YYYY MM/DD/YYYY  
FROM 02/01/2009 TO 02/28/2009

NO DISCHARGE [ x ]

ATTN: MR. SCOTT POTTER

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	0.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	0.00	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	#DIV/0!	0.000		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	8	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	0	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  SCOTT A. POTTER DIRECTOR	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
		615 862-4591	03/10/2009
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER MM/DD/YYYY
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			

Feb 2009

**CENTRAL WASTEWATER TREATMENT PLANT  
CSO - 047 - BOSCOBEL**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1					1	
2					1	
3						
4						
5						
6						
7						
8						
9						
10					1	
11					1	
12						
13						
14						
15						
16						
17			0.06	3.00		
18	0.011	1	0.53	5.00		Rain, Overflow Duration = 0.25 hours
19						
20						
21						
22						
23						
24						
25						
26						
27	0.211	1	0.63	3.00		Rain, Overflow Duration = 0.25 hours
28					1	

TOTAL	0.222	2	1.22	11.00	5	
AVG	0.111	1	0.41	3.67	1	
MAX	0.211	1	0.63	5.00	1	
MIN	0.011	1	0.06	3.00	1	
COUNT	2	2	3	3	5	

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Form Approved  
OMB NO. 2040-0004

DISCHARGE MONITORING REPORT (DMR)

NAME NASHVILLE-CENTRAL STP  
ADDRESS 1600 2ND AVENUE NORTH  
NASHVILLE TN 372082206

TN0020575  
PERMIT NUMBER

047 G  
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206

MAJOR \$  
(SUBR 04)  
BOSCOBEL MI 192.6 CSO  
External Outfall

FACILITY NASHVILLE-CENTRAL STP  
LOCATION 1600 2ND AVENUE NORTH  
NASHVILLE TN 372082206

MONITORING PERIOD  
MM/DD/YYYY  
FROM 02/01/2009 TO 02/28/2009

NO DISCHARGE [ ]

ATTN: MR. SCOTT POTTER

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	11.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	1.22	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	0.111	0.211		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	5	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	2	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
SCOTT A. POTTER DIRECTOR		615 862-4591	03/10/2009
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			