

Monthly Overflow Report

Date Range: January, 2009

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14701029	01/02/09	01/02/09	2 hours	0.00006	0.00	Grit/Debris	350 Binkley Dr. Line Cleaned
000	16206092	01/02/09	01/02/09	4 hours	0.00003	0.00	Grit/Debris	173 Tusculum Rd. Line Cleaned
000	17203125	01/05/09	01/05/09	3 hours	0.00007	0.00	Grit/Debris	5921 Woodland Ave. Line Cleaned
000	09510050	01/06/09	01/07/09	12 hours	0.1	1.50	Rainfall	510 Bismark Dr
000	13209013	01/07/09	01/07/09	2.5 hours	0.00011	0.00	Roots	220 Brattlesboro Pl. Line Cleaned
000	10705000	01/23/09	01/23/09	2 hours	0.00005	0.00	Grease	1905 Pamela Dr Line Cleaned (Overflowed from Clean Out.)
000	13308047	01/24/09	01/24/09	2.5 hours	0.00003	0.00	Grease	94 Antioch Pk. Line Cleaned
000	13515015	01/26/09	01/26/09	1.5 hours	0.00009	0.00	Grit/Debris	500 Brooksboro Ter. Line Cleaned
000	14703095	01/28/09	01/29/09	24 hours	0.1	2.07	Rainfall	4112 Nolensville Rd. Line Cleaned
000	09510050	01/28/09	01/29/08	23 hours	0.1	2.69	Rainfall	510 Bismark Dr
000	10616033	01/28/09	01/28/09	12 hours	0.1	2.07	Rainfall	Holleydale Dr.
124	Williamson Ferry PS	01/28/09	01/28/09	6.5 hours	0.367	2.64	Rainfall	Inflow/Infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	01/28/09	01/28/09	0.58 hours	0.016	2.65	Rainfall	Inflow/Infiltration. Siphon appears to have partial blockage.
133	Holiday Travel Park PS	01/28/09	01/28/09	10.167 hours		2.69	Rainfall	Inflow/Infiltration. Station at rated capacity.
134	Riverside Drive PS	01/15/09	01/15/09	0.25 hours	0.00001		Controllor	Controllor. Fuse blown to bubbler line compressor.
134	Riverside Drive PS	01/28/09	01/28/09	7 hours	0.005	3.04	Rainfall	Inflow/Infiltration. Station at rated capacity.
151	Shelby Park PS	01/28/09	01/28/09	6.67 hours	0.418	2.64	Rainfall	Inflow/Infiltration. Station at rated capacity.
176	Dodson Chapel PS	01/28/09	01/29/09	16.66 hours	0.286	2.69	Rainfall	Inflow/Infiltration. Station at rated capacity.
189	Langford Farms PS	01/06/09	01/07/09	16 hours	0.05	2.64	Rainfall	Inflow/Infiltration. Station at rated capacity.
189	Langford Farms PS	01/28/09	01/29/09	29.5 hours	0.01	3.09	Rainfall	Inflow/Infiltration. Station at rated capacity.
198	Lakeview P.S.	01/28/09	01/28/09	1.25 hours	0.0005	2.13	Rainfall	Inflow/Infiltration. Station at rated capacity.
222	Barker Road	01/06/09	01/07/09	21.25 hours	1.337	1.50	Rainfall	Equalization Under construction.
222	Barker Road	01/27/09	01/27/09	38.08 hours	5.727	2.69	Rainfall	Equalization Under construction.
226	Cowan St. Relief Bleeder	01/06/09	01/07/09	8.25 hours	0.237	1.54	Rainfall	I/I. Tributary lines cleaned by WLH.
226	Cowan St. Relief Bleeder	01/27/09	01/28/09	24.84 hours	2.125	2.64	Rainfall	I/I. Tributary lines cleaned by WLH.
328	Cooper Lane	01/28/09	01/28/09	12.15 hours	0.1	2.64	Rainfall	

Monthly Overflow Report

Date Range: January, 2009

371	Apex St.	01/28/09	01/28/09	8.5 hours	0.1	2.64	Rainfall
-----	----------	----------	----------	-----------	-----	------	----------

Monthly Overflow Report

Date Range: January, 2009

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	03316074	01/27/09	01/27/09	2 hours	0.00011	0.00	Grit/Debris	924 Sun Valley Dr. Line Cleaned
106	Vandiver PS	01/28/09	01/28/09	11.58 hours	0.958	2.97	Rainfall	Inflow/Infiltration. Station at rated capacity.
109	Dry Creek PS	01/28/09	01/28/09	7 hours	2.775	3.85	Rainfall	Inflow/Infiltration. Station at rated capacity.
110	Loves Branch PS	01/28/09	01/28/09	6.92 hours	0.438	3.85	Rainfall	Inflow/Infiltration. Station at rated capacity.
112	Gibson Creek PS	01/28/09	01/28/09	9.83 hours	2.298	3.85	Rainfall	Inflow/Infiltration. Station at rated capacity.
117	Neely's Bend PS	01/06/09	01/06/09	2.5 hours	0.02	1.46	Rainfall	Inflow/Infiltration. Station at rated capacity.
117	Neely's Bend PS	01/28/09	01/28/09	11 hours	0.2	3.87	Rainfall	Inflow/Infiltration. Station at rated capacity.
127	Madison Heights PS	01/28/09	01/28/09	8 hours	0.001	3.87	Rainfall	Inflow/Infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	01/28/09	01/28/09	10.833 hours	0.01	3.87	Rainfall	Inflow/Infiltration. Station at rated capacity.
150	Hidden Acres PS	01/28/09	01/28/09	7 hours	0.001	3.87	Rainfall	Inflow/Infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: January, 2009

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07008054	01/05/09	01/05/09	2 hours	0.001	0.00	Air Relief Valve	Faulty air relief valve. Valved off ARV and replaced.
000	13011005	01/07/09	01/07/09	11 hours	0.0004	1.34	Rainfall	805 Lynnwood Blvd
000	05911063	01/15/09	01/15/09	5 hours	0.1	0.00	Grit/Debris	2715 Whites Creek Pk. Line Cleaned
000	05003011	01/22/09	01/22/09	3 hours	0.00006	0.00	Grease	1474 Bellshire Ter Dr. Line Cleaned
000	05911027	01/28/09	01/28/09	9 hours	0.1	3.03	Rainfall	707 Rowan Dr.
000	06001011	01/28/09	01/28/09	5 hours	0.1	3.03	Rainfall	Brick Church Pk
000	14405017	01/28/09	01/28/09	2 hours	0.0002	2.75	Rainfall	1318 Chickering Rd
000	09012057	01/28/09	01/28/09	3 hours	0.0005	2.75	Rainfall	6030 Henry Ford Dr
104	Whites Creek PS	01/06/09	01/07/09	20.66 hours	3.115	1.42	Rainfall	Inflow/Infiltration. Station at rated capacity.
104	Whites Creek PS	01/27/09	01/29/09	11 hours	1.472	3.03	Rainfall	Inflow/Infiltration. Station at rated capacity.
107	West Park PS	01/27/09	01/28/09	16.42 hours	4.122	3.03	Rainfall	I/I. Station at rated capacity. EQ under construction.
114	Davidson Branch PS	01/06/09	01/06/09	1.08 hours	0.053	1.55	Rainfall	Inflow/Infiltration. Station at rated capacity.
114	Davidson Branch PS	01/28/09	01/28/09	5.08 hours	0.151	3.33	Rainfall	Inflow/Infiltration. Station at rated capacity.
126	Cleeces Ferry PS	01/28/09	01/28/09	3 hours	0.01	3.33	Rainfall	Inflow/Infiltration. Station at rated capacity.
136	River Drive PS	01/28/09	01/28/09	3.58 hours	0.026	3.03	Rainfall	Inflow/Infiltration. Station at rated capacity.
145	Joelton PS	01/06/09	01/07/09	14.75 hours	0.05	1.45	Rainfall	I/I from adjacent development. Station at rated capacity.
145	Joelton PS	01/27/09	01/28/09	45.75 hours	0.1	3.28	Rainfall	I/I from adjacent development. Station at rated capacity.
217	Basswood	01/06/09	01/07/09	5.42 hours	0.206	1.55	Rainfall	Equalization Under construction.
217	Basswood	01/28/09	01/28/09	22 hours	1.133	3.33		Equalization Under construction.
337	Richland Creek (TDOT)	01/28/09	01/28/09	15 hours	0.1	3.33	Rainfall	Equalization Under construction.
379	622 Davidson	01/28/09	01/28/09	12 hours	0.1	3.33	Rainfall	

Monthly Overflow Report

Date Range: January, 2009

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

111	Brentwood PS	01/06/09	01/07/09	26.59 hours	0.751	1.35	Rainfall	Inflow/Infiltration. Station operating above rated capacity.
111	Brentwood PS	01/28/09	01/29/09	22.84 hours	1.078	2.13	Rainfall	Inflow/Infiltration. Station operating above rated capacity.