

# Monthly Overflow Report

Date Range: February, 2009

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	13514136	02/09/09	02/09/09	3.5 hours	0.00002	0.00	Blockage	505 Titan Ct, Line Cleaned
000	07210054	02/13/09	02/13/09	3 hours	0.00016	0.00	Grease	2624 Gallatin Rd. Line Cleaned
000	07207113	02/27/09	02/27/09	3 hours	0.00021	0.00	Grease	1410 Kirkland Ave. Line Cleaned
000	09510050	02/28/09	02/28/09	11 hours	0.1	1.68	Rainfall	510 Bismark Dr
133	Holiday Travel Park PS	02/09/09	02/10/09	10.5 hours	0.018	0.00	Controller	Bubbler line clogged, pumps clogged. Some sewage recovered.
187	Peppertree PS	02/27/09	02/27/09	3.4 hours	0.01	2.51	Rainfall	Inflow/Infiltration. Station at rated capacity.
222	Barker Road	02/27/09	03/01/09	27.74 hours	0.717	1.33	Rainfall	

---

# Monthly Overflow Report

Date Range: February, 2009

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	03314048	02/11/09	02/11/09	3 hours	0.00015	0.00	Grease	811 Nella Dr. Line Cleaned

# Monthly Overflow Report

Date Range: February, 2009

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	15712024	02/27/09	02/28/09	40 hours	0.00025	2.22	Rainfall	
104	Whites Creek PS	02/28/09	02/28/09	1.33 hours	0.054	1.23	Rainfall	Inflow/Infiltration. Station at rated capacity.
138	Sunliner PS	02/18/09	02/18/09	0.083 hours	0.0001	1.35	Power Out	NES Power Out. Will install stationary generator.
145	Joelton PS	02/18/09	02/18/09	2 hours	0.002	0.68	Rainfall	Inflow/Infiltration. Station at rated capacity.
145	Joelton PS	02/27/09	02/27/09	2.5 hours	0.005	1.16	Rainfall	Inflow/Infiltration. Station at rated capacity.

---

# Monthly Overflow Report

Date Range: February, 2009

---

## Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

## Sanitary Sewer Overflows

111	Brentwood PS	02/27/09	03/02/09	64.5 hours	3.469	2.22	Rainfall	Inflow/Infiltration. Station at rated capacity.
-----	--------------	----------	----------	------------	-------	------	----------	---