

Monthly Overflow Report

Date Range: April, 2009

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	16307039	04/02/09	04/02/09	1.5 hours	0.00005	1.12	Rags	500 Hickory Hollow Ter. Line Cleaned
000	11702085	04/02/09	04/02/09	1 hours	0.00008	2.36	Grit/Debris	2904 23 Ave So. Line Cleaned
000	09211000	04/02/09	04/02/09	7 hours	0.00065	2.14	Rainfall	323 21st Ave No. Overflowed into basement
000	10412137	04/02/09	04/02/09	2 hours	0.00005	2.14	Grit/Debris	1933 18th Ave So. Line Cleaned
000	08103012	04/02/09	04/02/09	11 hours	0.00035	1.97	Rainfall	1808 Hughes St. Line Cleaned
000	09510050	04/02/09	04/05/09	23 hours	0.1	2.33	Rainfall	501 Bismark Dr
000	10408028	04/03/09	04/03/09	2 hours	0.00006	2.14	Grit/Debris	1901 Capers Ave. Line Cleaned
000	08205000	04/03/09	04/03/09	0.5 hours	0.1	2.62	Mechanical	Channel overflow due to screw pump malfunction.
000	07116057	04/06/09	04/06/09	1.5 hours	0.00009	0.12	Grit/Debris	1400 North 6th St. Line Cleaned
000	07215000	04/09/09	04/09/09	4.5 hours	0.00013	0.00	Grit/Debris	2516 Pennington Ave. Line Cleaned
000	08401009	04/20/09	04/20/09	1.5 hours	0.00012	0.06	Roots	1412 Rosebank Ave, Line Cleaned
000	08301121	04/23/09	04/23/09	1 hours	0.00003	0.02	Grit/Debris	1101 No. 14th St. Line Cleaned
124	Williamson Ferry PS	04/02/09	04/03/09	5.67 hours	0.316	2.62	Rainfall	Inflow/Infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	04/02/09	04/05/09	22.03 hours	0.7	2.33	Rainfall	Inflow/Infiltration. Station at rated capacity.
133	Holiday Travel Park PS	04/02/09	04/03/09	5.58 hours	0.03	1.58	Rainfall	Inflow/Infiltration. Station at rated capacity.
140	28th Avenue PS / Centennial	04/02/09	04/03/09	8.67 hours	1.067	1.60	Rainfall	Inflow/Infiltration. Station at rated capacity.
188	South Oak Hill PS	04/02/09	04/02/09	1.73 hours	0.005	2.37	Rainfall	Inflow/Infiltration. Station at rated capacity.
189	Langford Farms PS	04/02/09	04/03/09	16.62 hours	0.08	1.34	Rainfall	Inflow/Infiltration. Station at rated capacity.
222	Barker Road	04/02/09	04/04/09	44.25 hours	5	1.57	Rainfall	
226	Cowan St. Relief Bleeder	04/02/09	04/03/09	24.33 hours	2.023	2.62	Rainfall	Inflow/Infiltration. Station at rated capacity.
371	Apex St.	04/02/09	04/03/09	12 hours	0.1	2.62	Rainfall	

Monthly Overflow Report

Date Range: April, 2009

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	03413034	04/02/09	04/03/09	12 hours	0.00045	3.51	Rainfall	1442 Gallatin Rd.
106	Vandiver PS	04/02/09	04/03/09	5.84 hours	0.33	2.03	Rainfall	Inflow/Infiltration. Station at rated capacity.
110	Loves Branch PS	04/02/09	04/03/09	6.33 hours	0.437	3.51	Rainfall	Inflow/Infiltration. Station at rated capacity.
112	Gibson Creek PS	04/02/09	04/03/09	4.59 hours	0.886	3.51	Rainfall	Inflow/Infiltration. Station at rated capacity.
117	Neely's Bend PS	04/02/09	04/03/09	8.92 hours	0.2	3.51	Rainfall	Inflow/Infiltration. Station at rated capacity.
127	Madison Heights PS	04/02/09	04/03/09	6.07 hours	0.02	3.51	Rainfall	Inflow/Infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	04/02/09	04/03/09	5.45 hours	0.05	3.51	Rainfall	Inflow/Infiltration. Station at rated capacity.
150	Hidden Acres PS	04/02/09	04/03/09	4.47 hours	0.04	3.51	Rainfall	Inflow/Infiltration. Station at rated capacity.
303	N. Dupont Avenue	04/02/09	04/03/09	8 hours	0.00015	3.51	Rainfall	

Monthly Overflow Report

Date Range: April, 2009

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09110002	04/02/09	04/03/09	10 hours	0.1	1.65	Rainfall	Briley Parkway
000	11507055	04/02/09	04/03/09	11 hours	0.1	1.65	Rainfall	612 Davidson Rd.
000	05013010	04/02/09	04/03/09	12 hours	0.00075	2.62	Rainfall	Brick Church Pk
000	13007005	04/02/09	04/02/09	7 hours	0.0023	2.36	Rainfall	4013 Harding Pl
000	07006034	04/24/09	04/24/09	1.5 hours	0.00006	0.00	Grit/Debris	926 W. Trinity Ln. Line Cleaned
104	Whites Creek PS	04/02/09	04/03/09	5.91 hours	0.789	1.60	Rainfall	Inflow/Infiltration. Station at rated capacity.
104	Whites Creek PS	04/06/09	04/08/09	63 hours	0.052	0.13	Rainfall	Inflow/Infiltration. Station at rated capacity.
104	Whites Creek PS	04/10/09	04/11/09	34.17 hours	0.026	0.96	Rainfall	Inflow/Infiltration. Station at rated capacity.
107	West Park PS	04/02/09	04/03/09	5.84 hours	0.461	4.65	Rainfall	Inflow/Infiltration. Station at rated capacity.
114	Davidson Branch PS	04/02/09	04/02/09	1.58 hours	0.127	1.65	Rainfall	Inflow/Infiltration. Station at rated capacity.
145	Joelton PS	04/02/09	04/03/09	7.77 hours	0.05	2.03	Rainfall	Inflow/Infiltration. Station at rated capacity.
145	Joelton PS	04/10/09	04/10/09	3.72 hours	0.02	0.90	Rainfall	Inflow/Infiltration. Station at rated capacity.
145	Joelton PS	04/19/09	04/19/09	5.37 hours	0.05	1.40	Rainfall	Inflow/Infiltration. Station at rated capacity.
170	Edinburgh PS	04/02/09	04/03/09	8.9 hours	0.02	2.37	Rainfall	Inflow/Infiltration. Station at rated capacity.
217	Basswood	04/02/09	04/03/09	9.42 hours	0.797	1.65	Rainfall	
337	Richland Creek (TDOT)	04/02/09	04/03/09	10 hours	0.1	1.65	Rainfall	
379	622 Davidson	04/02/09	04/02/09	3 hours	0.1	1.65	Rainfall	

Monthly Overflow Report

Date Range: April, 2009

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume	Rainfall	Overflow Cause	Remarks
					(mg)			

Sanitary Sewer Overflows

111	Brentwood PS	04/02/09	04/04/09	37.42 hours	2.348	2.37	Rainfall	Inflow/Infiltration. Station at rated capacity.
-----	--------------	----------	----------	-------------	-------	------	----------	---