

Monthly Overflow Report

Date Range: August, 2009

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09216006	08/04/09	08/04/09	0.5 hours	0.00002	0.86	Grit/Debris	1900 Broadway. Line Cleaned.
000	07111054	08/10/09	08/11/09	22 hours	0.1	1.78	Grit/Debris	1549 Luton St. Line Cleaned
000	16116070	08/14/09	08/14/09	7.5 hours	0.00009	0.00	Line Break	455 Swiss Ave. Line Repaired
000	09208136	08/22/09	08/22/09	9 hours	0.00011	0.00	Line Break	17th Ave & Jo Johnson. Line Repaired, Contained Overflow.
001a	Central WTP Stormwater TF	08/20/09	08/20/09	0.5 hours	0.05	0.66	Excessive Flow	Heavy flow. Staff attempting to distribute flow thru plant.
199	Woodlake P.S.	08/27/09	08/27/09	0.5 hours	0.001	0.00	Other/not listed	Route crew left pumps in OFF position.
226	Cowan St. Relief Bleeder	08/11/09	08/11/09	0.67 hours	0.002	1.78	Rainfall	

Monthly Overflow Report

Date Range: August, 2009

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09016059	08/08/09	08/08/09	3.5 hours	0.00005	0.00	Line Break	6426 Thunderbird Dr. Line Repaired
000	06014008	08/26/09	08/26/09	3.5 hours	0.00003	0.00	Grit/Debris	2710 Locust St. Line Cleaned
000	14510040	08/27/09	08/27/09	1.5 hours	0.00002	0.00	Line Break	1334 Otter Creek Rd. Line Repaired
138	Sunliner PS	08/04/09	08/04/09	2 hours	0.006	1.16	Power Related	NES Power out. Stationary generator to be installed.