

Monthly Overflow Report

Date Range: September, 2009

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	12009028	09/03/09	09/03/09	1 hours	0.00002	0.31	Roots	613 Glen Park Ct. Line Cleaned
000	13302041	09/17/09	09/17/09	1.5 hours	0.00006	4.85	Grit/Debris	3120 Kinross. Line cleaned.
000	09510050	09/17/09	09/18/09	31 hours	0.1	4.85	Rainfall	501 Bismark Dr
000	08602058	09/17/09	09/17/09	2.5 hours	0.1	5.89	Rainfall	428 Old Lebanon Rd
000	08602062	09/17/09	09/17/09	3 hours	0.1	4.85	Rainfall	Old Lebanon Dirt Rd.
000	08606106	09/17/09	09/17/09	5 hours	0.1	4.85	Rainfall	5289 Old Hickory Blvd
000	17605032	09/19/09	09/19/09	2 hours	0.00004	0.11	Grease	6644 Shady View Dr.
000	16205055	09/23/09	09/23/09	4 hours	0.00009	0.31	Grease	355 Ocala Line Cleaned
000	09206027	09/23/09	09/23/09	3 hours	0.00009	0.72	Line Break	2620 27th Ave No. (Overflowed into basement) Line Repaired.
000	08212007	09/25/09	09/25/09	0.5 hours	0.00009	0.01	Grit/Debris	926 Marina St. Line Cleaned
000	11913092	09/26/09	09/26/09	3 hours	0.00005	3.17	Rainfall	2932 Louise Dr.
000	08602062	09/26/09	09/26/09	2 hours	0.00007	2.33	Rainfall	Old Lebanon Dirt Rd.
000	10616031	09/26/09	09/26/09	3 hours	0.00005	2.13	Rainfall	412 Hollydale Dr.
000	08606106	09/26/09	09/26/09	1.5 hours	0.00005	2.33	Rainfall	5301 Old Hickory Blvd
000	17204046	09/26/09	09/26/09	5 hours	0.00006	2.13	Grit/Debris	1405 Timber Ridge Cir
000	10405023	09/26/09	09/26/09	4 hours	0.00009	2.62	Rainfall	223 Nebraska Ave.
000	07508062	09/26/09	09/26/09	1 hours	0.00006	2.65	Rainfall	692 Frankfort Dr.
000	08603179	09/26/09	09/26/09	4 hours	0.00004	2.33	Rainfall	4021 Andrew Jackson Pwky
000	15007013	09/26/09	09/26/09	4 hours	0.00003	2.50	Rainfall	3244 New Towne Rd.
000	09510050	09/26/09	09/27/09	40 hours	1	2.33	Rainfall	501 Bismark
102	Smith Springs PS	09/26/09	09/27/09	16.33 hours	1.873	2.50	Rainfall	Inflow/Infiltration. Station at rated capacity. EQ basins full.
124	Williamson Ferry PS	09/17/09	09/17/09	3.08 hours	0.159	4.25	Rainfall	Inflow/Infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	09/16/09	09/18/09	25.59 hours	4.591	4.50	Rainfall	Inflow/Infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	09/26/09	09/27/09	29.42 hours	5.793	3.18	Rainfall	Inflow/Infiltration. Station at rated capacity.
133	Holiday Travel Park PS	09/15/09	09/17/09	22.3 hours	0.5	4.85	Rainfall	Inflow/Infiltration. Station at rated capacity.
133	Holiday Travel Park PS	09/26/09	09/26/09	10 hours	0.01	2.33	Rainfall	Inflow/Infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: September, 2009

134	Riverside Drive PS	09/17/09	09/17/09	6.85 hours	0.02	4.00	Rainfall	Inflow/Infiltration. Station at rated capacity.
134	Riverside Drive PS	09/26/09	09/26/09	4.5 hours	0.01	1.69	Rainfall	Inflow/Infiltration. Station at rated capacity.
140	28th Avenue PS / Centennial	09/17/09	09/17/09	2.17 hours	0.149	4.00	Rainfall	Inflow/Infiltration. Station at rated capacity.
140	28th Avenue PS / Centennial	09/26/09	09/26/09	5.5 hours	0.12	1.69	Rainfall	Inflow/Infiltration. Station at rated capacity.
151	Shelby Park PS	09/17/09	09/17/09	2.92 hours	0.404	4.25	Rainfall	Inflow/Infiltration. Station at rated capacity.
151	Shelby Park PS	09/26/09	09/26/09	2 hours	0.035	1.87	Rainfall	Inflow/Infiltration. Station at rated capacity.
161	Longhunter Chase SPS	09/26/09	09/26/09	17 hours	0.02	2.60	Power Related	NES power failure. Stationary generator to be installed.
176	Dodson Chapel PS	09/17/09	09/17/09	0.25 hours	0.001	4.85	Rainfall	Inflow/Infiltration. Station at rated capacity.
176	Dodson Chapel PS	09/26/09	09/26/09	1.58 hours	0.012	2.33	Rainfall	Inflow/Infiltration. Station at rated capacity.
187	Peppertree PS	09/26/09	09/26/09	11.5 hours	0.02	2.60	Rainfall	Inflow/Infiltration. Station at rated capacity.
189	Langford Farms PS	09/17/09	09/17/09	15.25 hours	0.02	5.89	Rainfall	Inflow/Infiltration. Station at rated capacity.
189	Langford Farms PS	09/26/09	09/26/09	17 hours	0.02	2.65	Rainfall	Inflow/Infiltration. Station at rated capacity.
222	Barker Road	09/16/09	09/18/09	35.92 hours	8.603	4.85	Rainfall	
222	Barker Road	09/26/09	09/27/09	40.25 hours	12.455	2.33	Rainfall	
226	Cowan St. Relief Bleeder	09/17/09	09/17/09	20.75 hours	0.823	4.25	Rainfall	Inflow/Infiltration. Station at rated capacity.
226	Cowan St. Relief Bleeder	09/26/09	09/26/09	16.67 hours	0.507	1.87	Rainfall	Inflow/Infiltration. Station at rated capacity.
308	Omohundro Dr.-W of Filt P	09/26/09	09/27/09	29 hours	1	3.18	Rainfall	
328	Cooper Lane	09/17/09	09/17/09	6 hours	0.1	4.25	Rainfall	
370	Lisa Lane Overflow	09/26/09	09/27/09	27 hours	1	3.18	Rainfall	
371	Apex St.	09/17/09	09/17/09	5 hours	0.00002	4.25	Rainfall	
371	Apex St.	09/26/09	09/26/09	4 hours	0.00008	1.87	Rainfall	

Monthly Overflow Report

Date Range: September, 2009

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	03405041	09/16/09	09/16/09	1 hours	0.0001	10.62	Grit/Debris	309 Goldie Dr. Line Cleaned
000	03413034	09/17/09	09/17/09	3 hours	0.00006	10.62	Rainfall	1442 Gallatin Pk.
000	05316027	09/21/09	09/21/09	3.5 hours	0.00006	0.19	Grit/Debris	3608 Old Hickory Blvd. Line Cleaned
106	Vandiver PS	09/17/09	09/17/09	6.33 hours	0.155	3.61	Rainfall	Inflow/Infiltration. Station at rated capacity.
110	Loves Branch PS	09/17/09	09/17/09	6.33 hours	0.602	10.62	Rainfall	Inflow/Infiltration. Station at rated capacity.
112	Gibson Creek PS	09/17/09	09/17/09	3.25 hours	0.494	10.62	Rainfall	Inflow/Infiltration. Station at rated capacity.
117	Neely's Bend PS	09/17/09	09/17/09	0.25 hours	0.01	10.62	Rainfall	Inflow/Infiltration. Station at rated capacity.
117	Neely's Bend PS	09/26/09	09/26/09	0.25 hours	0.001	2.91	Rainfall	Inflow/Infiltration. Station at rated capacity.
127	Madison Heights PS	09/17/09	09/17/09	5.5 hours	0.006	4.25	Rainfall	Inflow/Infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	09/17/09	09/17/09	3 hours	0.004	10.62	Rainfall	Inflow/Infiltration. Station at rated capacity.
303	N. Dupont Avenue	09/17/09	09/17/09	4 hours	0.00002	10.62	Rainfall	

Monthly Overflow Report

Date Range: September, 2009

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09015150	09/17/09	09/17/09	1 hours	0.00002	4.46	Roots	409 Capri Ct (Overflowed into basement)
000	09015152	09/17/09	09/17/09	1 hours	0.00002	4.46	Roots	405 Capri Ct. (Overflowed into basement)
000	09015151	09/17/09	09/17/09	1 hours	0.00002	4.46	Roots	407 Capri Ct. (Overflowed into basement)
000	05010029	09/17/09	09/17/09	8 hours	0.00006	4.88	Rainfall	Brick Church Pk.
000	09015147	09/17/09	09/17/09	1 hours	0.00002	4.46	Roots	415 Capri Ct. (Overflowed into basement)
000	09012057	09/17/09	09/17/09	8 hours	0.00005	4.46	Rainfall	6303 Henry Ford Dr.
000	1020300FM	09/17/09	09/17/09	4 hours	0.05	4.46	Force Main	Broken 14" FM. Forcemain repaired.
000	06001011	09/17/09	09/17/09	6 hours	0.00007	4.88	Rainfall	Brick Church Pk.
000	05010032	09/26/09	09/26/09	3 hours	0.00004	1.92	Rainfall	Brick Church Pk.
000	06010013	09/26/09	09/26/09	3 hours	0.00003	1.87	Rainfall	Brick Church Pk.
000	13007005	09/26/09	09/26/09	5 hours	0.00005	2.62	Rainfall	4013 Harding Place
000	11507055	09/26/09	09/26/09	3 hours	0.00005	2.02	Rainfall	612 Davidson Rd
000	09012057	09/26/09	09/26/09	10 hours	0.00005	2.02	Rainfall	6303 Henry Ford Dr.
000	05010032	09/26/09	09/26/09	3 hours	0.00002	1.87	Rainfall	Brick Church Pk.
000	07006009	09/30/09	09/30/09	3 hours	0.00009	0.00	Grit/Debris	2525 Buena Vista Pk. Line Cleaned.
101	Bordeaux Hospital PS	09/17/09	09/17/09	1 hours	0.001	4.00	Rainfall	Inflow/Infiltration. Station at rated capacity.
104	Whites Creek PS	09/17/09	09/18/09	29.75 hours	4.843	4.00	Rainfall	Inflow/Infiltration. Station at rated capacity.
104	Whites Creek PS	09/26/09	09/27/09	30.5 hours	4.682	1.69	Rainfall	Inflow/Infiltration. Station at rated capacity.
107	West Park PS	09/17/09	09/17/09	6.33 hours	1.608	4.46	Rainfall	Inflow/Infiltration. Station at rated capacity.
107	West Park PS	09/26/09	09/26/09	8.5 hours	1.569	2.02	Rainfall	Inflow/Infiltration. Station at rated capacity.
114	Davidson Branch PS	09/17/09	09/17/09	3.92 hours	0.129	4.46	Rainfall	Inflow/Infiltration. Station at rated capacity.
114	Davidson Branch PS	09/26/09	09/26/09	1.83 hours	0.024	2.02	Rainfall	Inflow/Infiltration. Station at rated capacity.
126	Cleeces Ferry PS	09/17/09	09/17/09	4.5 hours	0.01	4.46	Rainfall	Inflow/Infiltration. Station at rated capacity.
126	Cleeces Ferry PS	09/26/09	09/26/09	6 hours	0.01	2.02	Rainfall	Inflow/Infiltration. Station at rated capacity.
136	River Drive PS	09/17/09	09/17/09	0.92 hours	0.004	4.00	Rainfall	Inflow/Infiltration. Station at rated capacity.
138	Sunliner PS	09/17/09	09/17/09	2.25 hours	0.003	4.46	Rainfall	Inflow/Infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: September, 2009

138	Sunliner PS	09/17/09	09/17/09	0.5 hours	0.005	4.46	Power Related	NES power out. Stationary generator ordered.
145	Joelton PS	09/06/09	09/06/09	0.25 hours	0.001	0.80	Rainfall	Inflow/Infiltration. Station at rated capacity.
217	Basswood	09/17/09	09/17/09	15.42 hours	1.78	4.46	Rainfall	
217	Basswood	09/26/09	09/26/09	16.83 hours	1.798	2.02	Rainfall	
337	Richland Creek (TDOT)	09/17/09	09/17/09	11.5 hours	1	4.46	Rainfall	
337	Richland Creek (TDOT)	09/26/09	09/26/09	15 hours	0.1	2.02	Rainfall	
379	622 Davidson	09/26/09	09/26/09	4 hours	0.00005	2.02	Rainfall	