

Monthly Overflow Report

Date Range: October, 2009

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14814096	10/02/09	10/02/09	1 hours	0.00003	0.31	Grit/Debris	4702 Packard Dr. Line Cleaned
000	12005053	10/03/09	10/03/09	1 hours	0.00004	0.00	Grit/Debris	412 McDonald Dr. Line Cleaned
000	09208055	10/05/09	10/05/09	1 hours	0.00002	0.49	Grit/Debris	1413 Charlotte Ave. Line Cleaned
000	09308041	10/15/09	10/15/09	1.5 hours	0.00004	0.00	Roots	899 S. 6th St. Line Cleaned
000	09510050	10/15/09	10/16/09	16 hours	0.1	1.55	Rainfall	501 Bismark
000	14808058	10/18/09	10/18/09	1.5 hours	0.00005	0.00	Grit/Debris	134 Volcano Ct. Line Cleaned
000	13408036	10/18/09	10/18/09	1 hours	0.00005	0.00	Grit/Debris	436 Ezell Pk. Line Cleaned
000	08309028	10/23/09	10/23/09	1 hours	0.00002	0.65	Grit/Debris	1410 Woodland St. Line Cleaned
000	09510050	10/31/09	10/31/09	13 hours	0.409	1.84	Rainfall	501 Bismark
000	10616031	10/31/09	10/31/09	10 hours	0.0001	1.97	Rainfall	416 Hollydale Dr
102	Smith Springs PS	10/31/09	10/31/09	5.75 hours	0.359	1.41	Rainfall	Inflow/infiltration. PS at rated capacity. EQ basins full.
124	Williamson Ferry PS	10/31/09	10/31/09	5 hours	0.224	1.91	Rainfall	Inflow/infiltration. PS at rated capacity.
130	Brown's Creek PS / Visco Dr.	10/15/09	10/15/09	1.75 hours	0.036	1.92	Rainfall	Inflow/infiltration. PS at rated capacity.
130	Brown's Creek PS / Visco Dr.	10/31/09	10/31/09	7.5 hours	0.145	1.97	Rainfall	Inflow/infiltration. PS at rated capacity.
133	Holiday Travel Park PS	10/15/09	10/15/09	0.2 hours	0.002	1.35	Rainfall	Inflow/infiltration. PS at rated capacity.
133	Holiday Travel Park PS	10/30/09	11/02/09	65.97 hours	0.2	1.88	Rainfall	Inflow/infiltration. PS at rated capacity. #1 pump OoS.
134	Riverside Drive PS	10/31/09	10/31/09	5.62 hours	0.02	1.71	Rainfall	Inflow/infiltration. PS at rated capacity.
140	28th Avenue PS / Centennial	10/31/09	10/31/09	2.5 hours	0.041	1.71	Rainfall	Inflow/infiltration. PS at rated capacity.
189	Langford Farms PS	10/31/09	10/31/09	10 hours	0.03	1.85	Rainfall	Inflow/infiltration. PS at rated capacity.
222	Barker Road	10/15/09	10/16/09	17.92 hours	3.025	1.62	Rainfall	
222	Barker Road	10/31/09	11/01/09	24.08 hours	5.223	1.84	Rainfall	
226	Cowan St. Relief Bleeder	10/15/09	10/15/09	3.92 hours	0.04	1.53	Rainfall	
226	Cowan St. Relief Bleeder	10/31/09	11/01/09	25.75 hours	0.997	1.91	Rainfall	
370	Lisa Lane Overflow	10/31/09	10/31/09	6 hours	0.5	1.97	Rainfall	

Monthly Overflow Report

Date Range: October, 2009

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04315046	10/01/09	10/01/09	1.5 hours	0.00004	0.00	Grease	820 Old Hickory Blvd. Line Cleaned
000	04312026	10/03/09	10/03/09	1.5 hours	0.00005	0.00	Grit/Debris	218 Rio Vista Dr. Line Cleaned
106	Vandiver PS	10/31/09	10/31/09	8.25 hours	0.212	1.84	Rainfall	Inflow/infiltration. PS at rated capacity.
110	Loves Branch PS	10/31/09	10/31/09	3.58 hours	0.081	1.84	Rainfall	Inflow/infiltration. PS at rated capacity.
132	Berwick Trail PS / Center St.	10/31/09	10/31/09	9.5 hours	0.03	1.85	Rainfall	Inflow/infiltration. PS at rated capacity.

Monthly Overflow Report

Date Range: October, 2009

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	11612075	10/07/09	10/07/09	1 hours	0.00003	0.00	Grit/Debris	228 Burlington Pl. Line Cleaned
000	10306039	10/12/09	10/12/09	1 hours	0.00002	0.00	Grit/Debris	5604 Stoneway Trail. Line Cleaned
000	11612075	10/16/09	10/16/09	2 hours	0.00007	0.00	Grit/Debris	228 Burlington Pl. Line Cleaned
000	08006006	10/28/09	01/28/09	1 hours	0.00002	0.00	Grit/Debris	3308 Olsen Ln. Overflowed in basement. Line Cleaned
104	Whites Creek PS	10/15/09	10/16/09	20.42 hours	3.077	1.59	Rainfall	Inflow/infiltration. PS at rated capacity.
104	Whites Creek PS	10/31/09	11/01/09	25.33 hours	3.896	1.71	Rainfall	Inflow/infiltration. PS at rated capacity.
107	West Park PS	10/31/09	10/31/09	2.08 hours	0.192	1.88	Rainfall	Inflow/infiltration. PS at rated capacity.
114	Davidson Branch PS	10/15/09	10/15/09	2 hours	0.028	1.73	Rainfall	Inflow/infiltration. PS at rated capacity.
114	Davidson Branch PS	10/31/09	10/31/09	4.42 hours	0.047	1.88	Rainfall	Inflow/infiltration. PS at rated capacity.
145	Joelton PS	10/15/09	10/15/09	8.3 hours	0.02	1.20	Rainfall	Inflow/infiltration. PS at rated capacity.
145	Joelton PS	10/30/09	10/31/09	16.4 hours	0.05	1.78	Rainfall	Inflow/infiltration. PS at rated capacity.
217	Basswood Ave.	10/15/09	10/15/09	4.42 hours	0.113	1.73	Rainfall	
217	Basswood Ave.	10/31/09	10/31/09	12.67 hours	0.648	1.88	Rainfall	
337	Richland Creek (TDOT)	10/15/09	10/15/09	4 hours	0.1	1.73	Rainfall	
337	Richland Creek (TDOT)	10/31/09	10/31/09	11 hours	0.1	1.88	Rainfall	