

Monthly Overflow Report

Date Range: December, 2009

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	15113020	12/01/09	12/01/09	2.5 hours	0.00002	0.00	Grit/Debris	5413 Skip Jack Dr. Line Cleaned.
000	14905042	12/01/09	12/01/09	1 hours	0.00001	0.00	Roots	4761 Terragon Tr. Line Cleaned
000	13413101	12/02/09	12/02/09	4 hours	0.00002	0.58	Grit/Debris	267 Eisenhower Dr. Line Cleaned
000	WLS52013	12/03/09	12/03/09	7 hours	0.00004	0.00	Force Main	820 Overhills Dr. placed cap back on force main.
000	16413006	12/04/09	12/04/09	3 hours	0.00002	0.00	Roots	5536 Cedar Ash Crossing. Line Cleaned
000	18206043	12/08/09	12/08/09	0.5 hours	0.00001	1.67	Grit/Debris	7100 Legacy Dr.
000	09510050	12/08/09	12/09/09	5.5 hours	0.1	2.02	Rainfall	501 Bismark Dr.
000	10402072	12/09/09	12/09/09	2 hours	0.00002	0.00	Grit/Debris	213 30th Ave No. Line Cleaned
000	09209019	12/09/09	12/09/09	3.5 hours	0.00003	1.94	Grit/Debris	3920 Clifton Ave. Line Cleaned
000	WLS52058	12/09/09	12/09/09	1 hours	0.00003	0.00	Force Main	812 Overhills Dr. Place cap back on force main.
000	10606003	12/11/09	12/11/09	1.5 hours	0.00001	0.00	Grease	1009 Foster Ave. Line Cleaned
000	WLS52058	12/11/09	12/11/09	3 hours	0.00004	0.00	Force Main	810 Overhills Dr. Placed cap back on force main
000	10509144	12/13/09	12/13/09	2.5 hours	0.00002	0.00	Grit/Debris	1019 Bate Ave. Line Cleaned
000	052090CO	12/14/09	12/14/09	4 hours	0.00003	0.00	Force Main	2663 Miami Ave. Replaced cap back on grinder FM.
000	WLS52058	12/17/09	12/17/09	4 hours	0.00003	0.00	Force Main	812 Overhills Dr. Repaired force main
000	WSL52058	12/22/09	12/22/09	2 hours	0.00003	0.00	Force Main	812 Overhills Dr. Repaired force main
000	16207032	12/29/09	12/29/09	6.5 hours	0.00006	0.00	Grit/Debris	152 Tusculum Rd. Line Cleaned
000	08303025	12/29/09	12/29/09	1.5 hours	0.00001	0.00	Grit/Debris	2038 Greenwood Ave. Line Cleaned
000	16204021	12/29/09	12/29/09	3 hours	0.00002	0.00	Grit/Debris	Blue Hole Rd. & Antioch Pk. Line Cleaned
000	07108082	12/29/09	12/29/09	1 hours	0.00001	0.00	Grit/Debris	502 Norton Ave. Line Cleaned
102	Smith Springs PS	12/09/09	12/09/09	2.08 hours	0.048	1.53	Rainfall	Inflow/infiltration. Station at rated capacity.
124	Williamson Ferry PS	12/08/09	12/09/09	8.92 hours	0.487	2.06	Rainfall	Inflow/infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	12/08/09	12/09/09	6.75 hours	0.476	2.02	Rainfall	Inflow/infiltration. Station at rated capacity.
133	Holiday Travel Park PS	12/08/09	12/09/09	17 hours	0.05	1.65	Rainfall	Inflow/infiltration. Station at rated capacity.
134	Riverside Drive PS	12/08/09	12/09/09	9.15 hours	0.03	2.01	Rainfall	Inflow/infiltration. Station at rated capacity.
140	28th Avenue PS / Centennial	12/08/09	12/09/09	4.84 hours	0.23	2.01	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: December, 2009

158	Farmingham Woods PS	12/08/09	12/08/09	1 hours	0.001	1.65	Rainfall	Inflow/infiltration. Station at rated capacity.
222	Barker Road	12/08/09	12/10/09	22.75 hours	3.586	1.65	Rainfall	
226	Cowan St. Relief Bleeder	12/08/09	12/09/09	18.08 hours	0.786	2.06	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: December, 2009

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
106	Vandiver PS	12/08/09	12/09/09	9.25 hours	0.357	2.05	Rainfall	Inflow/infiltration. Station at rated capacity.
110	Loves Branch PS	12/08/09	12/09/09	5.08 hours	0.189	2.01	Rainfall	Inflow/infiltration. Station at rated capacity.
123	Lakewood PS	12/08/09	12/08/09	1 hours	0.001	2.05	Rainfall	Inflow/infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	12/08/09	12/09/09	6 hours	0.01	2.01	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: December, 2009

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	11507055	12/08/09	12/08/09	1.5 hours	0.00007	1.94	Rainfall	612 Davidson Rd.
000	05815039	12/09/09	12/09/09	3 hours	0.00003	0.00	Grit/Debris	4129 Home Haven Dr. Line Cleaned.
104	Whites Creek PS	12/08/09	12/10/09	30.58 hours	2.822	2.01	Rainfall	Inflow/infiltration. Station at rated capacity.
107	West Park PS	12/08/09	12/09/09	1.5 hours	0.147	1.94	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	12/08/09	12/09/09	0.91 hours	0.004	1.94	Rainfall	Inflow/infiltration. Station at rated capacity.
145	Joelton PS	12/08/09	12/08/09	14.5 hours	0.02	2.44	Rainfall	Inflow/infiltration. Station at rated capacity.
170	Edinburgh PS	12/08/09	12/08/09	1 hours	0.001	1.74	Rainfall	Inflow/infiltration. Station at rated capacity.
217	Basswood Ave.	12/08/09	12/09/09	12.42 hours	0.604	1.94	Rainfall	
337	Richland Creek (TDOT)	12/08/09	12/09/09	10 hours	0.1	1.94	Rainfall	
379	622 Davidson	12/08/09	12/09/09	2 hours	0.00008	1.94	Rainfall	