

Monthly Overflow Report

Date Range: January, 2010

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	13413029	01/04/10	01/04/10	1 hours	0.00001	0.00	Grit/Debris	200 Paragon Mills Rd. Line Cleaned
000	07404104	01/11/10	01/11/10	1.5 hours	0.00001	0.00	Grit/Debris	709 Linden Green Dr. Line Cleaned
000	09308041	01/11/10	01/11/10	2 hours	0.00001	0.00	Roots	891 South 6th. St Line Cleaned
000	08302003	01/13/10	01/13/10	1.5 hours	0.00001	0.00	Grit/Debris	1539 Douglas Ave. Line Cleaned
000	WMN33P077	01/15/10	01/15/10	1 hours	0.00001	0.00	Grit/Debris	2608 Brookfield. Line Cleaned
000	09510050	01/17/10	01/17/10	5 hours	0.1	2.05	Rainfall	501 Bismark
000	13512019	01/17/10	01/17/10	4 hours	0.00002	1.37	Grit/Debris	Nashboro Village. Line Cleaned
000	10616031	01/17/10	01/17/10	5 hours	0.00003	2.05	Rainfall	408 Holly Dale Dr.
000	08602062	01/17/10	01/17/10	2 hours	0.00003	1.93	Rainfall	Old Lebanon Dirt Rd.
000	10504094	01/20/10	01/20/10	1.5 hours	0.00001	0.50	Grit/Debris	1260 Lewis St. Line Cleaned
000	16211019	01/22/10	01/22/10	1.5 hours	0.00001	0.00	Grit/Debris	1453 Bell Rd. Line Cleaned
000	08110027	01/25/10	01/25/10	2.5 hours	0.00002	0.07	Roots	1737 22nd Ave. N Line Cleaned
000	09613035	01/26/10	01/26/10	3.5 hours	0.00002	0.00	Grit/Debris	519 Donelson Pk. Line Cleaned
000	10509095	01/26/10	01/26/10	1 hours	0.00001	0.00	Grit/Debris	1001 W. Grove Ave. Line Cleaned
102	Smith Springs PS	01/17/10	01/17/10	8.5 hours	0.979	1.93	Rainfall	Inflow/infiltration - station at rated capacity.
130	Brown's Creek PS / Visco Dr.	01/17/10	01/17/10	0.08 hours	0.002	2.05	Rainfall	Inflow/infiltration - station at rated capacity.
133	Holiday Travel Park PS	01/17/10	01/18/10	23.5 hours	0.01	2.19	Rainfall	Inflow/infiltration - station at rated capacity.
134	Riverside Drive PS	01/15/10	01/15/10	0.5 hours	0.0001	0.00	Controller	Compressor failed on bubbler control system. Unit replaced.
134	Riverside Drive PS	01/17/10	01/17/10	4.5 hours	0.005	1.86	Rainfall	Inflow/infiltration - station at rated capacity.
161	Longhunter Chase SPS	01/17/10	01/17/10	11.5 hours	0.002	2.04	Rainfall	Inflow/infiltration - station at rated capacity.
176	Dodson Chapel PS	01/17/10	01/17/10	1.17 hours	0.044	1.93	Rainfall	Inflow/infiltration - station at rated capacity.
189	Langford Farms PS	01/17/10	01/17/10	4 hours	0.001	1.94	Rainfall	Inflow/infiltration - station at rated capacity.
190	Towne Village PS	01/17/10	01/17/10	5.75 hours	0.001	1.93	Rainfall	Inflow/infiltration - station at rated capacity.
222	Barker Road	01/17/10	01/19/10	13.17 hours	0.272	1.93	Rainfall	
222	Barker Road	01/22/10	01/22/10	0.67 hours	0.005	0.45	Rainfall	2.60" rain in previous 5 days
226	Cowan St. Relief Bleeder	01/17/10	01/17/10	13.75 hours	0.303	1.83	Rainfall	

Monthly Overflow Report

Date Range: January, 2010

371	Apex St.	01/17/10	01/17/10	7 hours	0.00004	1.83	Rainfall
-----	----------	----------	----------	---------	---------	------	----------

Monthly Overflow Report

Date Range: January, 2010

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05316095	01/13/10	01/13/10	2.5 hours	0.00001	0.00	Grit/Debris	100 Iris Ave. Line Cleaned

Monthly Overflow Report

Date Range: January, 2010

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14405017	01/17/10	01/17/10	10 hours	0.00003	1.05	Rainfall	1318 Chickering Rd.
000	09114155	01/18/10	01/18/10	4 hours	0.00002	0.00	Line Break	5600 Lozier St. Broke and repaired by Contractor
104	Whites Creek PS	01/17/10	01/18/10	24.09 hours	4.465	1.86	Rainfall	Inflow/infiltration - station at rated capacity.
104	Whites Creek PS	01/21/10	01/22/10	14.5 hours	1.171	0.28	Rainfall	2.35" rain in previous 5 days. Station at rated capacity.
104	Whites Creek PS	01/24/10	01/25/10	19 hours	0.263	0.91	Rainfall	Inflow/infiltration - station at rated capacity.
114	Davidson Branch PS	01/17/10	01/17/10	1.33 hours	0.008	1.85	Rainfall	Inflow/infiltration - station at rated capacity.
145	Joelton PS	01/17/10	01/17/10	10 hours	0.001	1.75	Rainfall	Inflow/infiltration - station at rated capacity.
145	Joelton PS	01/20/10	01/21/10	12.25 hours	0.001	1.08	Rainfall	Inflow/infiltration - station at rated capacity.
145	Joelton PS	01/24/10	01/24/10	12 hours	0.001	0.80	Rainfall	Inflow/infiltration - station at rated capacity.
217	Basswood Ave.	01/21/10	01/21/10	1.75 hours	0.024	0.29	Rainfall	2.42" rain in previous 5 days
217	Basswood Ave.	01/24/10	01/25/10	10.09 hours	0.167	0.95	Rainfall	
337	Richland Creek (TDOT)	01/24/10	01/25/10	9 hours	0.1	0.95	Rainfall	