

Monthly Overflow Report

Date Range: February, 2010

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09510050	02/05/10	02/05/10	9 hours	0.1	1.48	Rainfall	501 Bismark.
000	10616031	02/05/10	02/05/10	3 hours	0.00002	1.48	Rainfall	416 Hollydale Dr.
000	06509119	02/08/10	02/08/10	4.5 hours	0.00002	0.00	Grit/Debris	4864 Whittier Dr. Line Cleaned
000	09510005	02/09/10	02/10/10	2.5 hours	0.00002	0.85	Rainfall	501 Bismark.
000	06509121	02/16/10	02/16/10	1 hours	0.00001	0.00	Roots	4817 Catskill Dr. Line Cleaned
000	16112028	02/16/10	02/16/10	2 hours	0.00002	0.00	Roots	500 Hickoryview Dr. Line Cleaned
000	06101018	02/18/10	02/18/10	2 hours	0.00002	0.00	Grit/Debris	5005 Ruskin Ave. Line Cleaned
000	14902023	02/19/10	02/19/10	1 hours	0.00001	0.00	Grit/Debris	2231 Antioch Pk. Line Cleaned
000	14807075	02/20/10	02/20/10	0.5 hours	0.00001	0.00	Grit/Debris	1508 Denise Ct. Line Cleaned
000	08103070	02/24/10	02/24/10	1 hours	0.00001	0.00	Grit/Debris	1105 Cecilia Ave. Line Cleaned
000	08103088	02/24/10	02/24/10	1 hours	0.00001	0.00	Grit/Debris	1015 Kellow St. Line Cleaned
000	11706063	02/27/10	02/27/10	1 hours	0.00001	0.00	Grit/Debris	2164 Golf Ln. Line Cleaned
102	Smith Springs PS	02/05/10	02/05/10	8.58 hours	0.589	1.32	Rainfall	Inflow/Infiltration. Facility at design capacity.
130	Brown's Creek PS / Visco Dr.	02/05/10	02/05/10	7.25 hours	0.005	1.48	Rainfall	Inflow/Infiltration. Facility at design capacity.
133	Holiday Travel Park PS	02/05/10	02/05/10	11.8 hours	0.005	1.30	Rainfall	Inflow/Infiltration. Facility at design capacity.
222	Barker Road	02/06/10	02/06/10	8.92 hours	0.998	1.29	Rainfall	EQ basin full.
222	Barker Road	02/09/10	02/10/10	7.17 hours	0.453	0.85	Rainfall	EQ basin full.
226	Cowan St. Relief Bleeder	02/05/10	02/05/10	16.75 hours	0.228	1.29	Rainfall	
370	Lisa Lane Overflow	02/05/10	02/05/10	6 hours	0.1	1.48	Rainfall	
371	Apex St.	02/05/10	02/05/10	3 hours	0.00002	1.29	Rainfall	

Monthly Overflow Report

Date Range: February, 2010

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04304018	02/19/10	02/19/10	2 hours	0.00001	0.00	Grit/Debris	140 Scenic View Dr. Line Cleaned
000	04401021	02/23/10	02/23/10	1.5 hours	0.00001	0.00	Grit/Debris	5004 Cobblestone Creek Dr. Line Cleaned

Monthly Overflow Report

Date Range: February, 2010

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05912006	02/17/10	02/17/10	4.5 hours	0.00003	0.00	Roots	108 Highland Trace Cove. Line Cleaned
104	Whites Creek PS	02/05/10	02/06/10	14.5 hours	1.096	1.27	Rainfall	Inflow/Infiltration. Facility at design capacity.
107	West Park PS	02/05/10	02/06/10	30.75 hours	8.143	1.31	Rainfall	Inflow/Infiltration. Facility at design capacity.
107	West Park PS	02/09/10	02/09/10	1.83 hours	0.911	0.90	Rainfall	Inflow/Infiltration. Facility at design capacity.
145	Joelton PS	02/05/10	02/06/10	22.4 hours	0.01	1.28	Rainfall	Inflow/Infiltration. Facility at design capacity.
145	Joelton PS	02/09/10	02/09/10	4.21 hours	0.005	0.77	Rainfall	Inflow/Infiltration. Facility at design capacity.
217	Basswood Ave.	02/05/10	02/06/10	28.66 hours	2.164	1.31	Rainfall	
217	Basswood Ave.	02/09/10	02/09/10	7.92 hours	0.227	0.90	Rainfall	
337	Richland Creek (TDOT)	02/05/10	02/06/10	28 hours	0.1	1.31	Rainfall	TDOT Manhole.
337	Richland Creek (TDOT)	02/09/10	02/09/10	1 hours	0.00009	0.90	Rainfall	TDOT Manhole.