

# Monthly Overflow Report

Date Range: March, 2010

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	07114063	03/09/10	03/09/10	2.5 hours	0.00001	0.01	Grit/Debris	1309 Baptist World Center Dr. Line Cleaned.
000	14805016	03/15/10	03/15/10	2 hours	0.00001	0.00	Grit/Debris	3756 Turley Dr. Line Cleaned
000	10402031	03/22/10	03/22/10	1 hours	0.00001	0.00	Line Break	407 Avoca St. Line Repaired
000	13101098	03/23/10	03/23/10	1.5 hours	0.00001	0.00	Grit/Debris	102 Chatsworth Dr. Line Cleaned
000	WMN55D011	03/24/10	03/24/10	0.5 hours	0.00001	0.00	Grit/Debris	1582 Shining Ore Dr. Line Cleaned
000	09209004	03/25/10	03/25/10	4 hours	0.00002	0.99	Line Break	3900 Clifton Ave. Line Repaired
133	Holiday Travel Park PS	03/28/10	03/28/10	3 hours	0.005	0.57	Rags	Rags and Inflow/Infiltration. All equipment in service.

# Monthly Overflow Report

Date Range: March, 2010

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	04208004	03/04/10	03/04/10	2 hours	0.00001	0.00	Roots	2037 Williams Valley Dr. Line Cleaned
000	05316095	03/09/10	03/09/10	6.5 hours	0.00003	0.03	Grit/Debris	100 Iris Ave. Line Cleaned
000	00714008	03/25/10	03/25/10	2 hours	0.0001	0.00	Air Relief Valve	1554 Springfield Highway. Replaced air relief valve.
000	04309080	03/26/10	03/26/10	1 hours	0.00001	0.00	Grit/Debris	101 Duling Ave. Line Cleaned

# Monthly Overflow Report

Date Range: March, 2010

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	05911059	03/02/10	03/02/10	3 hours	0.00001	0.10	Grit/Debris	503 Revels Dr. Line Cleaned
000	05809069	03/12/10	03/12/10	2 hours	0.00001	0.56	Grit/Debris	2817 Cato Ridge. Line Cleaned
000	05905053	03/12/10	03/12/10	1.5 hours	0.00001	0.56	Grit/Debris	4145 Boyd Dr. Line Cleaned
104	Whites Creek PS	03/25/10	03/26/10	13.58 hours	0.767	0.99	Rainfall	Inflow/Infiltration. Facility at rated capacity.
145	Joelton PS	03/21/10	03/21/10	3.45 hours	0.002	0.89	Rainfall	Inflow/Infiltration. Facility at rated capacity.
145	Joelton PS	03/25/10	03/26/10	5.25 hours	0.005	1.11	Rainfall	Inflow/Infiltration. Facility at rated capacity.