

Monthly Overflow Report

Date Range: April, 2010

Central WWTP NPDES# TN 0020575

| # | Overflow Name | Start Date | End Date | Duration | Volume (mg) | Rainfall | Overflow Cause | Remarks |
|---------------------------------|-----------------------------|------------|----------|------------|-------------|----------|------------------|---|
| Sanitary Sewer Overflows | | | | | | | | |
| 000 | 10901032 | 04/01/10 | 04/02/10 | 4 hours | 0.00002 | 0.00 | Grit/Debris | 3936 Lake Ridge Run. Line Cleaned |
| 000 | 11006000 | 04/04/10 | 04/04/10 | 6.5 hours | 0.00003 | 0.00 | Line Break | 1731 Stewarts Ferry Pk. Line Repaired |
| 000 | 11002007 | 04/04/10 | 04/04/10 | 10 hours | 0.00005 | 0.00 | Line Break | 3619 Earhart. Line Repaired |
| 000 | 09401114 | 04/05/10 | 04/05/10 | 1 hours | 0.00001 | 0.00 | Grit/Debris | 610 South 15th St. Line Cleaned |
| 000 | 14801040 | 04/06/10 | 04/06/10 | 1 hours | 0.00001 | 0.00 | Roots | 3713 Turley Dr. Line Repaired |
| 000 | 10901032 | 04/07/10 | 04/07/10 | 2 hours | 0.00001 | 0.00 | Roots | 3936 Lake Ridge Run. Line Cleaned |
| 000 | 08303091 | 04/09/10 | 04/09/10 | 2 hours | 0.00001 | 0.00 | Grit/Debris | 2309 11th Ave No. Line Cleaned |
| 000 | 10412103 | 04/24/10 | 04/24/10 | 1 hours | 0.00001 | 3.17 | Grit/Debris | 1916 19th Ave So. Line Cleaned |
| 000 | 05414033 | 04/26/10 | 04/26/10 | 2 hours | 0.00001 | 0.00 | Air Relief Valve | 301 Louviers Ln. Closed off valve |
| 133 | Holiday Travel Park PS | 04/24/10 | 04/24/10 | 5.95 hours | 0.01 | 2.95 | Rainfall | Inflow/infiltration. Station at rated capacity. |
| 134 | Riverside Drive PS | 04/24/10 | 04/24/10 | 8.8 hours | 0.1 | 2.86 | Rainfall | Inflow/infiltration. Station at rated capacity. |
| 140 | 28th Avenue PS / Centennial | 04/24/10 | 04/24/10 | 1.92 hours | 0.084 | 2.86 | Rainfall | |
| 222 | Barker Road | 04/24/10 | 04/25/10 | 3.75 hours | 0.05 | 1.87 | Rainfall | |
| 226 | Cowan St. Relief Bleeder | 04/24/10 | 04/24/10 | 9.83 hours | 0.317 | 2.92 | Rainfall | |
| 371 | Apex St. | 04/24/10 | 04/24/10 | 9 hours | 0.00005 | 2.92 | Rainfall | |

Monthly Overflow Report

Date Range: April, 2010

Dry Creek WWTP NPDES# TN0020648

| # | Overflow Name | Start Date | End Date | Duration | Volume (mg) | Rainfall | Overflow Cause | Remarks |
|---------------------------------|-------------------------------|------------|----------|------------|-------------|----------|----------------|---|
| Sanitary Sewer Overflows | | | | | | | | |
| 000 | 00715038 | 04/11/10 | 04/11/10 | 7 hours | 0.00004 | 0.00 | Line Break | 2049 Graceland Dr. Line Repaired |
| 106 | Vandiver PS | 04/24/10 | 04/24/10 | 3.33 hours | 0.031 | 1.47 | Rainfall | Inflow/infiltration. Station at rated capacity. |
| 110 | Loves Branch PS | 04/24/10 | 04/24/10 | 1.08 hours | 0.01 | 1.47 | Rainfall | Inflow/infiltration. Station at rated capacity. |
| 132 | Berwick Trail PS / Center St. | 04/24/10 | 04/24/10 | 3.33 hours | 0.005 | 1.47 | Rainfall | Inflow/infiltration. Station at rated capacity. |

Monthly Overflow Report

Date Range: April, 2010

Whites Creek WWTP NPDES# TN 0024970

| # | Overflow Name | Start Date | End Date | Duration | Volume (mg) | Rainfall | Overflow Cause | Remarks |
|---------------------------------|-----------------------|------------|----------|-------------|-------------|----------|----------------|---|
| Sanitary Sewer Overflows | | | | | | | | |
| 000 | 05003010 | 04/02/10 | 04/02/10 | 2 hours | 0.00001 | 0.00 | Grit/Debris | 1404 Bellshire Ter. Line Cleaned |
| 000 | 11507055 | 04/24/10 | 04/24/10 | 2.5 hours | 0.00001 | 2.95 | Rainfall | 612 Davidson Rd. |
| 104 | Whites Creek PS | 04/24/10 | 04/25/10 | 28.08 hours | 3.863 | 2.86 | Rainfall | Inflow/infiltration. Station at rated capacity. |
| 107 | West Park PS | 04/24/10 | 04/24/10 | 4.08 hours | 0.656 | 2.95 | Rainfall | Inflow/infiltration. Station at rated capacity. |
| 114 | Davidson Branch PS | 04/24/10 | 04/24/10 | 3.97 hours | 0.1 | 2.95 | Rainfall | Inflow/infiltration. Station at rated capacity. |
| 126 | Cleeces Ferry PS | 04/24/10 | 04/24/10 | 1.07 hours | 0.01 | 2.95 | Rainfall | Inflow/infiltration. Station at rated capacity. |
| 217 | Basswood Ave. | 04/24/10 | 04/25/10 | 10.25 hours | 0.363 | 2.95 | Rainfall | |
| 337 | Richland Creek (TDOT) | 04/24/10 | 04/24/10 | 8 hours | 0.1 | 2.95 | Rainfall | |