

Monthly Overflow Report

Date Range: June, 2010

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	16013009	06/01/10	06/01/10	1.5 hours	0.00001	0.00	Grit/Debris	5566 Franklin Pk, Line Cleaned
000	WLS75034	06/02/10	06/02/10	2.5 hours	0.00001	0.00	Grit/Debris	4621 Raccoon Trail. Line Cleaned
000	11006013	06/05/10	06/05/10	7.5 hours	0.00013	0.00	Line Break	1735 Stewarts Ferry Pk, Line Repaired
000	16216032	06/06/10	06/06/10	1.5 hours	0.00001	0.00	Grit/Debris	1306 Hickory Park Ct. Line Cleaned
000	WLS52025	06/10/10	06/10/10	2 hours	0.00001	0.00	Roots	268 Lookout Dr. Line Cleaned
000	13304050	06/12/10	06/13/10	12 hours	0.00009	0.00	Grit/Debris	1022 Antioch Pk. Line Cleaned
000	18114026	06/14/10	06/14/10	1 hours	0.00001	0.00	Grit/Debris	6716 Nolensville Rd. Line Cleaned
000	10408036	06/15/10	06/15/10	1 hours	0.00001	0.00	Grit/Debris	1800 21st Ave So. Line Cleaned
000	13308082	06/15/10	06/15/10	12 hours	0.00009	0.00	Roots	241 Brevard Ct, Line Cleaned
000	08108067	06/29/10	06/29/10	6 hours	0.00002	0.00	Grit/Debris	1705 7th Ave No. Line Cleaned
133	Holiday Travel Park PS	06/26/10	06/26/10	4 hours	0.01	1.27	Rainfall	Inflow/infiltration. Station at rated capacity.
134	Riverside Drive PS	06/17/10	06/17/10	5 hours	0.01	1.32	May 2010 Flood	Flood damage to electrical. Shorted motor windings.
222	Barker Road	06/26/10	06/27/10	4.83 hours	0.593	1.27	May 2010 Flood	NES transformer offline due to flood damage.

Monthly Overflow Report

Date Range: June, 2010

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04307015	06/24/10	06/24/10	2 hours	0.00001	0.00	Grit/Debris	914 Anderson Ln. Line Cleaned
106	Vandiver PS	06/09/10	06/09/10	0.5 hours	0.002	0.45	May 2010 Flood	Flood damage to two pumps. One pump in service.
109	Dry Creek PS	06/02/10	06/02/10	0.5 hours	0.102	0.01	Power Related	Changes made to VFD running PS equipment.
112	Gibson Creek PS	06/26/10	06/26/10	0.08 hours	0.001	2.12	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: June, 2010

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	10310008	06/14/10	06/14/10	11 hours	0.00007	0.00	Line Break	53 Brookwood Ter. Line repaired.
217	Basswood Ave.	06/05/10	06/07/10	20.5 hours	0.001	0.00	Line Break	Contractor adjusted bypass pumping
217	Basswood Ave.	06/20/10	06/20/10	3.67 hours	0.078	0.00	Line Break	Bypass pump not working. Contractor turned pump back on.