

Monthly Overflow Report

Date Range: July, 2010

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	16204017	07/09/10	07/09/10	2.5 hours	0.00001	0.00	Grit/Debris	5023 Blue Hole Rd. Line Cleaned
000	11711063	07/09/10	07/09/10	4.5 hours	0.00001	0.00	Roots	1705 Graybar Ln. Line Cleaned
000	16216016	07/17/10	07/17/10	3 hours	0.00001	0.00	Grit/Debris	Sycamore Dr. Line Cleaned
000	10608013	07/21/10	07/21/10	7 hours	0.00003	0.00	Grit/Debris	347 Wilhagan Rd. Line Cleaned
000	10713069	07/23/10	07/23/10	1 hours	0.00001	0.00	Grit/Debris	309 Philfre Ct. Line Cleaned
130	Brown's Creek PS / Visco Dr.	07/13/10	07/13/10	6.33 hours	0.181	1.85	Rainfall	
134	Riverside Drive PS	07/26/10	07/26/10	3 hours	0.01		Power Related	NES Power outage. Evaluate addition of stationary generator.
222	Barker Road	07/13/10	07/13/10	14.83 hours	1.255	1.88	May 2010 Flood	EQ basin out of service. NES power restored 7/15/2010.

Monthly Overflow Report

Date Range: July, 2010

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04315003	07/03/10	07/03/10	3 hours	0.00001	0.00	Grit/Debris	102 Wychewood Cove. Line Cleaned
109	Dry Creek PS	07/26/10	07/26/10	2.58 hours	0.213	1.09	May 2010 Flood	Limited pumping capacity due to flood damage

Monthly Overflow Report

Date Range: July, 2010

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09004002	07/12/10	07/12/10	4 hours	0.001	0.00	Line Break	Backflow from bypass pumping at Reostone Quarry.