

# Monthly Overflow Report

Date Range: August, 2010

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	14808023	08/05/10	08/05/10	1 hours	0.00001	0.07	Grit/Debris	301 Waikiki. Line Cleaned
000	14703095	08/16/10	08/16/10	0.5 hours	0.00001	0.09	Grit/Debris	4112 Nolensville Rd. Line Cleaned
000	08606106	08/18/10	08/19/10	3 hours	0.00001	4.97	Rainfall	Old Hickory Blvd.
000	08602062	08/18/10	08/19/10	3 hours	0.00001	4.97	Rainfall	Old Lebanon Dirt Rd.
000	07203023	08/18/10	08/18/10	1 hours	0.00001	5.02	Grit/Debris	1005 McClurkin St. Line Cleaned
000	09510050	08/19/10	08/19/10	8 hours	0.1	4.97	Rainfall	501 Bismark Dr.
000	11909113	08/19/10	08/19/10	3 hours	0.00001	4.60	Rainfall	2803 Foster Ave.
000	11908037	08/23/10	08/23/10	5.5 hours	0.001	0.00	Grit/Debris	736 Currey Rd. Line Cleaned
000	13214030	08/27/10	08/27/10	1 hours	0.00001	0.00	Grit/Debris	852 Battery Ln. Line Cleaned
102	Smith Springs PS	08/18/10	08/19/10	24.75 hours	1.648	4.32	Rainfall	Inflow/infiltration. Station at rated capacity.
124	Williamson Ferry PS	08/19/10	08/20/10	23.5 hours	0.273	5.02	Rainfall	Inflow/infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	08/18/10	08/19/10	10.33 hours	0.259	4.60	Rainfall	Inflow/infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	08/25/10	08/26/10	7 hours	0.341	0.00	Mechanical	Hydraulic gates isolating bar rakes leaked partially closed.
133	Holiday Travel Park PS	08/19/10	08/19/10	22.25 hours	0.02	4.97	Rainfall	Inflow/infiltration. Station at rated capacity.
134	Riverside Drive PS	08/17/10	08/19/10	10.25 hours	0.02	4.66	Rainfall	Inflow/infiltration. Station at rated capacity.
151	Shelby Park PS	08/19/10	08/19/10	5.5 hours	0.08	5.02	Rainfall	Inflow/infiltration. Station at rated capacity.
176	Dodson Chapel PS	08/18/10	08/20/10	16.58 hours	0.51	4.97	Rainfall	Inflow/infiltration. Station at rated capacity.
189	Langford Farms PS	08/19/10	08/19/10	10.4 hours	0.02	6.98	Rainfall	Inflow/infiltration. Station at rated capacity.
222	Barker Road	08/18/10	08/21/10	34.25 hours	8.043	4.97	Rainfall	Inflow/infiltration. Station at rated capacity.
222	Barker Road	08/25/10	08/25/10	0.25 hours	0.001	0.00	Mechanical	Browns Creek isolation gates leaked partially closed.
226	Cowan St. Relief Bleeder	08/19/10	08/20/10	35.83 hours	0.883	5.02	Rainfall	Inflow/infiltration. Station at rated capacity.
330	Anderson Road	08/19/10	08/19/10	1 hours	0.00001	4.32	Rainfall	177 Timber Ridge Dr.

# Monthly Overflow Report

Date Range: August, 2010

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
106	Vandiver PS	08/19/10	08/19/10	9.42 hours	1.126	5.78	Rainfall	Inflow/infiltration. Station at rated capacity.
109	Dry Creek PS	08/18/10	08/19/10	15.59 hours	6.484	6.22	May 2010 Flood	
110	Loves Branch PS	08/19/10	08/19/10	8.33 hours	1.23	6.22	Rainfall	Inflow/infiltration. Station at rated capacity.
112	Gibson Creek PS	08/19/10	08/20/10	36.7 hours	3	6.98	Rainfall	Inflow/infiltration. Station at rated capacity.
116	Rainbow Terrace PS	08/19/10	08/19/10	5.9 hours	0.01	6.22	Rainfall	Inflow/infiltration. Station at rated capacity.
117	Neely's Bend PS	08/19/10	08/20/10	31.5 hours	0.1	6.22	Rainfall	Inflow/infiltration. Station at rated capacity.
127	Madison Heights PS	08/19/10	08/19/10	6.5 hours	0.01	6.22	Rainfall	Inflow/infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	08/19/10	08/19/10	9.4 hours	0.1	6.22	Rainfall	Inflow/infiltration. Station at rated capacity.

# Monthly Overflow Report

Date Range: August, 2010

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	11516004	08/06/10	08/06/10	3.5 hours	0.00001	0.79	Other/not listed	6201Jocelyn Hollow.Plug left in line by contractor.Removed plug
000	09004002	08/18/10	08/18/10	8 hours	0.002	4.31	Line Break	Backup from pumping @ Reostone Quarry. 6514 Robertson
000	13007001	08/19/10	08/19/10	1.5 hours	0.00001	2.85	Rainfall	803 Lynnwood Blvd.
000	05010033	08/19/10	08/19/10	2 hours	0.00002	5.93	Rainfall	Brick Church Pk.
000	05013010	08/19/10	08/19/10	5 hours	0.001	5.93	Rainfall	3300 Briley Pkwy.
104	Whites Creek PS	08/18/10	08/21/10	28.67 hours	1.279	4.66	Rainfall	Inflow/infiltration. Station at rated capacity.
217	Basswood Ave.	08/18/10	08/19/10	12 hours	0.661	4.31	Rainfall	Inflow/infiltration.