## Monthly Overflow Report

Date Range: September, 2010

Central WWTP NPDES# TN 0020575										
#	Overflow Name	Start Date	End Date	Duration	(mg)	Rainfall	Overflow Cause	Remarks		
Sanita	Sanitary Sewer Overflows									
000	17503012	09/03/10	09/03/10	1 hours	0.00001	0.00	Grit/Debris	12520 Old Hickory. Line Cleaned		
000	13316023	09/16/10	09/16/10	1.5 hours	0.00001	0.00	Grit/Debris	323 Tampa Dr. Line Cleaned		
001B	Central WWTP - Biosolids	09/10/10	09/10/10	1.25 hours	0.002	1.40	Other/not listed	Contractors opened a series of valves resulting in overflow.		

Wednesday, October 13, 2010

## Monthly Overflow Report

Date Range: September, 2010

Dry C	Dry Creek WWTP NPDES# TN0020648								
#	Overflow Name	Start Date	End Date	Duration	(mg)	Rainfall	Overflow Cause	Remarks	
Sanita	Sanitary Sewer Overflows								
000	04309080	09/08/10	09/08/10	1 hours	0.00001	0.00	Grit/Debris	314 Gallatin Rd. Line Cleaned	
108	River Retreat	09/10/10	09/10/10	1 hours	0.001	1.70	Power Related	NES power out. Stationary generator flood repairs underway.	

Wednesday, October 13, 2010

## Monthly Overflow Report

Date Range: September, 2010

White	s Creek WWTP NPDE	ES# TN 00249	970		Volume				
#	Overflow Name	Start Date	End Date	Duration	(mg)	Rainfall (	Overflow Cause	Remarks	
Sanita	Sanitary Sewer Overflows								
000	10316058	09/08/10	09/08/10	2.5 hours	0.00001	0.00	Other/not listed	101 Cherokee Rd. Quick-lock sealed off 8" line, relocated sewer.	
000	10316058	09/28/10	09/28/10	1.5 hours	0.00001	0.00	Other/not listed	101 Cherokee Rd. Quick-lock sealed off 8" line, relocated sewer.	
000	10316058	09/30/10	09/30/10	1.5 hours	0.00001	0.00	Other/not listed	101 Cherokee Rd. Quick-lock sealed off 8" line, relocated sewer.	

Wednesday, October 13, 2010