

# Monthly Overflow Report

Date Range: October, 2010

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	06111010	10/01/10	10/01/10	1 hours	0.00001	0.00	Grit/Debris	912 Matthews Ave. Line Cleaned
000	16111020	10/02/10	10/02/10	3.5 hours	0.00003	0.00	Grit/Debris	1000 Enclave Cir. Line Cleaned
000	16216066	10/04/10	10/04/10	1 hours	0.0001	0.00	Line Problem	Blue Hole Rd @ Crystal Brook. Contractor plug deflated.
000	17308004	10/05/10	10/05/10	5 hours	0.002	0.00	Line Problem	Pettus Rd @ Blue Hole Rd. Manhole failure.
000	WLS52K059	10/05/10	10/05/10	1.5 hours	0.001	0.00	Roots	676 South View Dr. Line Cleaned
000	14702067	10/10/10	10/10/10	4 hours	0.00002	0.00	Grit/Debris	4811 Abbay Dr. Line Cleaned
000	WLS52L159	10/17/10	10/17/10	1.45 hours	0.00001	0.00	Grit/Debris	319 Matterhorn Dr. Line Cleaned.
000	17404072	10/21/10	10/21/10	3.5 hours	0.00001	0.00	Grit/Debris	5401 Oak Chase Dr. Line Cleaned
000	09308057	10/22/10	10/22/10	1 hours	0.00001	0.00	Grit/Debris	515 Crutcher St. Line Cleaned
000	10709005	10/22/10	10/22/10	3 hours	0.00001	0.00	Grit/Debris	644 Glastonbury Rd. Line Cleaned
000	08610022	10/23/10	10/23/10	1 hours	0.00001	0.00	Grit/Debris	3501 Magnum Dr. Line Cleaned
000	14812012	10/23/10	10/23/10	11.5 hours	0.002	0.00	Grit/Debris	143 Waikiki Blvd. Line Cleaned
134	Riverside Drive PS	10/22/10	10/22/10	0.65 hours	0.0005	0.00	Controller	Bubbler system malfunctioned. Replaced complete system.

---

# Monthly Overflow Report

Date Range: October, 2010

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
132	Berwick Trail PS / Center St.	10/28/10	10/29/10	14.5 hours	0.2	0.00	Force Main	Broken 16" forcemain. Repair clamp placed on line.

---

# Monthly Overflow Report

Date Range: October, 2010

---

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	05815039	10/09/10	10/09/10	2.5 hours	0.0001	0.00	Grit/Debris	4213 Hallmark Rd. Line Cleaned
000	11604044	10/29/10	10/29/10	0.5 hours	0.00001	0.00	Grit/Debris	701 Crescent Rd. Line Cleaned