

# Monthly Overflow Report

Date Range: November, 2010

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	17301052	11/06/10	11/06/10	1.5 hours	0.0001	0.00	Grit/Debris	330 Cedar Creek. Line cleaned
000	09205080	11/07/10	11/07/2101	6.75 hours	0.0001	0.00	Grit/Debris	3312 Clifton. Line cleared
000	18104001	11/09/10	11/09/10	2.5 hours	0.001	0.00	Grit/Debris	6508 Broken Bow Dr. Line cleaned
000	07213001	11/13/10	11/13/10	0.25 hours	0.00001	0.03	Grit/Debris	1026 Carolyn Ave. Line cleaned
000	14711009	11/15/10	11/15/10	0.75 hours	0.001	0.01	Grit/Debris	517 Northcrest Ln. Line cleaned
000	10808074co	11/18/10	11/18/10	0.75 hours	0.0001	0.00	Roots	3316 A& B White Pine Dr. (cleanout) Line cleaned.
000	WMN030F041	11/19/10	11/19/10	0.5 hours	0.00001	0.00	Grit/Debris	501 N. Woods Ct. Line cleaned
000	14614022	11/22/10	11/22/10	0.5 hours	0.00001	0.00	Grit/Debris	5111 Franklin Rd. Line Cleaned
000	07507175	11/22/10	11/22/10	0.5 hours	0.0001	0.00	Roots	509 Dutchman Dr. Line Cleaned
000	17304060	11/25/10	11/25/10	1.83 hours	0.001	0.60	Line Break	Hickory Park Dr. Bypass pump discharge line failure.
000	07116039	11/28/10	11/28/10	0.5 hours	0.00001	0.00	Grit/Debris	917 Blue Ridge Dr. Line Cleaned
000	14905113	11/28/10	11/28/10	2 hours	0.00001	0.00	Grease	4904 Pebble Creek Dr. Line Cleaned
000	10505006	11/28/10	11/28/10	1 hours	0.00001	0.00	Grit/Debris	1405 12th Ave. South. Line cleaned
000	09306026co	11/29/10	11/29/10	1 hours	0.00001	0.41	Grit/Debris	127 3rd Ave. S. (cleanout) Line cleaned
000	07108082co	11/30/10	11/30/10	1.25 hours	0.00001	2.08	Grease	502 Norton Ave (cleanout) - line cleaned
000	09510050	11/30/10	11/30/10	14.5 hours	0.001	2.10	Rainfall	501 Bismark Dr. Rain
001b	Central WWTP - Biosolids	11/20/10	11/20/10	3 hours	0.065	0.00	Line Break	Broken PVC line. Recovered .113 MG.
133	Holiday Travel Park PS	11/30/10	11/30/10	2 hours	0.001	2.10	Rainfall	Inflow/infiltration. Station at rated capacity.
161	Longhunter Chase SPS	11/30/10	11/30/10	9 hours	0.01	2.56	Rainfall	Inflow/infiltration. Station at rated capacity.
222	Barker Road	11/30/10	12/01/10	15.67 hours	0.258	2.10	Rainfall	Equalization basin full.
226	Cowan St. Relief Bleeder	11/30/10	11/30/10	13.67 hours	0.405	2.08	Rainfall	Inflow/infiltration. Station at rated capacity.

# Monthly Overflow Report

Date Range: November, 2010

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	03316032co	11/30/10	11/30/10	0.75 hours	0.00001	1.50	Grease	1105 Nelson Dr. (cleanout) Line cleaned
106	Vandiver PS	11/30/10	11/30/10	10.08 hours	0.206	1.99	Rainfall	Inflow/infiltration. Station at rated capacity.
112	Gibson Creek PS	11/30/10	11/30/10	5.5 hours	1.143	1.98	Rainfall	Inflow/infiltration. Station at rated capacity.
117	Neely's Bend PS	11/30/10	11/30/10	7.2 hours	0.05	1.98	Rainfall	Inflow/infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	11/30/10	11/30/10	12.25 hours	0.1	1.98	Rainfall	Inflow/infiltration. Station at rated capacity.

# Monthly Overflow Report

Date Range: November, 2010

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	13101096	11/26/10	11/26/10	1.2 hours	0.0001	0.67	Grit/Debris	102 Chatsworth Dr. Line Cleaned
104	Whites Creek PS	11/30/10	12/01/10	34.34 hours	5.499	1.89	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	11/30/10	11/30/10	14.83 hours	0.563	2.04	Rainfall	Inflow/infiltration. Station at rated capacity.
217	Basswood Ave.	11/03/10	11/03/10	1.08 hours	0.011	0.35	Line Break	Bypass pump controls inaccurately set. Adjusted float levels.
217	Basswood Ave.	11/23/10	11/23/10	5.75 hours	0.112	1.31	Rainfall	516 Basswood Dr. Rain
217	Basswood Ave.	11/25/10	11/27/10	2.25 hours	0.05	0.69	Rainfall	
217	Basswood Ave.	11/30/10	11/30/10	22.67 hours	2.57	2.04	Rainfall	