

# Monthly Overflow Report

Date Range: December, 2010

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	18105008	12/01/10	12/01/10	4 hours	0.001		Grease	6448 Nolensville Pk. Line Cleaned
000	09208067	12/01/10	12/01/10	0.5 hours	0.0001		Grit/Debris	319 15th Ave. N. Line Cleaned
000	08103009	12/02/10	12/02/10	8 hours	0.001		Grease	1805 Hughes St. Line Cleaned
000	08115088	12/09/10	12/09/10	1 hours	0.0001		Grit/Debris	1412 22nd Ave. N. Line Cleaned
000	09206008	12/12/10	12/12/10	0.5 hours	0.00001		Grit/Debris	3013 Clare Ave. Line Cleaned
000	09308057	12/14/10	12/14/10	0.45 hours	0.0001		Grit/Debris	508 Crutcher St. Line Cleaned
000	WLS74M025	12/16/10	12/16/10	0.5 hours	0.001	0.57	Grit/Debris	203 Cobblestone Landing Line Cleaned
000	13312096	12/20/10	12/20/10	1.5 hours	0.001		Grit/Debris	3861 Scotwood Ave. Line Cleaned
000	WLS52N227	12/21/10	12/21/10	1 hours	0.001		Grit/Debris	511 Pin Oak Dr. Line Cleaned
000	08601029	12/21/10	12/21/10	3 hours	0.001		Grit/Debris	1412 Central Ct. (called in by 112 Thistle Ln.) Line Cleaned
000	16211019	12/23/10	12/23/10	1 hours	0.001		Grit/Debris	1451 Bell Rd. Line Cleaned
000	13413008	12/23/10	12/23/10	0.75 hours	0.001		Grit/Debris	95 Wallace Rd. Line Cleaned
000	10414041	12/24/10	12/24/10	2.5 hours	0.00001		Grit/Debris	2607 Natchez Trace Line Cleaned
000	05413024	12/30/10	12/30/10	3 hours	0.00001		Grit/Debris	100 Fields Dr. Line Cleaned
000	07512235	12/31/10	12/31/10	1.5 hours	0.00001		Grit/Debris	759 Tulip Grove Rd. Line Cleaned
103	McCrary Creek PS	12/14/10	12/14/10	0.92 hours	0.19		Power Related	NES Power failure. Damaged ATS from May Flood under repair.
176	Dodson Chapel PS	12/01/10	12/01/10	0.83 hours	0.013	2.10	Rainfall	2.1" of rain on 11/29 and 30. EQ full. PS at rated capacity.

# Monthly Overflow Report

Date Range: December, 2010

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	14307002	12/02/10	12/02/10	3 hours	0.001		Grit/Debris	100 Harpeth Trace Dr. Line Cleaned
000	06003042	12/08/10	12/08/10	2.5 hours	0.0001		Grit/Debris	3301 Creekwood Dr. Line Cleaned
000	10203126	12/17/10	12/17/10	3 hours	0.0001		Grit/Debris	5628 Meadowcrest Ln. Line Cleaned
000	04901019	12/20/10	12/20/10	2 hours	0.00001		Grit/Debris	723 Willow Trace Dr. Line Cleaned
104	Whites Creek PS	12/12/10	12/12/10	13 hours	0.499	1.07	Rainfall	Inflow/infiltration. Station at rated capacity.
217	Basswood Ave.	12/11/10	12/13/10	22.5 hours	1.317	1.21	Rainfall	516 Basswood Ave.
217	Basswood Ave.	12/16/10	12/17/10	3 hours	0.138	0.34	Line Problem	516 Basswood Ave. Contractor adjusted temporary pump settings.