

Sept 2011

**CENTRAL WASTEWATER TREATMENT PLANT
CSO - 018 - 1st & VAN BUREN**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1						
2						
3					1	
4					1	
5					1	
6					1	
7						
8						
9					1	
10					1	
11						
12						
13						
14					1	
15					1	
16						Discharge pipe to the river was plugged 9-28-11 CSO has been eliminated.
17						
18						
19					1	
20					1	
21					1	
22					1	
23					1	
24					1	
25						
26					1	
27					1	
28					1	
29					1	
30						

TOTAL	0.000	0	0.00	0.00	18
AVG	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	1
MAX	0.000	0	0.00	0.00	1
MIN	0.000	0	0.00	0.00	1
COUNT	0	0	0	0	18

DISCHARGE MONITORING REPORT (DMR)

NAME NASHVILLE-CENTRAL STP
 ADDRESS 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206

TN0020575
 PERMIT NUMBER

018 G
 DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206

MAJOR \$
 (SUBR 04)
 VAN BUREN AT MI 189.5 CSO
 External Outfall

FACILITY NASHVILLE-CENTRAL STP
 LOCATION 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206
 ATTN: MR. SCOTT POTTER

MONITORING PERIOD
 MM/DD/YYYY MM/DD/YYYY
 FROM 09/01/2011 TO 09/30/2011

NO DISCHARGE [x]

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	0.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	0.00	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	#DIV/0!	0.000		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	18.00			*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL		occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	0.00	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
SCOTT A. POTTER DIRECTOR		615 862-4591	10/10/2011
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			

Sept 2011

**CENTRAL WASTEWATER TREATMENT PLANT
CSO - 019 - KERRIGAN**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1						
2						
3					1	
4					1	
5					1	
6					1	
7						
8						
9						
10					1	
11						
12						
13						
14					1	
15					1	
16						
17						
18						
19					1	
20					1	
21					1	
22					1	
23	0.054	1	0.46	4.00		Rain, Overflow Duration = 0.57 hours
24						
25						
26	0.154	1	0.87	7.00		Rain, Overflow Duration = 1.73 hours
27						
28					1	
29					1	
30						

TOTAL	0.208	2	1.33	11.00	13	
AVG	0.104	1	0.67	5.50	1	
MAX	0.154	1	0.87	7.00	1	
MIN	0.054	1	0.46	4.00	1	
COUNT	2	2	2	2	13	

DISCHARGE MONITORING REPORT (DMR)

DMR Mailing ZIP CODE: 372082206

NAME NASHVILLE-CENTRAL STP
 ADDRESS 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206

TN0020575
 PERMIT NUMBER

019 G
 DISCHARGE NUMBER

MAJOR \$
 (SUBR 04) EJM
 KERRIGAN AT MI 190.4 CSO
 External Outfall

FACILITY NASHVILLE-CENTRAL STP
 LOCATION 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206
 ATTN: MR. SCOTT POTTER

MONITORING PERIOD
 MM/DD/YYYY TO MM/DD/YYYY
 FROM 09/01/2011 TO 09/30/2011

NO DISCHARGE []

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	11.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	1.33	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	0.104	0.154		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	13.00	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	2.00	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER SCOTT A. POTTER DIRECTOR	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
		615 862-4591	10/10/2011
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			

Sept 2011

**CENTRAL WASTEWATER TREATMENT PLANT
CSO - 020 - 1st & BROADWAY**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						Discharge pipe to the river was plugged 9-15-11
16						CSO has been eliminated.
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

TOTAL	0.000	0	0.00	0.00	0
AVG	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
MAX	0.000	0	0.00	0.00	0
MIN	0.000	0	0.00	0.00	0
COUNT	0	0	0	0	0

DISCHARGE MONITORING REPORT (DMR)

DMR Mailing ZIP CODE: 372082206

NAME NASHVILLE-CENTRAL STP
 ADDRESS 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206

TN0020575
 PERMIT NUMBER

020 G
 DISCHARGE NUMBER

MAJOR \$
 (SUBR 04)
 1ST & BROADWAY MI 191.0 CSO
 External Outfall

FACILITY NASHVILLE-CENTRAL STP
 LOCATION 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206
 ATTN: MR. SCOTT POTTER

MONITORING PERIOD

FROM 09/01/2011 TO 09/30/2011

NO DISCHARGE []

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	0.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	0.00	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	#DIV/0!	0.000		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	0.00	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	0.00	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
SCOTT A. POTTER DIRECTOR		615 862-4591	10/10/2011
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			

Sept 2011

**CENTRAL WASTEWATER TREATMENT PLANT
CSO - 023 - BENEDICT & CRUTCHER**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1						
2						
3					1	
4	0.005	1	0.76	11.00		Rain, Overflow Duration = 0.17 hours
5	2.690		2.06	21.00		Rain, Overflow Duration = 5.75 hours
6	0.211		1.19	19.00		Rain, Overflow Duration = 3.67 hours
7						
8						
9					1	
10	0.069	1	0.21	1.00		Rain, Overflow Duration = 0.92 hours
11						
12						
13						
14			0.32	4.00		
15	0.003	1	0.18	5.00		Rain, Overflow Duration = 0.25 hours
16						
17						
18						
19	0.001	1	0.21	4.00		Rain, Overflow Duration = 0.25 hours
20	0.001		0.24	6.00		Rain, Overflow Duration = 0.17 hours
21					1	
22	0.001	1	0.01	1.00		Rain, Overflow Duration = 0.17 hours
23	0.023		0.36	4.00		Rain, Overflow Duration = 0.50 hours
24					1	
25						
26	0.335	1	0.81	7.00		Rain, Overflow Duration = 1.42 hours
27					1	
28					1	
29					1	
30						

TOTAL	3.339	6	6.35	83.00	7	
AVG	0.334	1	0.58	7.55	1	
MAX	2.690	1	2.06	21.00	1	
MIN	0.001	1	0.01	1.00	1	
COUNT	10	6	11	11	7	

DISCHARGE MONITORING REPORT (DMR)

NAME NASHVILLE-CENTRAL STP
 ADDRESS 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206

TN0020575
 PERMIT NUMBER

023 G
 DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206

MAJOR \$
 (SUBR 04)
 BENEDICT & CRUTCHER 191.6 CSO
 External Outfall

FACILITY NASHVILLE-CENTRAL STP
 LOCATION 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206

MONITORING PERIOD
 FROM 09/01/2011 TO 09/30/2011

NO DISCHARGE []

ATTN: MR. SCOTT POTTER

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	83.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	6.35	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	0.334	2.690		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	7.00	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	6.00	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER SCOTT A. POTTER DIRECTOR	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
		615 862-4591	10/10/2011
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			MM/DD/YYYY

Sept 2011

**CENTRAL WASTEWATER TREATMENT PLANT
CSO - 024 - WASHINGTON DC**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1						
2						
3	0.400	1	0.30	2.00		Rain, Overflow Duration = 0.25 hours
4	0.702		0.61	11.00		Rain, Overflow Duration = 3.92 hours
5	25.467		2.11	21.00		Rain, Overflow Duration = 23.42 hours
6	22.898		1.19	19.00		Rain, Overflow Duration = 24 hours
7	3.991					Previous Rain, Overflow Duration = 13.42 hours
8						
9						
10	0.244	1	0.11	1.00		Rain, Overflow Duration = 0.83 hours
11	0.004		0.01	1.00		Rain, Overflow Duration = 0.25 hours
12						
13						
14	0.579	1	0.31	3.00		Rain, Overflow Duration = 2.33 hours
15	0.878		0.26	4.00		Rain, Overflow Duration = 23.92 hours
16	0.010					Previous Rain, Overflow Duration = 3.58 hours
17						
18						
19	0.042	1	0.26	7.00		Rain, Overflow Duration = 0.58 hours
20	0.003		0.23	7.00		Rain, Overflow Duration = 0.42 hours
21	0.050		0.13	1.00		Rain, Overflow Duration = 1.33 hours
22					1	
23	1.048	1	0.40	4.00		Rain, Overflow Duration = 5.25 hours
24						
25						
26	12.796	1	1.25	7.00		Rain, Overflow Duration = 5.83 hours
27						
28						
29						
30						

TOTAL	69.112	6	7.17	88.00	1	
AVG	4.607	1	0.55	6.77	1	
MAX	25.467	1	2.11	21.00	1	
MIN	0.003	1	0.01	1.00	1	
COUNT	15	6	13	13	1	

DISCHARGE MONITORING REPORT (DMR)

DMR Mailing ZIP CODE: 372082206

NAME NASHVILLE-CENTRAL STP
 ADDRESS 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206

TN0020575	024G
PERMIT NUMBER	DISCHARGE NUMBER

MAJOR \$
 (SUBR 04) EMH
 WASHINGTON MI 190.4 CSO
 External Outfall

FACILITY NASHVILLE-CENTRAL STP
 LOCATION 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206
 ATTN: MR. SCOTT POTTER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
FROM 09/01/2011	TO 09/30/2011

NO DISCHARGE []

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	88.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	7.17	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	4.607	25.467		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	1	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	6	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
SCOTT A. POTTER DIRECTOR		615 862-4591	10/10/2011
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			

Sept 2011

**CENTRAL WASTEWATER TREATMENT PLANT
CSO - 033 - SCHRADER LANE**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1						
2						
3			0.08	1.00		
4			0.60	12.00		
5			1.89	21.00		
6	0.009	1	0.94	20.00		Rain, Overflow Duration = 0.92 hours
7						
8						
9						
10	0.004	1	0.20	2.00		Rain, Overflow Duration = 0.67 hours
11			0.01	1.00		
12						
13						
14					1	
15					1	
16						
17						
18						
19					1	
20					1	
21					1	
22						
23	0.001	1	0.46	4.00		Rain, Overflow Duration = 0.17 hours
24						
25						
26	0.522	1	0.52	7.00		Rain, Overflow Duration = 1.25 hours
27						
28						
29					1	
30						

TOTAL	0.536	4	4.70	68.00	6
AVG	0.134	1	0.59	8.50	1
MAX	0.522	1	1.89	21.00	1
MIN	0.001	1	0.01	1.00	1
COUNT	4	4	8	8	6

DISCHARGE MONITORING REPORT (DMR)

NAME NASHVILLE-CENTRAL STP
 ADDRESS 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206

TN0020575
 PERMIT NUMBER

033 G
 DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206

MAJOR \$
 (SUBR 04) EMH
 SCHRADER LN MI 184.7 CSO
 External Outfall

FACILITY NASHVILLE-CENTRAL STP
 LOCATION 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206
 ATTN: MR. SCOTT POTTER

MONITORING PERIOD

MM/DD/YYYY TO MM/DD/YYYY
 FROM 09/01/2011 TO 09/30/2011

NO DISCHARGE []

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	68.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	4.70	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	0.134	0.522		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	6	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	4	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
SCOTT A. POTTER DIRECTOR		615 862-4591	10/10/2011
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			

Sept 2011

**CENTRAL WASTEWATER TREATMENT PLANT
CSO - 035 - DRIFTWOOD**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1						
2						
3					1	
4					1	
5					1	
6					1	
7						
8						
9						
10					1	
11						
12						
13						
14					1	
15					1	
16						NO DISCHARGE FOR THIS SITE FOR THIS MONTH
17						
18						
19					1	
20					1	
21					1	
22					1	
23					1	
24						
25						
26					1	
27						
28					1	
29					1	
30						

TOTAL	0.000	0	0.00	0.00	15
AVG	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	1
MAX	0.000	0	0.00	0.00	1
MIN	0.000	0	0.00	0.00	1
COUNT	0	0	0	0	15

DISCHARGE MONITORING REPORT (DMR)

NAME NASHVILLE-CENTRAL STP
 ADDRESS 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206

TN0020575
 PERMIT NUMBER

035 G
 DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206

MAJOR \$
 (SUBR 04)
 DRIFTWOOD MI 192.0 CSO
 External Outfall

FACILITY NASHVILLE-CENTRAL STP
 LOCATION 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206
 ATTN: MR. SCOTT POTTER

MONITORING PERIOD
 MM/DD/YYYY TO MM/DD/YYYY
 FROM 09/01/2011 TO 09/30/2011

NO DISCHARGE [x]

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	0.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	0.00	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	#DIV/0!	0.000		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	15	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	0	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER SCOTT A. POTTER DIRECTOR	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
		615 862-4591	10/10/2011
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE NUMBER MM/DD/YYYY
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			

Sept 2011

**CENTRAL WASTEWATER TREATMENT PLANT
CSO - 047 - BOSCOBEL**

DATE	Effluent Flow MGD	Number of Discharges from Outfall	Rainfall causing a Discharge Inches	Rain Duration causing a Discharge Hours	Number of Rain Events Not causing a Discharge	Reason for Bypassing
1						
2						
3	0.028	1	0.30	2.00		Rain, Overflow Duration = 0.25 hours
4	0.022		0.61	11.00		Rain, Overflow Duration = 0.17 hours
5			2.11	21.00		
6	0.012		1.19	19.00		Rain, Overflow Duration = 0.50 hours
7						
8						
9						
10	0.001	1	0.11	1.00		Rain, Overflow Duration = 0.08 hours
11			0.01	1.00		
12						
13						
14					1	
15					1	
16						
17						
18						
19					1	
20					1	
21					1	
22						
23	0.014	1	0.40	4.00		Rain, Overflow Duration = 0.17 hours
24						
25						
26					1	
27						
28						
29						
30						

TOTAL	0.077	3	4.73	59.00	6	
AVG	0.015	1	0.68	8.43	1	
MAX	0.028	1	2.11	21.00	1	
MIN	0.001	1	0.01	1.00	1	
COUNT	5	3	7	7	6	

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Form Approved

OMB NO. 2040-0004

DISCHARGE MONITORING REPORT (DMR)

NAME NASHVILLE-CENTRAL STP
 ADDRESS 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206

TN0020575
 PERMIT NUMBER

047 G
 DISCHARGE NUMBER

DMR Mailing ZIP CODE: 372082206

MAJOR \$
 (SUBR 04)
 BOSCOBEL MI 192.6 CSO
 External Outfall

FACILITY NASHVILLE-CENTRAL STP
 LOCATION 1600 2ND AVENUE NORTH
 NASHVILLE TN 372082206

MONITORING PERIOD
 MM/DD/YYYY TO MM/DD/YYYY
 FROM 09/01/2011 TO 09/30/2011

NO DISCHARGE []

ATTN: MR. SCOTT POTTER

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Rainfall duration	SAMPLE MEASUREMENT	59.00	*****		*****	*****	*****	****			
00135 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	hr	*****	*****	*****	****		Daily When Discharging	CALCTD
Rainfall	SAMPLE MEASUREMENT	4.73	*****		*****	*****	*****	****			
46529 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	in	*****	*****	*****	****		Daily When Discharging	CALCTD
Flow, in conduit	SAMPLE MEASUREMENT	0.015	0.028		*****	*****	*****	****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	****		Daily When Discharging	CONTIN
Rainfall events with no discharge	SAMPLE MEASUREMENT	6	*****		*****	*****	*****	****			
51407 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	occur/mo	*****	*****	*****	****		Daily When Discharging	CALCTD
Discharge event observation	SAMPLE MEASUREMENT	3	*****		*****	*****	*****	****			
84165 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO TOTAL	*****	Y=1;N=0	*****	*****	*****	****		Daily When Discharging	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
SCOTT A. POTTER DIRECTOR			615 862-4591	10/10/2011
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE NUMBER
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)				