

Monthly Overflow Report

Date Range: January, 2011

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07107044	01/01/11	01/01/11	3 hours	0.0001	0.63	Grit/Debris	1907 Dickerson Pk. Line Cleaned
000	WMN056J050	01/03/11	01/03/11	0.5 hours	0.0001		Grit/Debris	1946 Ashburn Ct. Line Cleaned
000	07102052	01/04/11	01/04/11	7 hours	0.0001		Grit/Debris	201 Grizzard Ave. Line Cleaned
000	08303022	01/07/11	01/07/11	0.25 hours	0.0001		Grit/Debris	1201 Porter Rd. Line Cleaned
000	13515049	01/07/11	01/07/11	3.5 hours	0.001		Grit/Debris	2330 Murfreesboro Pk. Line Cleaned
000	13611005	01/12/11	01/12/11	3.5 hours	0.00001		Grease	3644 Anderson Rd. Line Cleaned
000	07104068	01/13/11	01/13/11	4 hours	0.00001		Grit/Debris	2520 Flamingo Dr. Line Cleaned
000	10807019	01/13/11	01/13/11	0.75 hours	0.0001		Grit/Debris	3108 Elm Hill Pk. Line Cleaned
000	16206084	01/13/11	01/13/11	0.5 hours	0.0001		Line Break	165 Tusculum Rd. Line Repaired
000	17308003	01/14/11	01/14/11	5.5 hours	0.0001	0.15	Line Problem	5618 Pettus Rd. Contractor's plug lost pressure
000	08204021	01/17/11	01/17/11	0.25 hours	0.00001	0.04	Grit/Debris	998 McFerrin Ave. Line Cleaned
000	01215005	01/17/11	01/17/11	0.75 hours	0.001	0.01	Grit/Debris	100 Northfork Ln. Line Cleaned
000	10404032	01/19/11	01/19/11	1 hours	0.00001		Grit/Debris	1105 17th Ave. S. Line Cleaned
000	07515141	01/25/11	01/25/11	2 hours	0.001	0.49	Grit/Debris	825 Netherlands Dr. Line Cleaned

Monthly Overflow Report

Date Range: January, 2011

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05104001	01/27/11	01/27/11	7 hours	0.00001		Roots	223 Madison St. Line Cleaned

Monthly Overflow Report

Date Range: January, 2011

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05010088	01/18/11	01/18/11	2 hours	0.0001	0.58	Roots	3307 Brick Church Pk. Line Cleaned
000	05915005co	01/18/11	01/18/11	2.5 hours	0.00001	0.59	Grit/Debris	723 Ringgold Dr. (cleanout) Line Cleaned
000	06008012	01/18/11	01/19/11	1.5 hours	0.0001	0.59	Grit/Debris	228 Broadmoor Dr. Line Cleaned
000	10203046	01/18/11	01/18/11	25 hours	0.001	0.43	Roots	637 Galaxy Dr. Line Cleaned
217	Basswood Ave.	01/01/11	01/01/11	3.75 hours	0.118	0.76	Rainfall	516 Basswood Dr.
217	Basswood Ave.	01/04/11	01/05/11	30.33 hours	1.775	0.03	Line Problem	516 Basswood Dr. Contractor relocating bypass pump
217	Basswood Ave.	01/18/11	01/18/11	1.58 hours	0.011	0.43	Rainfall	516 Basswood Dr.