

Monthly Overflow Report

Date Range: February, 2011

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	08610110	02/01/11	02/01/11	1 hours	0.001		Grit/Debris	3300 Lakeside Place - Line Cleaned
000	16107039	02/05/11	02/05/11	2.5 hours	0.001	0.04	Grit/Debris	483 Huntington Ridge - Line Cleaned - holding pond
000	09515040	02/08/11	02/08/11	1.8 hours	0.0001		Roots	26 Century Blvd. Line Cleaned
000	07408061	02/13/11	02/13/11	0.3 hours	0.00001		Grit/Debris	335 Bonnavue Dr. Line Cleaned
000	17212115	02/18/11	02/18/11	0.5 hours	0.00001	0.05	Grease	509 Bradford Hills Pl. Line Cleaned
000	08212033C	02/21/11	02/21/11	1.5 hours	0.001	0.35	Grit/Debris	314 N. 9th St. At Clean out - Line Cleaned
000	11902063	02/22/11	02/22/11	0.5 hours	0.00001		Grit/Debris	98 Peachtree St. Line Cleaned
000	07408032C	02/22/11	02/22/11	1.5 hours	0.0001		Roots	7022 Bonnavent- out of washer hose-Line Cleaned
000	08602062	02/25/11	02/26/11	24 hours	0.001	2.22	Rainfall	Old Lebanon Dirt Rd.
000	08606106	02/25/11	02/26/11	24.5 hours	0.001	2.22	Rainfall	5301 Old Hickory Blvd.
000	09510050	02/25/11	02/25/11	13 hours	0.001	2.22	Rainfall	501 Bismark Dr.
000	16413006	02/25/11	02/26/11	1.75 hours	0.001		Grit/Debris	5424 Cedar Ash Crossing
000	07416003C	02/26/11	02/26/11	1 hours	0.0001		Roots	5007 Bonnaside Drive - Inside of house- removed blockage
000	08204007	02/28/11	03/01/11	8 hours	0.001	2.39	Rainfall	Apex Ave. - drains to Washington CSS Basin
000	09611116	02/28/11	03/01/11	18 hours	0.0001	1.76	Rainfall	3218 Cloverwood Dr.
000	17308004	02/28/11	02/28/11	6.75 hours	0.001	1.10	Rainfall	Pettus Road at Blue Hole Rd.
000	09510050	02/28/11	03/01/11	14 hours	0.001	1.76	Rainfall	501 Bismark Dr.
000	08208025	02/28/11	02/28/11	0.75 hours	0.001	2.39	Rainfall	727 Myrtle Ave.
000	71140071	02/28/11	03/01/11	31 hours	0.001	2.03	Rainfall	1300 Vashti
000	07309066	02/28/11	03/01/11	14 hours	0.001	2.39	Rainfall	2301 Cooper Ln.
000	08115021	02/28/11	02/28/11	1 hours	0.0001	2.03	Roots	245 Riverside Dr
000	06108059C	02/28/11	02/28/11	7 hours	0.0001	2.39	Rainfall	1501 Winding Way - seep out clean out
000	08111055	02/28/11	02/28/11	0.75 hours	0.00001	2.14	Grit/Debris	1714 Dr. D. B. Todd Blvd.- Cleaned line
000	08204006	02/28/11	03/01/11	8 hours	0.001	2.39	Rainfall	McFerrin Ave. - drains to Washington CSS basin
103	McCrary Creek PS	02/11/11	02/11/11	0.5 hours	0.1		Force Main	FM break - 585 Stewarts Ferry Pk. Force main valved off
124	Williamson Ferry PS	02/25/11	02/25/11	2.42 hours	0.069	2.57	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: February, 2011

124	Williamson Ferry PS	02/28/11	02/28/11	5.67 hours	0.403	2.39	Rainfall	Inflow/infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	02/25/11	02/25/11	0.17 hours	0.004	2.17	Rainfall	Inflow/infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	02/28/11	02/28/11	0.5 hours	0.001	1.54	Rainfall	Inflow/infiltration. Station at rated capacity.
133	Holiday Travel Park PS	02/24/11	02/25/11	27.95 hours	0.3	2.22	Rainfall	Inflow/infiltration. Station at rated capacity.
133	Holiday Travel Park PS	02/28/11	03/01/11	13.85 hours	0.1	1.79	Rainfall	Inflow/infiltration. Station at rated capacity.
134	Riverside Drive PS	02/24/11	02/25/11	14.4 hours	0.1	2.52	Rainfall	Inflow/infiltration. Station at rated capacity.
134	Riverside Drive PS	02/28/11	02/28/11	9.75 hours	0.06	2.78	Rainfall	Inflow/infiltration. Station at rated capacity.
140	28th Avenue PS / Centennial	02/24/11	02/25/11	2.67 hours	0.024	2.52	Rainfall	Inflow/infiltration. Station at rated capacity.
140	28th Avenue PS / Centennial	02/28/11	02/28/11	8.83 hours	2.743	2.69	Rainfall	Inflow/infiltration. Station at rated capacity.
151	Shelby Park PS	02/24/11	02/25/11	2.5 hours	0.215	2.57	Rainfall	Inflow/infiltration. Station at rated capacity.
151	Shelby Park PS	02/28/11	02/28/11	12.42 hours	2.587	2.39	Rainfall	Inflow/infiltration. Station at rated capacity.
158	Farmingham Woods PS	02/25/11	02/25/11	4.6 hours	0.01	2.22	Rainfall	Inflow/infiltration. Station at rated capacity.
158	Farmingham Woods PS	02/28/11	02/28/11	7.6 hours	0.01	1.79	Rainfall	Inflow/infiltration. Station at rated capacity.
176	Dodson Chapel PS	02/24/11	02/24/11	2.83 hours	0.031	2.21	Rainfall	Inflow/infiltration. Station at rated capacity.
176	Dodson Chapel PS	02/28/11	03/01/11	13.33 hours	0.093	1.75	Rainfall	Inflow/infiltration. Station at rated capacity.
189	Langford Farms PS	02/24/11	02/25/11	18.2 hours	0.1	2.64	Rainfall	Inflow/infiltration. Station at rated capacity.
189	Langford Farms PS	02/28/11	02/28/11	11.1 hours	0.1	2.18	Rainfall	Inflow/infiltration. Station at rated capacity.
222	Barker Road	02/24/11	02/26/11	30.67 hours	0.872	2.21	Rainfall	
222	Barker Road	02/28/11	03/02/11	32.09 hours	1.973	1.75	Rainfall	
226	Cowan St. Relief Bleeder	02/01/11	02/01/11	2.92 hours	0.018	1.01	Rainfall	
226	Cowan St. Relief Bleeder	02/24/11	02/25/11	31.92 hours	2.781	2.57	Rainfall	
226	Cowan St. Relief Bleeder	02/28/11	03/01/11	18.59 hours	1.976	2.39	Rainfall	

Monthly Overflow Report

Date Range: February, 2011

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
106	Vandiver PS	02/24/11	02/25/11	22.67 hours	1.071	2.34	Rainfall	Inflow/infiltration. Station at rated capacity.
106	Vandiver PS	02/28/11	02/28/11	12.67 hours	1.173	1.97	Rainfall	Inflow/infiltration. Station at rated capacity.
109	Dry Creek PS	02/24/11	02/26/11	37.92 hours	8.168	2.46	Rainfall	Inflow/infiltration.
109	Dry Creek PS	02/28/11	03/03/11	66.09 hours	6.978	1.91	Rainfall	Inflow/infiltration.
110	Loves Branch PS	02/24/11	02/25/11	11.41 hours	0.335	2.46	Rainfall	Inflow/infiltration. Station at rated capacity.
110	Loves Branch PS	02/28/11	02/28/11	10.75 hours	1.103	1.91	Rainfall	Inflow/infiltration. Station at rated capacity.
112	Gibson Creek PS	02/24/11	02/25/11	13.92 hours	2.141	2.46	Rainfall	Inflow/infiltration. Station at rated capacity.
112	Gibson Creek PS	02/28/11	02/28/11	9.83 hours	2.402	1.91	Rainfall	Inflow/infiltration. Station at rated capacity.
117	Neely's Bend PS	02/24/11	02/25/11	20 hours	0.4	2.46	Rainfall	Inflow/infiltration. Station at rated capacity.
117	Neely's Bend PS	02/28/11	03/01/11	32.2 hours	0.6	1.95	Rainfall	Inflow/infiltration. Station at rated capacity.
127	Madison Heights PS	02/24/11	02/25/11	8.9 hours	0.05	2.46	Rainfall	Inflow/infiltration. Station at rated capacity.
127	Madison Heights PS	02/28/11	02/28/11	6.45 hours	0.03	1.95	Rainfall	Inflow/infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	02/24/11	02/25/11	16.45 hours	0.2	2.46	Rainfall	Inflow/infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	02/28/11	02/28/11	7.25 hours	0.08	1.95	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: February, 2011

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	06013002	02/14/11	02/14/11	1 hours	0.0001		Grit/Debris	2141 Old Matthews Rd. Line Cleaned
000	05013010	02/24/11	02/25/11	18 hours	0.001	2.57	Rainfall	Briley Parkway
000	06001013	02/24/11	02/25/11	23 hours	0.001	2.57	Rainfall	3258 Brick Church Pk.
000	05010029	02/24/11	02/25/11	26 hours	0.001	2.57	Rainfall	Brick Church Pk.
000	06001011	02/24/11	02/25/11	20 hours	0.001	2.57	Rainfall	Brick Church Pk-Richmond Hill
000	11507055	02/25/11	02/25/11	1 hours	0.00001	2.59	Rainfall	612 Davidson
000	05910048	02/25/11	02/26/11	24 hours	0.001	2.57	Rainfall	3800 Dunbar
000	09012056A	02/28/11	02/28/11	1.5 hours	0.0001	1.91	Rainfall	6303 Henry Ford Dr.
000	05013010	02/28/11	03/01/11	23 hours	0.001	2.39	Rainfall	3300 Brick Church Pk
000	10306040	02/28/11	02/28/11	1 hours	0.0001	1.91	Rainfall	5605 Stoneway Tr.
000	14405017	02/28/11	02/28/11	1.5 hours	0.001	1.08	Rainfall	1318 Chickering
000	13010031	02/28/11	03/04/11	Unknown	0.001	1.08	Rainfall	1202 Chickering
000	05010029	02/28/11	03/01/11	24.75 hours	0.001	2.39	Rainfall	Brick Church Pk
000	13005007	02/28/11	03/01/11	21 hours	0.001	1.61	Rainfall	4302 Harding Pl.
000	11507055	02/28/11	03/01/11	1 hours	0.001	1.91	Rainfall	612 Davidson
000	06001011	02/28/11	03/01/11	23 hours	0.001	2.39	Rainfall	Brick Church Pk- Richmond Hill
000	10314008	02/28/11	02/28/11	1 hours	0.001	1.91	Rainfall	47 Brookwood Terrace
000	06001013	02/28/11	03/01/11	23 hours	0.001	2.39	Rainfall	3258 Brick Church Pk
101	Bordeaux Hospital PS	02/28/11	02/28/11	4.25 hours	0.02	2.78	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	02/01/11	02/02/11	26.91 hours	3.138	0.99	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	02/24/11	02/27/11	72.17 hours	7.51	2.61	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	02/28/11	03/02/11	50.42 hours	2.245	2.69	Rainfall	Inflow/infiltration. Station at rated capacity.
107	West Park PS	02/24/11	02/25/11	4.42 hours	1.82	2.59	Rainfall	Inflow/infiltration. Station at rated capacity.
107	West Park PS	02/28/11	02/28/11	6.25 hours	2.335	1.91	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	02/01/11	02/02/11	6.08 hours	0.32	1.08	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	02/24/11	02/25/11	23.25 hours	1.812	2.59	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: February, 2011

114	Davidson Branch PS	02/28/11	02/28/11	11.33 hours	0.901	1.91	Rainfall	Inflow/infiltration. Station at rated capacity.
126	Cleeces Ferry PS	02/28/11	02/28/11	3.25 hours	0.05	1.96	Rainfall	Inflow/infiltration. Station at rated capacity.
136	River Drive PS	02/25/11	02/25/11	2.75 hours	0.016	2.52	Rainfall	Inflow/infiltration. Station at rated capacity.
136	River Drive PS	02/28/11	02/28/11	6.25 hours	0.162	2.69	Rainfall	Inflow/infiltration. Station at rated capacity.
138	Sunliner PS	02/28/11	02/28/11	2 hours	0.01	1.96	Rainfall	Inflow/infiltration. Station at rated capacity.
145	Joelton PS	02/01/11	02/01/11	2.25 hours	0.02	1.13	Rainfall	Inflow/infiltration. Station at rated capacity.
145	Joelton PS	02/24/11	02/24/11	10.92 hours	0.04	2.74	Rainfall	Inflow/infiltration. Station at rated capacity.
217	Basswood Ave.	02/24/11	02/25/11	16.75 hours	0.934	2.59	Rainfall	
217	Basswood Ave.	02/28/11	03/01/11	16.34 hours	1.317	1.91	Rainfall	
379	622 Davidson	02/25/11	02/25/11	Unknown	0.00001	2.59	Rainfall	
379	622 Davidson	02/28/11	03/01/11	9 hours	0.001	1.91	Rainfall	