

# Monthly Overflow Report

Date Range: March, 2011

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	10405085C	03/01/11	03/01/11	1 hours	0.00001		Roots	515 Acklen cleanout -building backup -Line cleaned
000	16206138	03/04/11	03/04/11	1.25 hours	0.00001		Grit/Debris	5237 Tusculum Ct. - Line Cleaned
000	09611008	03/06/11	03/06/11	3.5 hours	0.00001		Grit/Debris	338 Hickory Place - Line Cleaned
000	07112072	03/08/11	03/08/11	1 hours	0.00001		Grit/Debris	714 Ward St. - Line Cleaned
000	08204034	03/09/11	03/09/11	27 hours	0.001	0.81	Grit/Debris	820 Seymour - drains to Washington CSS basin
000	18608046	03/17/11	03/17/11	0.75 hours	0.00001		Grit/Debris	8117 Middlewick Ln. - Line Cleaned
000	09308019	03/25/11	03/25/11	0.5 hours	0.0001	0.13	Grit/Debris	601 Crutcher St.- Line Cleaned
000	14711085	03/28/11	03/28/11	1.5 hours	0.0001	0.18	Grit/Debris	0 Cotton Ln. - Line Cleaned
000	97101002	03/29/11	03/29/11	1.5 hours	0.0001	0.09	Grit/Debris	2528 Old Mathews Rd. Cleanout - Line Cleaned
000	13404012	03/30/11	03/30/11	0.5 hours	0.001	0.93	Roots	1601 Citation Dr. - Line Cleaned, roots in service
130	Brown's Creek PS / Visco Dr.	03/02/11	03/02/11	0.67 hours	0.099		Electrical	ATS installation. Switched from primary to secondary feed.
130	Brown's Creek PS / Visco Dr.	03/11/11	03/11/11	0.17 hours	0.017	0.00	Electrical	Bad breaker on Lebanon Rd controls gear. Transfer to Riverside.
133	Holiday Travel Park PS	03/05/11	03/06/11	13 hours	0.01	1.25	Rainfall	Inflow/infiltration. Station at rated capacity.
133	Holiday Travel Park PS	03/08/11	03/09/11	4.25 hours	0.005	0.88	Rainfall	Inflow/infiltration. Station at rated capacity.
176	Dodson Chapel PS	03/06/11	03/06/11	1.5 hours	0.004		Rainfall	Inflow/infiltration. EQ basin full. Station at rated capacity.
184	Munn Rd PS	03/09/11	03/09/11	1.1 hours	0.005	0.88	Rainfall	Inflow/infiltration. Pump Station at rated capacity.
222	Barker Road	03/05/11	03/07/11	6.92 hours	0.059	1.25	Rainfall	Inflow/infiltration. EQ Pump Station at rated capacity.
222	Barker Road	03/09/11	03/10/11	1.17 hours	0.017	0.88	Rainfall	Inflow/infiltration. EQ Pump Station at rated capacity.
222	Barker Road	03/30/11	03/30/11	1 hours	0.006	1.31	Rainfall	Inflow/infiltration. EQ Pump Station at rated capacity.

---

# Monthly Overflow Report

Date Range: March, 2011

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
117	Neely's Bend PS	03/06/11	03/06/11	0.7 hours	0.005	1.14	Rainfall	Inflow/infiltration. Pump Station at rated capacity.

# Monthly Overflow Report

Date Range: March, 2011

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	06003022	03/03/11	03/03/11	0.75 hours	0.0001		Grit/Debris	120 Oak Valley Dr. - Line Cleaned
000	09004005	03/05/11	03/05/11	2 hours	0.001	1.35	Rainfall	6601 Centennial Blvd. (TDOT)
000	11616035	03/07/11	03/07/11	0.75 hours	0.00001		Grit/Debris	4004 Wallace Ln. Line Cleaned
000	01513002	03/16/11	03/16/11	2 hours	0.0001		Grit/Debris	7305 Whites Creek Pk. Line Cleaned
000	06007018	03/23/11	03/23/11	2 hours	0.00001	0.36	Grit/Debris	2925 Rich Acres Dr. - Line Cleaned
104	Whites Creek PS	03/05/11	03/07/11	36.91 hours	5.653	1.36	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	03/09/11	03/10/11	20.5 hours	1.374	0.76	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	03/05/11	03/05/11	9.58 hours	0.107	1.33	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	03/30/11	03/30/11	3.83 hours	0.052	1.11	Rainfall	Inflow/infiltration. Station at rated capacity.
217	Basswood Ave.	03/05/11	03/05/11	3.17 hours	0.012	1.35	Rainfall	516 Basswood Ave.