

Monthly Overflow Report

Date Range: May, 2011

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	10616033	05/03/11	05/04/11	24 hours	0.00001	1.89	Rainfall	412 Hollydale Dr.
000	07309066	05/03/11	05/04/11	19 hours	0.001	1.78	Rainfall	Cooper Terrace
000	09510050	05/03/11	05/04/11	41 hours	0.01	1.69	Rainfall	501 Bismark Dr
000	08602062	05/03/11	05/04/11	27 hours	0.001	1.69	Rainfall	Old Lebanon Dirt Rd.
000	08606106	05/03/11	05/04/11	26 hours	0.00001	1.69	Rainfall	5289 Old Hickory Blvd.
000	13607014	05/04/11	05/03/11	26 hours	0.00001	1.47	Rainfall	Timber Ridge Dr.
000	13204037	05/05/11	05/05/11	0.75 hours	0.001		Grit/Debris	2960 Armory Dr. Line Cleaned
000	07605033CO	05/30/11	05/30/11	6 hours	0.001		Roots	645 Debbie Dr. Line Cleaned
000	17312006	05/30/11	05/30/11	2 hours	0.001		Line Problem	Pettus, South of Blue Hole- bypass pump malfunction
000	WLS052E098	05/31/11	05/31/11	4 hours	0.00001		Force Main	5259 Rustic Way. Repaired forcemain cleanout
103	McCrary Creek PS	05/03/11	05/03/11	2 hours	0.081	1.74	Rainfall	Inflow/infiltration. Station at rated capacity.
124	Williamson Ferry PS	05/03/11	05/03/11	3.58 hours	0.043	1.93	Rainfall	Inflow/infiltration. Station at rated capacity.
133	Holiday Travel Park PS	05/03/11	05/03/11	15.9 hours	0.08	1.74	Rainfall	Inflow/infiltration. Station at rated capacity.
133	Holiday Travel Park PS	05/24/11	05/24/11	1 hours	0.01	2.03	Rainfall	Inflow/infiltration. Station at rated capacity.
134	Riverside Drive PS	05/03/11	05/03/11	10.2 hours	0.05	1.97	Rainfall	Inflow/infiltration. Station at rated capacity.
140	28th Avenue PS / Centennial	05/03/11	05/03/11	1.08 hours	0.002	1.97	Rainfall	Inflow/infiltration. Station at rated capacity.
151	Shelby Park PS	05/03/11	05/04/11	16.09 hours	1.424	1.93	Rainfall	Inflow/infiltration. Station at rated capacity.
158	Farmingham Woods PS	05/03/11	05/03/11	6.2 hours	0.01	1.74	Rainfall	Inflow/infiltration. Station at rated capacity.
221	Katie Avenue	05/03/11	05/04/11	19 hours	0.001	1.80	Rainfall	1313 Katie Ave.
222	Barker Road	05/03/11	05/05/11	39.16 hours	3.561	1.74	Rainfall	
226	Cowan St. Relief Bleeder	05/03/11	05/03/11	15.67 hours	1.029	1.93	Rainfall	
328	Cooper Lane	05/03/11	05/05/11	20 hours	0.001	1.78	Rainfall	Cooper Ln.
371	Apex St.	05/03/11	05/04/11	19 hours	0.001	1.78	Rainfall	Apex St.

Monthly Overflow Report

Date Range: May, 2011

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
106	Vandiver PS	05/03/11	05/03/11	11.5 hours	0.415	1.66	Rainfall	Inflow/infiltration. Station at rated capacity.
108	River Retreat	05/26/11	05/26/11	1 hours	0.01	0.61	Power Related	NES Power. Station generator out due to flood mitigation proj
109	Dry Creek PS	05/03/11	05/04/11	10.17 hours	2.107	1.66	Rainfall	
110	Loves Branch PS	05/03/11	05/03/11	6.92 hours	0.258	1.66	Rainfall	Inflow/infiltration. Station at rated capacity.
112	Gibson Creek PS	05/03/11	05/03/11	2.42 hours	0.279	1.66	Rainfall	Inflow/infiltration. Station at rated capacity.
117	Neely's Bend PS	05/03/11	05/03/11	16.7 hours	0.2	1.66	Rainfall	Inflow/infiltration. Station at rated capacity.
127	Madison Heights PS	05/03/11	05/03/11	5.1 hours	0.01	1.66	Rainfall	Inflow/infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	05/03/11	05/03/11	11.45 hours	0.05	1.66	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: May, 2011

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05911027	05/03/11	05/04/11	20 hours	0.001	1.80	Rainfall	701 Rowan Dr.
000	05910048	05/03/11	05/04/11	19 hours	0.001	1.80	Rainfall	3800 Dunbar Dr.
000	14405017	05/03/11	05/04/11	19 hours	0.0001	1.46	Rainfall	1318 Chickering Rd.
000	14405014	05/03/11	05/04/11	22 hours	0.001	1.46	Rainfall	4419 Chickering Ln.
000	05911028	05/03/11	05/04/11	21 hours	0.001	1.80	Rainfall	709 Rowan Dr.
000	06001013	05/03/11	05/05/11	47 hours	0.01	1.80	Rainfall	3258 Brick Church Pk.
000	05010029	05/03/11	05/04/11	24 hours	0.0001	1.80	Rainfall	3438 Briley Park Blvd.
000	09004030	05/03/11	05/03/11	3.75 hours	0.001	1.80	Rainfall	6514 Robertson Ave.
000	06004005CO	05/03/11	05/04/11	24 hours	0.001	1.78	Rainfall	120 Oak Valley Dr.
000	13014013	05/04/11	05/05/11	25 hours	0.001		Grit/Debris	1218 Chickering Rd.- Line Cleaned
000	10203046	05/23/11	05/23/11	0.5 hours	0.001	0.72	Roots	633 Galaxie Dr. Line Cleaned
104	Whites Creek PS	05/03/11	05/05/11	43.83 hours	7.197	1.97	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	05/23/11	05/23/11	0.42 hours	0.015	1.30	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	05/26/11	05/26/11	17 hours	1.947	1.19	Rainfall	Inflow/infiltration. Station at rated capacity.
107	West Park PS	05/03/11	05/03/11	0.33 hours	0.011	1.97	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	05/03/11	05/03/11	13.67 hours	0.709	1.97	Rainfall	Inflow/infiltration. Station at rated capacity.
145	Joelton PS	05/03/11	05/03/11	13.6 hours	0.05	1.97	Rainfall	Inflow/infiltration. Station at rated capacity.
217	Basswood Ave.	05/03/11	05/03/11	14.5 hours	0.743	1.97	Rainfall	
337	Richland Creek (TDOT)	05/03/11	05/04/11	18 hours	0.1	1.80	Rainfall	6601 Centennial Blvd.