

Monthly Overflow Report

Date Range: June, 2011

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	WLS052E098	06/02/11	06/02/11	7.5 hours	0.00001		Force Main	5259 Rustic Way Repaired force main cleanout
000	14705015CO	06/13/11	06/13/11	5 hours	0.0001		Grit/Debris	4837 Briarwood Dr. - Cleanout - Cleaned Line
000	10411066CO	06/14/11	06/14/11	4 hours	0.0001	0.05	Roots	2510 Barton Ave. Cleanout.- Cleaned line
000	17312006	06/15/11	06/15/11	3 hours	0.0001	1.04	Rainfall	Pettus Road, South of Blue Hole Rd.
000	13614012	06/18/11	06/18/11	1 hours	0.00001	0.26	Grit/Debris	637 Lake Terrace Dr- Cleaned line
102	Smith Springs PS	06/28/11	06/28/11	0.33 hours	0.004	1.76	Rainfall	Intense Rain. Station at rated capacity.
155	Woodland Point PS #1	06/07/11	06/07/11	3.25 hours	0.005	0.00	Other/not listed	Operator error. Station returned to service.
158	Farmingham Woods PS	06/05/11	06/05/11	0.25 hours	0.001	0.15	Power Related	NES Power. Portable generator dispatched. Overflow contained.
158	Farmingham Woods PS	06/28/11	06/28/11	7.7 hours	0.05	1.86	Power Related	NES Power. Portable generator dispatched.

Monthly Overflow Report

Date Range: June, 2011

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04302011	06/07/11	06/07/11	1.75 hours	0.0001		Grit/Debris	713 May Dr. Cleaned Line
150	Hidden Acres PS	06/21/11	06/25/11	101 hours	0.4	0.30	Controller	Bad compressor on bubbler. HW/OF alarm failed.

Monthly Overflow Report

Date Range: June, 2011

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05003060	06/13/11	06/13/11	3 hours	0.001		Grit/Debris	1818 Apple Valley Cr.- Cleaned Line
000	04101021	06/24/11	06/24/11	0.5 hours	0.00001		Grit/Debris	5000 Cobblestone Creek Dr.- Cleaned line
145	Joelton PS	06/28/11	06/28/11	1.25 hours	0.005	1.01	Rainfall	Inflow/infiltration. Station at rated capacity.