

# Monthly Overflow Report

Date Range: August, 2011

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	17315009	08/01/11	08/01/11	11 hours	0.017		Line Break	905 Barnes Road - Repaired Weld- Contractor bypass pipe
000	16207032	08/02/11	08/02/11	0.5 hours	0.0001		Grit/Debris	150 Tusculum Road - Cleaned line
000	16206108	08/04/11	08/04/11	1.5 hours	0.00001		Roots	224 Old Tusculum Road - Cleaned line
000	08602010	08/15/11	08/15/11	2 hours	0.00001		Roots	7002 Panama Drive - Cleaned line
000	14810001	08/16/11	08/16/11	0.5 hours	0.00001		Grit/Debris	3939 Apache Trail - Cleaned line
000	16510001	08/16/11	08/16/11	4 hours	0.00001		Grit/Debris	3959 Pin Hook Road - Cleaned line
000	16204023	08/16/11	08/17/11	5 hours	0.001		Grit/Debris	4157 Apache Trail - Cleaned line
000	16407009	08/20/11	08/20/11	0.2 hours	0.00003		Air Relief Valve	152 Grovedale Ter. 2" ARV nipple replaced. Sewage vactored.
000	14816007	08/28/11	08/28/11	2 hours	0.00001		Grit/Debris	2315 Antioch Pk. - Cleaned line
000	11704014	08/29/11	08/29/11	0.5 hours	0.0001		Grit/Debris	2916 Primrose Cr. - Cleaned line
103	McCrary Creek PS	08/02/11	08/02/11	0.33 hours	0.003	0.00	Controller	Blown control fuse. Fuse replaced.

---

# Monthly Overflow Report

Date Range: August, 2011

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	05203003	08/26/11	08/26/11	0.5 hours	0.0001		Grit/Debris	434 Larkin Springs Rd - Cleaned line

---

# Monthly Overflow Report

Date Range: August, 2011

---

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	01416001	08/28/11	08/30/11	45 hours	0.05	0.00	Grit/Debris	Blockage discovered 8/30 @ 8:30 am. Blockage cleared by 9am.