

Monthly Overflow Report

Date Range: September, 2011

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09510050	09/06/11	09/06/11	2 hours	0.001	4.54	Rainfall	501 Bismark Dr.
000	14903012	09/06/11	09/06/11	1 hours	0.00001	4.73	Grit/Debris	2510 Sleepy Hollow - Cleaned Line
000	08309109	09/07/11	09/07/11	0.5 hours	0.0001		Grit/Debris	1406 Woodland St.- Cleaned Line
000	14812054	09/08/11	09/08/11	1.25 hours	0.0001		Grease	117 Dowdy Ct. Cleaned Line
000	10511027	09/11/11	09/11/11	1.25 hours	0.00001		Grit/Debris	300 Rains Ave
000	09208060	09/19/11	09/19/11	4.5 hours	0.00001	0.21	Roots	308 15th Ave. N. - Cleaned Line
000	11802066	09/19/11	09/19/11	0.5 hours	0.0001	0.21	Grit/Debris	819 Horner Ave. - Cleaned Line
000	09310147	09/20/11	09/20/11	1.25 hours	0.0001	0.30	Grit/Debris	314 Molloy St. - Cleaned line
000	10415003	09/26/11	09/26/11	2 hours	0.00001		Grit/Debris	2607 Natchez Trace - Cleaned Line
000	10704055	09/27/11	09/27/11	1.25 hours	0.00001		Roots	83 Century Blvd - Cleaned line
000	14810013	09/28/11	09/28/11	1 hours	0.0001		Grease	3939 Apache Trail Clean out - Cleaned Line
000	15014009	09/29/11	09/29/11	1 hours	0.001	0.03	Grease	4101 Tea Garden Way - Cleaned Line
102	Smith Springs PS	09/06/11	09/06/11	3.83 hours	0.095	4.57	Rainfall	Inflow/infiltration. Station at rated capacity. EQ basins full.
130	Brown's Creek PS / Visco Dr.	09/05/11	09/06/11	7.25 hours	0.248	4.91	Rainfall	Inflow/infiltration. Station at rated capacity.
222	Barker Road	09/05/11	09/08/11	44.5 hours	7.999	4.54	Rainfall	149 Barker Rd.

Monthly Overflow Report

Date Range: September, 2011

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	01416001	09/10/11	09/12/11	34 hours	0.04		Grit/Debris	3" PVC pipe blocking sewer line between MH 1 and wetwell.
107	West Park PS	09/06/11	09/06/11	1.42 hours	0.312	3.67	Rainfall	Inflow/infiltration. Station at rated capacity. EQ basin full.
217	Basswood Ave.	09/06/11	09/06/11	1.42 hours	0.004	3.67	Rainfall	