

# Monthly Overflow Report

Date Range: October, 2011

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	08514060	10/06/11	10/06/11	2.5 hours	0.06	0.00	Air Relief Valve	2" galvanized pipe nipple broken. Replaced pipe nipple and ARV.
000	14812039	10/06/11	10/06/11	0.5 hours	0.001		Roots	4716 McBride Rd. Cleaned Line
000	08301085	10/17/11	10/17/11	2 hours	0.0001		Grit/Debris	1116 Greenwood Ave. Basement backup - Cleaned Line
000	10704055	10/17/11	10/17/11	3.25 hours	0.0001		Roots	83 Century Blvd. Cleaned Line
000	10516067	10/24/11	10/24/11	1 hours	0.001		Line Break	2134 Canady Ave. Repaired same line as Kline
000	11804053	10/24/11	10/24/11	0.5 hours	0.0001		Line Break	2203 Kline Ave. - Repaired bad spot in liner
000	16303011	10/26/11	10/26/11	1.5 hours	0.001		Grit/Debris	660 Bell Rd. Cleaned Line
000	13304048	10/31/11	11/01/11	26.25 hours	0.01		Line Break	94 Antioch Pk. Cleaned line, later found broken line & repaired

---

# Monthly Overflow Report

Date Range: October, 2011

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
109	Dry Creek PS	10/11/11	10/11/11	0.33 hours	0.03		Repairs/Mechanical Problems	Construction at treatment plant

---

# Monthly Overflow Report

Date Range: October, 2011

---

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	06015009CO	10/23/11	10/23/11	3 hours	0.0001		Roots	2700A Brunswick Dr. Cleaned line. Overflow at cleanout.