

Monthly Overflow Report

Date Range: November, 2011

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	16208026	11/04/11	11/04/11	1 hours	0.00001		Roots	4924 Shihman Dr. Cleaned Line
000	14807040CO	11/09/11	11/09/11	2 hours	0.0001		Roots	1508 Denise Ct. Cleaned Line. Overflow inside home
000	09401149	11/10/11	11/10/11	4 hours	0.001		Roots	2009 Sevier St. Cleaned Line
000	16208027	11/13/11	11/13/11	3 hours	0.00001		Grit/Debris	29 Benzing Rd. Cleaned Line
000	09216121CO	11/17/11	11/17/11	2 hours	0.0001		Grit/Debris	2806 Batavia St. Clean out - Cleaned line
000	07404104	11/19/11	11/19/11	2 hours	0.001		Grit/Debris	723 Linden Green Cleaned Line
000	09510050	11/28/11	11/29/11	11 hours	0.001	2.38	Rainfall	501 Bismark Dr.
000	08110058	11/28/11	11/28/11	1 hours	0.0001	2.34	Grit/Debris	1713 26th Ave. North - Cleaned Line
000	14805033	11/28/11	11/28/11	2.5 hours	0.0001	2.38	Grit/Debris	301 Margo Lane -Cleaned Line
102	Smith Springs PS	11/28/11	11/28/11	8.67 hours	0.533	1.97	Rainfall	Inflow/infiltration - station at rated capacity. EQ basins full.
133	Holiday Travel Park PS	11/27/11	11/28/11	13.65 hours	0.07	2.31	Rainfall	Inflow/infiltration - station at rated capacity.
134	Riverside Drive PS	11/28/11	11/28/11	7.9 hours	0.04	2.28	Rainfall	Inflow/infiltration - station at rated capacity.
151	Shelby Park PS	11/28/11	11/28/11	6.92 hours	1.002	2.13	Rainfall	Inflow/infiltration - station at rated capacity.
222	Barker Road	11/21/11	11/21/11	1.92 hours	0.022	0.69	Controller	Controller malfunction. EQ basin did not fill early in event.
222	Barker Road	11/27/11	11/29/11	35 hours	2.469	2.42	Rainfall	Inflow/infiltration. EQ basin full.

Monthly Overflow Report

Date Range: November, 2011

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05305012	11/01/11	11/01/11	3 hours	0.001		Grit/Debris	1262 Sioux Ter. - Cleaned Line - overflow out of line break
106	Vandiver PS	11/28/11	11/28/11	4.33 hours	0.02	2.48	Rainfall	Inflow/infiltration - station at rated capacity.
109	Dry Creek PS	11/28/11	11/29/11	20.58 hours	23.192	1.61	Rainfall	Inflow/infiltration. Repairs being made on final tanks.

Monthly Overflow Report

Date Range: November, 2011

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	12911005	11/05/11	11/05/11	1.5 hours	0.001		Roots	6539 Melinda Dr. Cleaned Line
000	09016017CO	11/21/11	11/21/11	2.5 hours	0.0001	0.91	Roots	442 American Rd. Clean out - Cleaned line
000	06001013	11/28/11	11/29/11	24 hours	0.001	2.13	Rainfall	3258 Brick Church Pk.
000	05013010	11/28/11	11/29/11	24 hours	0.001	2.13	Rainfall	3300 Briley Park Blvd S
000	05010033	11/28/11	11/28/11	13 hours	0.001	2.13	Rainfall	3414 Brick Church Pk.
000	05010029	11/28/11	11/29/11	24 hours	0.001	2.13	Rainfall	3438 Briley Park Blvd N
104	Whites Creek PS	11/06/11	11/06/11	0.75 hours	0.012	0.00	Controller	Bubbler control system malfunction. Replaced bubbler system.
104	Whites Creek PS	11/21/11	11/21/11	6.08 hours	0.246	0.83	Rainfall	Inflow/infiltration - station at rated capacity.
104	Whites Creek PS	11/27/11	11/28/11	10.08 hours	1.508	2.23	Rainfall	Inflow/infiltration - station at rated capacity.
107	West Park PS	11/28/11	11/28/11	0.08 hours	0.015	2.34	Rainfall	Inflow/infiltration - station at rated capacity. EQ basin full.
114	Davidson Branch PS	11/21/11	11/21/11	5.92 hours	0.2	0.91	Rainfall	Inflow/infiltration - station at rated capacity.
114	Davidson Branch PS	11/27/11	11/28/11	21.58 hours	1.043	2.34	Rainfall	Inflow/infiltration - station at rated capacity.
145	Joelton PS	11/28/11	11/28/11	15 hours	0.05	2.32	Rainfall	Inflow/infiltration - station at rated capacity.
217	Basswood Ave.	11/28/11	11/28/11	10.75 hours	0.127	2.34	Rainfall	516 Basswood Ave.
337	Richland Creek (TDOT)	11/28/11	11/28/11	5 hours	0.001	2.34	Rainfall	6601 Centennial Blvd. (TDOT)