

# Monthly Overflow Report

Date Range: December, 2011

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	16204027CO	12/10/11	12/10/11	1.5 hours	0.0001		Grit/Debris	617 Tuscaraora Dr. at Cleanout- Cleaned Line
000	07601053	12/17/11	12/17/11	0.75 hours	0.00001		Grit/Debris	829 Oak Leaf Dr. Cleaned Line
000	09309093	12/18/11	12/18/11	3 hours	0.00001		Line Break	919 Broadway - Repaired line
000	08208034	12/18/11	12/18/11	2.5 hours	0.001		Grit/Debris	828 Seymour Ave. Cleaned Line
000	12005054	12/19/11	12/19/11	1 hours	0.0001		Roots	416 McDonald Dr. Cleaned Line
000	11913091	12/19/11	12/19/11	2 hours	0.001		Grit/Debris	2928 Louise Dr. Cleaned Line
000	08114043CO	12/20/11	12/20/11	19.75 hours	0.0001	0.17	Roots	2404 Scovel St. Clean out - Cleaned Line
000	14703095	12/21/11	12/21/11	1.5 hours	0.00001	0.16	Grit/Debris	370 Wallace Rd. Cleaned Line
000	08213093	12/28/11	12/28/11	1 hours	0.00001		Grit/Debris	915 9th Avenue North at Cleanout. Cleaned Line
000	11706063	12/28/11	12/28/11	2.75 hours	0.0001		Grit/Debris	4751 Lebanon Road - Cleaned Line
103	McCrary Creek PS	12/06/11	12/06/11	2.08 hours	0.072	1.51	Rainfall	Inflow/infiltration. Station at rated capacity.
133	Holiday Travel Park PS	12/05/11	12/06/11	10.7 hours	0.07	1.51	Rainfall	Inflow/infiltration. Station at rated capacity.
134	Riverside Drive PS	12/05/11	12/05/11	5.65 hours	0.04	1.71	Rainfall	Inflow/infiltration. Station at rated capacity.
222	Barker Road	12/05/11	12/07/11	26 hours	1.536	1.59	Rainfall	Inflow/infiltration. EQ tank full.
222	Barker Road	12/22/11	12/22/11	1.42 hours	0.007	0.71	Rainfall	Inflow/infiltration. EQ basin full.
222	Barker Road	12/27/11	12/27/11	2.17 hours	0.017	0.97	Rainfall	Inflow/infiltration. Modified EQ facility to divert flow earlier.
226	Cowan St. Relief Bleeder	12/05/11	12/05/11	7.92 hours	0.33	1.77	Rainfall	Inflow/infiltration. Station at rated capacity.

# Monthly Overflow Report

Date Range: December, 2011

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
106	Vandiver PS	12/05/11	12/05/11	6.08 hours	0.075	1.99	Rainfall	Inflow/infiltration. Station at rated capacity.
117	Neely's Bend PS	12/05/11	12/06/11	30.7 hours	0.3	1.99	Rainfall	Inflow/infiltration. Station at rated capacity.
127	Madison Heights PS	12/05/11	12/05/11	3.8 hours	0.1	1.99	Rainfall	Inflow/infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	12/05/11	12/06/11	10.5 hours	0.08	1.99	Rainfall	Inflow/infiltration. Station at rated capacity.

# Monthly Overflow Report

Date Range: December, 2011

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	13007001CO	12/05/11	12/05/11	1.5 hours	0.001	1.71	Rainfall	803 Lynnwood Blvd. at Cleanout
000	10314008	12/16/11	12/16/11	0.5 hours	0.001	0.40	Roots	47 Brookwood Terr. - Cleaned Line
000	05904085	12/20/11	12/20/11	1.75 hours	0.001	0.17	Grit/Debris	2895 Creekbend Dr. Cleaned Line
000	14409005	12/30/11	12/30/11	0.5 hours	0.00001		Grit/Debris	4362 Chickering Lane - Cleaned Line
104	Whites Creek PS	12/05/11	12/07/11	26.5 hours	2.618	1.76	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	12/27/11	12/27/11	0.42 hours	0.013	0.88	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	12/05/11	12/06/11	16.33 hours	0.622	1.84	Rainfall	Inflow/infiltration. Station at rated capacity.
145	Joelton PS	12/05/11	12/05/11	14.3 hours	0.1	1.77	Rainfall	Inflow/infiltration. Station at rated capacity.