

# Monthly Overflow Report

Date Range: January, 2012

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	14604012	01/02/12	01/02/12	1.5 hours	0.0001		Roots	4706 Richmar Ct. - Cleaned line - Building Backup
000	09805076CO	01/09/12	01/09/12	2 hours	0.0001	0.13	Roots	504 New Castle Lane Clean out - Cleaned Line
000	09510050	01/11/12	01/11/12	16 hours	0.001	1.62	Rainfall	501 Bismark Dr.
000	10616031	01/11/12	01/11/12	19.5 hours	0.002	1.94	Rainfall	412 Hollydale Dr.+ 408 Hollydale MH32
000	07208094CO	01/16/12	01/16/12	0.75 hours	0.00001	0.03	Roots	1609 Berrywood Rd. - Cleaned Line- Building Backup
000	07504236CO	01/19/12	01/19/12	2.5 hours	0.00001		Roots	4786 Trenton Dr. - Cleaned Line- Building Backup
000	09510050	01/23/12	01/23/12	1 hours	0.001	1.03	Rainfall	501 Bismark Dr.
000	09316055CO	01/30/12	01/30/12	3 hours	0.0001		Grit/Debris	73 Robertson St. Clean out - Cleaned Line
103	McCroy Creek PS	01/23/12	01/23/12	2.67 hours	0.059	1.03	Rainfall	Inflow/infiltration. Station at rated capacity.
124	Williamson Ferry PS	01/11/12	01/11/12	1.92 hours	0.041	1.83	Rainfall	Inflow/infiltration. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	01/11/12	01/11/12	3.67 hours	0.231	1.94	Rainfall	Inflow/infiltration. Station at rated capacity. #2 VFD cell bad.
130	Brown's Creek PS / Visco Dr.	01/23/12	01/23/12	0.08 hours	0.002	0.92	Rainfall	Inflow/infiltration. Station at rated capacity.
133	Holiday Travel Park PS	01/11/12	01/11/12	7.9 hours	0.1	1.67	Rainfall	Inflow/infiltration. Station at rated capacity.
134	Riverside Drive PS	01/11/12	01/11/12	6.75 hours	0.05	1.67	Rainfall	Inflow/infiltration. Station at rated capacity.
140	28th Avenue PS / Centennial	01/12/12	01/12/12	0.67 hours	0.023	1.67	Rainfall	Inflow/infiltration. Station at rated capacity.
151	Shelby Park PS	01/11/12	01/11/12	6.5 hours	1.031	1.83	Rainfall	Inflow/infiltration. Station at rated capacity.
158	Farmingham Woods PS	01/11/12	01/11/12	5.1 hours	0.05	1.67	Rainfall	Inflow/infiltration. Station at rated capacity.
222	Barker Road	01/11/12	01/11/12	14.17 hours	0.348	1.62	Rainfall	149 Barker Road. Inflow/infiltration - EQ basin full.
222	Barker Road	01/23/12	01/23/12	0.42 hours	0.0005	1.03	Rainfall	Inflow/infiltration. EQ basin 80% full.
226	Cowan St. Relief Bleeder	01/11/12	01/11/12	9.83 hours	0.493	1.83	Rainfall	Inflow/infiltration.
226	Cowan St. Relief Bleeder	01/23/12	01/23/12	3.58 hours	0.039	0.71	Rainfall	Inflow/infiltration.
371	Apex St.	01/11/12	01/11/12	3 hours	0.001	1.83	Rainfall	Inflow/infiltration.

# Monthly Overflow Report

Date Range: January, 2012

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	04310010CO	01/23/12	01/23/12	1.5 hours	0.0001	0.91	Grit/Debris	616 N DuPont Ave. Clean out -Cleaned Line
106	Vandiver PS	01/11/12	01/11/12	3.25 hours	0.061	1.80	Rainfall	Inflow/infiltration. Station at rated capacity.
109	Dry Creek PS	01/11/12	01/11/12	6.08 hours	0.822	1.62	Rainfall	Inflow/infiltration. 2 pumps being rebuilt.
110	Loves Branch PS	01/11/12	01/11/12	9.25 hours	0.44	1.62	Rainfall	Inflow/infiltration. Station at rated capacity.
112	Gibson Creek PS	01/11/12	01/11/12	1.75 hours	0.188	1.62	Rainfall	Inflow/infiltration. Station at rated capacity.
112	Gibson Creek PS	01/24/12	01/24/12	1.33 hours	0.136	0.87	Rainfall	Inflow/infiltration. Station at rated capacity.
127	Madison Heights PS	01/11/12	01/11/12	3.5 hours	0.01	1.63	Rainfall	Inflow/infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	01/11/12	01/11/12	2.3 hours	0.5	1.63	Rainfall	Inflow/infiltration. Station at rated capacity.

# Monthly Overflow Report

Date Range: January, 2012

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	13103010	01/11/12	01/11/12	4.5 hours	0.001	1.23	Rainfall	2000 Galbraith Dr.
000	06001013	01/11/12	01/11/12	6 hours	0.002	1.83	Rainfall	3258 Brick Church Pike
104	Whites Creek PS	01/11/12	01/11/12	4.5 hours	0.55	1.65	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	01/23/12	01/23/12	5.08 hours	0.384	0.93	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	01/26/12	01/27/12	1.83 hours	0.097	0.70	Rainfall	Inflow/infiltration. Station at rated capacity.
107	West Park PS	01/11/12	01/11/12	3.08 hours	0.148	1.90	Rainfall	Inflow/infiltration. Station at rated capacity, EQ filled.
114	Davidson Branch PS	01/11/12	01/11/12	12.75 hours	0.679	1.90	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	01/23/12	01/23/12	11.33 hours	0.007	0.88	Rainfall	Inflow/infiltration. Station at rated capacity.
138	Sunliner PS	01/11/12	01/11/12	0.95 hours	0.001	1.91	Rainfall	Inflow/infiltration. Station at rated capacity.
145	Joelton PS	01/11/12	01/12/12	25.8 hours	0.2	1.64	Rainfall	Inflow/infiltration. Station at rated capacity.
145	Joelton PS	01/23/12	01/23/12	1.6 hours	0.01	0.94	Rainfall	Inflow/infiltration. Station at rated capacity.
145	Joelton PS	01/26/12	01/27/12	5 hours	0.05	0.76	Rainfall	Inflow/infiltration. Station at rated capacity.
217	Basswood Ave.	01/11/12	01/11/12	2.17 hours	0.023	1.90	Rainfall	
346	3428 Briley/Brick Church	01/11/12	01/11/12	6.25 hours	0.002	1.83	Rainfall	3414 Brick Church Pike + 3438 Briley Pkwy Blvd.
347	3300 Briley/Brick Church	01/11/12	01/11/12	6.5 hours	0.001	1.83	Rainfall	3300 Briley Park Blvd.