

Monthly Overflow Report

Date Range: February, 2012

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09204002	02/06/12	02/06/12	1 hours	0.0001		Line Break	909 Warren St. Repaired Line
000	13204006	02/07/12	02/07/12	1.25 hours	0.0001		Grit/Debris	2979 Sidco Dr. Cleaned Line
000	06509117	02/12/12	02/12/12	4 hours	0.0001		Grit/Debris	4753 Cascade Dr. Cleaned Line
000	09211039	02/14/12	02/14/12	1.75 hours	0.0001		Line Break	176 Anthes Dr. Repaired Line
000	07107044	02/20/12	02/20/12	1 hours	0.0001		Grit/Debris	105 E. Trinity Lane - Cleaned Line
000	13413017	02/22/12	02/22/12	0.75 hours	0.0001		Grease	221 Largo Dr. Clean out. Cleaned line
000	14805028	02/24/12	02/24/12	2 hours	0.0001		Roots	3812 Briarcliff St. Cleaned Line
000	10403052	02/29/12	02/29/12	0.25 hours	0.0001		Line Break	2421 Vanderbilt Pl. in gym caused by contractor rod in main

Monthly Overflow Report

Date Range: February, 2012

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05207054	02/29/12	02/29/12	1.25 hours	0.001		Grit/Debris	621 Center St. Cleaned line