

Monthly Overflow Report

Date Range: March, 2012

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09614095	03/02/12	03/02/12	20 hours	0.001		Grit/Debris	917 Colfax Dr. - Cleaned Line
000	08702034	03/03/12	03/03/12	0.75 hours	0.001		Grit/Debris	4621 Raccoon Tr. - Cleaned Line
000	13403009	03/15/12	03/15/12	2 hours	0.001		Grit/Debris	1501 Murfreesboro Pk. - Cleaned Line
000	16116044	03/20/12	03/20/12	0.5 hours	0.001		Grit/Debris	5837 Nolensville Pk. - Cleaned Line
000	11003010	03/26/12	03/26/12	5 hours	0.0001		Line Break	2729 Alvin Sperry Pass - Repaired Force Main
000	13214005	03/29/12	03/29/12	1 hours	0.0001		Grit/Debris	4815 Franklin Pike - Cleaned Line
133	Holiday Travel Park PS	03/08/12	03/09/12	8.5 hours	0.1	1.80	Rainfall	Inflow/infiltration. Station at rated capacity.
158	Farmingham Woods PS	03/08/12	03/08/12	4.5 hours	0.05	1.80	Rainfall	Inflow/infiltration. Station at rated capacity.
222	Barker Road	03/08/12	03/09/12	5.66 hours	0.304	1.68	Rainfall	Inflow/infiltration. EQ basin full. Station at rated capacity.
226	Cowan St. Relief Bleeder	03/08/12	03/09/12	7.84 hours	0.344	1.65	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: March, 2012

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05106023	03/08/12	03/08/12	0.5 hours	0.0001		Grit/Debris	1202 Briarville Rd.- Cleaned Line
106	Vandiver PS	03/08/12	03/08/12	2.75 hours	0.017	1.79	Rainfall	Inflow/infiltration. Station at rated capacity.
112	Gibson Creek PS	03/08/12	03/08/12	1.83 hours	0.147	1.54	Rainfall	Inflow/infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	03/08/12	03/08/12	2.5 hours	0.05	1.54	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: March, 2012

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09113054	03/31/12	04/01/12	8.5 hours	0.001		Line Break	5917 Charlotte Pike - Repaired Line
104	Whites Creek PS	03/08/12	03/10/12	33.98 hours	3	1.63	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	03/08/12	03/08/12	6.42 hours	0.451	1.65	Rainfall	Inflow/infiltration. Station at rated capacity.
145	Joelton PS	03/08/12	03/09/12	17.5 hours	0.2	1.71	Rainfall	Inflow/infiltration. Station at rated capacity.
145	Joelton PS	03/16/12	03/16/12	7 hours	0.1	0.59	Rainfall	Inflow/infiltration. Station at rated capacity.