

Monthly Overflow Report

Date Range: April, 2012

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07508186	04/06/12	04/06/12	1 hours	0.001		Grit/Debris	706 Frankfort Dr. - Cleaned Line
000	14704049	04/16/12	04/16/12	0.5 hours	0.0001	0.12	Grit/Debris	3705 Faulkner Dr. - Cleaned Line
000	16206079	04/16/12	04/16/12	0.5 hours	0.00001	0.12	Roots	152 Tusculum Rd. - Cleaned Line
000	08413006	04/16/12	04/16/12	0.5 hours	0.0001	0.14	Grit/Debris	149 Barker Rd. - Cleaned Line
000	09215057	04/16/12	04/16/12	0.5 hours	0.00001	0.23	Grit/Debris	311 23rd Ave. N. - Cleaned Line
000	16202004	04/30/12	04/30/12	1 hours	0.0001		Grit/Debris	1432 Coleridge Dr. - Cleaned Line
130	Brown's Creek PS / Visco Dr.	04/02/12	04/02/12	0.25 hours	0.025		Controller	Controller problem. New I/O added to SCADA.

Monthly Overflow Report

Date Range: April, 2012

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14513062	04/03/12	04/03/12	4 hours	0.00001		Grit/Debris	1945 Edenbridge Way - Cleaned Line
114	Davidson Branch PS	04/05/12	04/06/12	7.58 hours	0.45	1.76	Rainfall	Inflow/Infiltration. Station at rated capacity.
145	Joelton PS	04/05/12	04/06/12	4.5 hours	0.1	1.99	Rainfall	Inflow/Infiltration. Station at rated capacity.