

Monthly Overflow Report

Date Range: May, 2012

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	17308022	05/01/12	05/01/12	1 hours	0.0001		Grit/Debris	5401 Oak Chase Dr. Cleaned Line
000	16003020	05/09/12	05/09/12	5 hours	0.0001		Line Break	5325 Overton Road. Repaired Line
000	09713013CO	05/23/12	05/23/12	1 hours	0.0001		Grit/Debris	3248 Blackwood Dr. Clean out - Cleaned Line
000	10901PSFM	05/29/12	05/29/12	1 hours	0.001		Force Main	Broken 6" forcemain from The Lakes PS. Repaired forcemain.
000	08206002	05/31/12	05/31/12	0.75 hours	0.0001		Grit/Debris	836 Joseph Ave.
133	Holiday Travel Park PS	05/13/12	05/13/12	11 hours	0.5	1.74	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: May, 2012

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04316001	05/30/12	05/30/12	0.5 hours	0.0001		Air Relief Valve	Air relief valve replaced on River Retreat 8" FM.
106	Vandiver PS	05/13/12	05/13/12	5.17 hours	0.024	3.11	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: May, 2012

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
104	Whites Creek PS	05/13/12	05/14/12	16.42 hours	2.482	2.56	Rainfall	Inflow/Infiltration. Station at rated capacity.
114	Davidson Branch PS	05/13/12	05/13/12	5.92 hours	0.238	3.10	Rainfall	Inflow/Infiltration. Station at rated capacity.
145	Joelton PS	05/13/12	05/14/12	26 hours	0.2	4.14	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	05/13/12	05/13/12	2.5 hours	0.032	3.10	Rainfall	Inflow/infiltration.